

SSO Notification List

April 2016

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	4/1/2016	3000 Reisterstown Rd	21215	Rags, Grease	WWO	N/A	116	Heavy gray water overflowing	232	Relieved mainline choke with 175 ft press truck on 8" line	CCTV	298523
2	4/2/2016	18 W 25th St	21218	Rags, Grease	WWO	N/A	76	Heavy gray water overflowing	760	Relieved mainline choke with 165 ft press truck on 8" line	CCTV	298674
3	4/3/2016	2600 Strathmore Ave	21214	Rags, Grease, Trash, Sand, Gravel, Rocks	WWO	N/A	56	Heavy gray water overflowing	280	Relieved mainline choke with 250 ft of pressure truck on 8" line	CCTV	298815
4	4/4/2016	4004 Maine Ave	21207	Roots	WWO	N/A	Not Witnessed	Gray water	Evidence of Overflow	Relieved house connection choke with 100 ft of electric machine	CCTV	239681
5	4/5/2016	2223 Wheatley Dr	21207	Rags, Roots	WWO	N/A	62	Sewer water overflowing	310	Relieved mainline choke with 250 ft of pressure truck on 8" line	CCTV	298987
6	4/5/2016	1900 Ashburton St	21216	Rags, Grease	WWO	Gwynns Falls	95	Clear water overflowing from manhole	475	Relieved mainline choke with 175 ft of pressure truck on 8" line	CCTV	299085
7	4/5/2016	1630 Moreland Ave	21216	Roots, Trash, Sand, Gravel, Rocks	WWO	N/A	Not Witnessed	Gray water and debris	Evidence of Overflow	Relieved house connection choke with 45 ft of electric machine	CCTV	299039
8	4/5/2016	1550 Bruce Ct	21217	Rags	WWO	N/A	Not Witnessed	Found evidence of overflow at location	Evidence of Overflow	Relieved mainline choke with 200 ft of pressure truck	CCTV	299142
9	4/7/2016	5300 Holabird Ave	21224	Rags	WWO	Inner Harbor	235	Cloudy water	2,350	Relieved mainline choke with pressure truck	CCTV	299441
10	4/7/2016	222 N Greene St	21201	Rags	WWO	N/A	Not Witnessed	Signs of overflow around the clean out and rear yard	Evidence of Overflow	Relieved house connection choke with 45 ft of electric machine	CCTV mainline	299502
11	4/7/2016	1217 N Patterson Pak Ave	21213	Rags, Grease	WWO	N/A	Not Witnessed	Found evidence of an overflow. Rear house connection choke	Evidence of Overflow	Relieved house connection choke with 30 ft of electric machine	CCTV	299552
12	4/7/2016	718 Lennox St	21217	Unknown	WWO	N/A	Not Witnessed	Gray water and toilet paper	Evidence of Overflow	Left plumbers notice to remove clean out cap.	Refer call back	299535
13	4/7/2016	1801 Chelsea Rd	21216	Rags, Trash, Sand, Gravel, Rocks	WWO	N/A	144	Tissue an debris overflowing	720	Pressure truck relieved mainline choke with 400 ft of pressure	CCTV mainline	299521
14	4/8/2016	1800 Falls Rd	21211	Rags, Grease, Trash, Sand, Gravel, Rocks	WWO	N/A	Not Witnessed	Heavy gray water	Evidence of Overflow	Mainline overcharged due to heavy rain event, removed debris from street	Will monitor location, no CCTV	299701
15	4/8/2016	2023 McHenry St	21223	Rags, Trash, Sand, Gravel, Rocks	WWO	N/A	625	Sewer water overflowing	1,250	Relieved house connection choke with 15 ft of electric machine on 6" line	CCTV	299703
16	4/9/2016	1138 Scott St	21230	Trash, Sand, Gravel, Rocks	WWO	N/A	Not Witnessed	Paper and feces	Evidence of Overflow	Relieved house connection choke with electric machine	CCTV	299748

SSO Notification List

April 2016

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
17	4/11/2016	239 N Monroe St	21223	Rags	WWO	N/A	Not Witnessed	Heavy debris	Evidence of Overflow	Relieved house connection choke with 30 ft of electric machine on 6" line	CCTV	299961
18	4/12/2016	830 N Broadway	21205	Rags, Grease	WWO	N/A	Not Witnessed	Gray water and evidence	Evidence of Overflow	Used 45ft of electric machine, could not relieve choke. Used bypass pumping	CCTV	3000172
19	4/12/2016	820 Bridgeview Rd	21225	Rags, Grease, Trash, Sand, Gravel, Rocks	WWO	N/A	96	Gray water overflowing	192	Relieved mainline choke with 200 ft of sewer jet	CCTV	300183
20	4/12/2016	1013 Darley Ave	21218	Rags	WWO	N/A	Not Witnessed	Paper and rags	Evidence of Overflow	Used electric machine and sewer jet and to relieve house connection choke	CCTV	300176
21	4/13/2016	1701 Sulgrave Ave	21209	Rags, Roots	WWO	Jones Falls	81	Tissue and debris	405	Used 30ft of electric machine to relieve house connection choke	CCTV	300393
22	4/13/2016	903 Nottingham Rd	21229	Rags, Roots	WWO	N/A	241	Heavy gray water	482	Relieved mainline choke with 400 ft of pressure truck on 8 in line	CCTV	300348
23	4/13/2016	4213 Ridge Wood Ave	21215	Rags	WWO	N/A	Not Witnessed	Paper and debris	Evidence of Overflow	Used 60 ft of electric machine to relieve house connection choke	CCTV	300375
24	4/13/2016	1318 Hull St	21230	Rags	WWO	N/A	Not Witnessed	Water, paper and debris around the clean out	Evidence of Overflow	Relieved house connection choke with sewer jet and electric machine	CCTV	300421
25	4/14/2016	1507 N Collington Ave	21213	Pipe Break	WWO	N/A	Not Witnessed	Gray water and evidence	Evidence of Overflow	Ran 9 ft of electric machine to relieve house connection choke	Refer for repairs to construction	300505
26	4/14/2016	305 E University Pkwy	21218	Rags, Roots	WWO	N/A	Not Witnessed	Murky water and evidence	Evidence of Overflow	Relieved house connection choke with 30' of electric machine	CCTV	300599
27	4/14/2016	2700 Frederick Ave	21223	Rags, Grease	WWO	Gwynns Falls	200	Found manhole overflowing in wooded area	800	Used 500 ft of sewer jet to relieve mainline choke	CCTV	300715
28	4/15/2016	2801 Strathmore Ave	21214	Rags, Roots	WWO	N/A	Not Witnessed	Sewer water and debris	Evidence of Overflow	Relieved house connection choke with 45 ft of electric machine	CCTV	300881
29	4/16/2016	408 Cambria St	21225	Rags, Trash, Sand, Gravel, Rocks	DWO	Patapsco River	120	Sewer water overflowing	360	Relieved mainline choke with 100 ft of pressure truck	Flushed and cleaned mainline, will CCTV	300970
30	4/16/2016	2223 Monticello Rd	21216	Rags, Roots, Grease, Trash, Sand, Gravel, Rocks	DWO	Gwynns Falls	113	Sewer water overflowing	1,130	Jetted line with vector truck, relieved mainline choke	CCTV	300925
31	4/16/2016	3630 Old Frederick Rd	21229	Roots, Grease	DWO	N/A	107	Sewer water & toilet paper overflowing	107	Cleaned line with electric machine to relieve house connection choke	CCTV	300931

SSO Notification List

April 2016

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
32	4/16/2016	3739 Nortonia Rd	21216	Roots	DWO	N/A	31	Sewer water overflowing from house connection	155	Cleaned line with electric machine to relieve house connection choke	CCTV	300948
33	4/16/2016	1730 Bolton St	21217	Rags, Roots, Trash, Sand, Gravel, Rocks	DWO	N/A	Not Witnessed	Sewer water	Evidence of Overflow	Relieved house connection choke with 45 ft of electric machine	CCTV	300976
34	4/16/2016	1533 Bentalou St	21216	Pipe Break	DWO	N/A	Not Witnessed	Paper and evidence	Evidence of Overflow	Jetted line with 70ft of pressure hose	CCTV	300937
35	4/17/2016	5268 Cordelia Ave	21215	Rags, Grease, Trash, Sand, Gravel, Rocks	DWO	N/A	Not Witnessed	Gray water and grease	Evidence of Overflow	Pressure machine relieved mainline choke with 275 ft of pressure machine hose	CCTV	301065
36	4/18/2016	5009 Blythewood Rd	21210	Infiltration/Inflow, Pipe Break	DWO	Western Run	11,602	Sewage discharging from storm water outfall into stream. Mainline choke overflowing into adjacent storm system. Found during routine monitoring	5,801	Contractor replaced 9 ft of pipe segment to abate overflow	Broken pipe segment removed and replaced	301140
37	4/18/2016	3402 Woodbine Ave	21207	Pipe Break	DWO	N/A	Not Witnessed	Gray water and toilet paper around clean out	Evidence of Overflow	Ran 60 ft of electric machine, not relieved	Turned over to construction for repairs	301161
38	4/18/2016	5204 Roland Park Country School	21210	Roots, Trash, Sand, Gravel, Rocks	DWO	N/A	159	Gray water overflowing	318	Pressure truck relieved mainline choke with 100 ft of pressure machine hose	CCTV mainline	301180
39	4/19/2016	912 N Montford Ave	21213	Rags	DWO	N/A	Not Witnessed	Paper and debris	Evidence of Overflow	Contacted landlord for house connection repairs	Refer over to housing if repairs are not made	310359
40	4/20/2016	5512 Boxhill Lane	21210	Rain, Pipe Break	DWO	Stony Run	1,381	Sewage entering stream from broken residential lateral connection	345	13 ft section of pipe was installed at the end of the cleanout and connected to the other side of the stream abating the overflow	New pipe section was installed	301648
41	4/21/2016	6 N Hilton St	21229	Grease, Trash, Sand, Gravel, Rocks	DWO	N/A	75	Gray murky water	375	Pressure truck relieved mainline choke with 150 ft of pressure machine hose	CCTV Mainline	301842
42	4/21/2016	721 E Preston St	21202	Trash, Sand, Gravel, Rocks	DWO	N/A	Not Witnessed	Paper and evidence visible around the house connection	Evidence of Overflow	Could not relieve house connection choke, bypass pumping was initiated.	Need to investigate this location further to determine if this is a public or private side issue.	301762
43	4/21/2016	4101 Balfern Ave	21213	Roots	DWO	N/A	Not Witnessed	Found evidence of overflow from clean out. Front house connection choke.	Evidence of Overflow	Relieved house connection choke with 45 ft of electric machine	CCTV	301917
44	4/21/2016	1007 Iris St	21205	Trash, Sand, Gravel, Rocks	DWO	N/A	Not Witnessed	Paper and evidence around the clean out	Evidence of Overflow	Relieved house connection choke with 45 ft of electric machine	CCTV	301820
45	4/23/2016	1450 Ridgely St	21230	Rags, Trash, Sand, Gravel, Rocks	WWO	N/A	Not Witnessed	Toilet paper and debris	Evidence of Overflow	Relieved house connection choke with 60 ft of electric machine cable	CCTV	302146
46	4/23/2016	912 N Montford Ave	21213	Pipe Break	WWO	N/A	Not Witnessed	Toilet paper and debris	Evidence of Overflow	Ran 6 ft of electric machine cable not relieved. Concrete in clean out.	Left plumbers notice to remove concrete from clean out	302134

