

## SSO Notification List

August 2023

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	8/1/2023	1304 Asbury Rd	21209	Grease, Trash	Dry	N/A		Gray water observed around the cleanout.	1	Relieved house connection choke with 30 ft of electric cable.	Confirmed the lateral is clear at this time.	1247852
2	8/2/2023	5307 Nuth Ave	21206	Structural	Dry	Biddison Run	158780	Mainline is leaking and sewage is entering the storm drain.	39,695	Contractor performed CIPP lining to successfully stop the leak.	System was restored to regular functionality.	1248022
3	8/2/2023	5254 Nelson Ave	21215	Rags, Roots	Dry	N/A		Gray water observed at the rear of the property.	1	Relieved house connection choke with 30 ft of electric cable.	CCTV inspection will be performed.	1248037
4	8/3/2023	2407 Arunah Ave	21223	Rags, Grease	Dry	N/A		Gray water observed around the cleanout.	1	Relieved house connection choke with 8 ft of electric cable.	Confirmed lateral is clear; cleaned the mainline.	1248228
5	8/3/2023	Sequoia Ave & Dolfield Ave	21215	Rags, Roots	Dry	Gwynns Falls	101	Sanitary manhole overflowing wastewater on to ground surface and into nearby storm drain inlet.	101	Relieved mainline choke with 150 ft of pressure hose.	CCTV inspection will be performed to ensure all obstructions were removed.	1248309
6	8/7/2023	3812 Juniper Rd	21218	Structural	Wet	Jones Falls	21780	Broken house connection leaking into the adjacent storm pipe.	2,178	Line was rehabilitated with a 30 ft open cut point repair.	Repair restored mainline to regular functionality.	1249101
7	8/7/2023	224 E 39th St	21218	Structural	Wet	Jones Falls	91110	Broken house connection leaking into an adjacent storm pipe.	9,111	Contractor lined the pipe to stop the overflow from occurring.	Abatement confirmed via the Office of Research & Environmental Protection.	1249094
8	8/7/2023	4008 Glenmore Ave	21206	Other	Wet	Moores Run	103740	Sanitary mainline is connected to the storm main.	25,935	Repairs were made to restore system to regular functionality.	Abatement confirmed via the Office of Research & Environmental Protection.	1249161
9	8/7/2023	5928 Falls Rd	21209	Structural, Other	Wet	Jones Falls	54780	House lateral is connected to an abandoned sanitary pipe which discharges into a waterway.	13,695	New sewer lateral has been installed at this location.	System is no longer discharging toward a waterway.	1249166
10	8/14/2023	1839 W North Ave	21217	Trash	Dry	N/A		Gray water observed at the rear of the property.	1	Relieved house connection choke with 15 ft of electric cable.	CCTV confirmed the lateral is clear.	1251104
11	8/14/2023	2221 Guilford Ave	21218	Rags, Trash	Wet	N/A		Gray water and debris observed in the street.	2	Relieved mainline choke with 200 ft of pressure hose.	Confirmed the line is clear at this time.	1251206
12	8/17/2023	5105 Roland Ave	21210	Roots	Dry	N/A	70	Sewage water coming from the cleanout.	7	Blockage relived with 30 ft of electric cable.	Location will be placed on routine cleaning; CCTV will be performed.	1252640
13	8/21/2023	120 N Fremont Ave	21201	Rags, Roots	Dry	N/A		Gray water observed at the rear of the propeerty.	1	Relieved house connection choke with 45 ft of electric cable.	CCTV inspection will be performed.	1253693
14	8/25/2023	529 Beaumont Ave	21212	Rags, Infiltration, Trash	Dry	Tiffany Run	336	Choke causing wastewater to infiltrate the storm drain subsurface.	672	Relieved mainline choke with 200 ft of pressure hose.	Confirmed the line is clear; CCTV inspection will be performed.	1255054
15	8/29/2023	Hartsdale Rd & Perring Pkwy	21239	Rags, Trash	Dry	N/A		Sewage and debris observed around the manhole.	2	Relieved mainline choke with 400 ft of pressure hose.	Confirmed the line is clear; CCTV inspection will be performed.	1255871
16	8/30/2023	2583 Southdene Ave	21230	Rags	Dry	N/A		Gray water observed around the cleanout.	1	Relieved house connection choke with 30 ft of electric cable.	CCTV inspection will be performed.	1256061
				# WWO	5			TOTAL	91,404	UNDER 100 GALLONS	9	