

SSO Notification List

December 2021

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	12/1/2021	5110 Ardmore Way	21206	Rags	Dry	N/A	0	Gray water observed at the front of the property.	1	Relieved house connection choke with 45 ft of electric cable.	Flushed and cleaned the mainline; performed CCTV inspection.	999918
2	12/1/2021	820 N Broadway	21205	Rags, Roots, Grease	Dry	N/A	0	Gray water observed at the rear of the property.	1	Relieved house connection choke with 30 ft of electric cable.	Confirmed the lateral is clear at this time.	1000016
3	12/1/2021	209 E Lafayette Ave	21202	Rags, Roots	Dry	N/A	0	Gray water observed around the cleanout at the rear of the property.	1	Relieved house connection choke with 90 ft of electric cable.	Confirmed the lateral and mainline are now clear.	1000031
4	12/1/2021	1204 Seminole Ave	21229	Structural	Dry	N/A	433	Broken sanitary sewer pipe discharging into stream.	12,990	Mainline was repaired to stop the SSO and restore line to working functionality.	Abatement confirmed by the Office of Compliance and Research.	1000086
5	12/3/2021	1041 St Paul St	21202	Rags, Roots	Dry	N/A	0	Gray water observed on the sidewalk.	2	Relieved house connection choke with 45 ft of electric cable.	Performed CCTV inspection and confirmed the lateral is clear at this time.	1000453
6	12/3/2021	2015 N Payson St	21217	Rags	Dry	N/A	0	Gray water observed at the rear of the property.	1	Relieved house connection choke with 30 ft of electric cable.	Lateral CCTV inspection will be performed. Flushed the 8" mainline.	1000462
7	12/4/2021	5908 Edna Ave	21214	Rags, Roots	Dry	N/A	0	Gray water and paper observed at the cleanout.	1	Relieved house connection choke with 45 ft of electric cable.	Performed CCTV inspection and results showed the line to be clear.	1000721
8	12/5/2021	4311 Penhurst Ave	21215	Rags, Trash	Dry	N/A	0	Gray water observed at the rear of the property.	1	Relieved house connection choke with 45 ft of electric cable.	CCTV inspection to be performed; advised consumer not to flush rags.	1000757
9	12/10/2021	3025 Mary Ave	21214	Rags, Trash	Dry	Herring Run	0	Gray water observed around the cleanout.	1	Relieved house connection choke with 30 ft of electric cable.	Confirmed line is clear at this time.	1002118
10	12/10/2021	1214 N Charles St	21201	Rags, Grease, Trash	Dry	Jones Falls	384	Gray water escaping the manhole.	384	Relieved mainline choke with 300 ft of pressure hose.	Confirmed the mainline is clear; CCTV inspection will be performed.	1002077
11	12/13/2021	1319 W North Ave	21217	Rags, Grease, Trash	Wet	N/A	0	Gray water observed at the rear of the property.	1	Relieved mainline choke with 150 ft of pressure hose.	Confirmed line is clear at this time.	1002265
12	12/14/2021	1615 Pumphrey St	21224	Rags, Grease, Trash	Wet	Inner Harbor	0	Gray water observed around the manhole and storm drain.	2	Relieved mainline choke with 280 ft of pressure hose.	CCTV inspection will be performed to ensure all obstructions were removed.	1002589
13	12/14/2021	2500 Allendale Rd	21216	Rags, Trash	Dry	N/A	0	Dampness observed at the property.	1	Flushed and cleaned 8" mainline with 200 ft of pressure hose.	Confirmed the line is clear at this time.	1002808
14	12/16/2021	2432 Fait Ave	21224	Roots	Dry	N/A	0	Gray water observed at the front of the property.	1	Relieved house connection choke with 45 ft of electric cable.	Confirmed the lateral and mainline are both clear.	1003267
15	12/16/2021	1903 McHenry St	21223	Trash	Dry	N/A	0	Gray water observed at the rear of the property.	1	Relieved house connection choke with 45 ft of electric cable.	Confirmed the lateral is clear; flushed and cleaned the 8" mainline.	1003333
16	12/16/2021	1854 Wilkens Ave	21223	Rags, Trash	Dry	N/A	0	Gray water observed at the rear of the property.	1	Relieved house connection choke with 60 ft of electric cable.	Lateral is clear at this time; CCTV inspection will be performed.	1003456
17	12/20/2021	Leith Walk & E Belvedere Ave	21239	Rags, Trash	Dry	N/A	0	Signs of a mainline overflow from trash and debris around manhole.	3	Relieved two sections of an 8" sanitary mainline.	Maintenance crew will CCTV the pipe.	1003834
18	12/21/2021	2807 ELGIN Ave	21216	Rags, Grease	Dry	Gwynns Falls	0	Gray water observed around the cleanout.	1	RELIEVED CHOKE WITH 90 FT ELECTRIC MACHINE CABLE.	CCTV inspection and mainline cleaning.	-
19	12/22/2021	5726 CLOVER Rd	21215	Rags, Grease	Dry	N/A	0	Gray water observed around the cleanout.	1	Relieved house connection choke with 30 ft of electric cable.	Lateral CCTV inspection and mainline cleaning will take place.	-
20	12/24/2021	2024 NORTH WOLFE ST	21213	Rags, Roots	Dry	N/A	0	Gray water observed around the cleanout.	1	Relieved house connection choke with 30 ft of electric cable.	Performed lateral CCTV inspection and confirmed the line is clear.	1004742
21	12/26/2021	Tompkins St & West Bay Ave	21225	Rags, Grease, Trash	Dry	N/A	314	Gray water escaping the manhole.	314	Relieved mainline choke with 100 ft of pressure hose.	CCTV inspection will be performed to ensure all obstructions were removed.	1004826

SSO Notification List

December 2021

22	12/26/2021	416 SOUTH AUGUSTA AVE	21229	Rags, Grease	Dry	N/A	0	Gray water observed around the cleanout.	1	Relieved house connection choke with 45 ft of electric cable.	Lateral CCTV inspection will be performed.	1004822
23	12/29/2021	3046 ASCENSION ST	21225	Sand, Gravel, Rocks, Structural	Dry	N/A	0	Gray water observed at the front of the property.	1	Ran 16 ft of electric cable through the lateral.	Determined structural damage exists; pipe will be repaired.	1005333
24	12/29/2021	1930 MOUNT ROYAL Terr	21217	Rags, Grease, Trash	Dry	Jones Falls	247	Gray water escaping the manhole.	494	Relieved mainline choke with 300 ft of pressure hose.	Confirmed the line is now clear; CCTV inspection will be performed.	1005357
				# WWO	2			TOTAL	14,206	UNDER 100 GALLONS	20	