

## SSO Notification List

December 2023

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	12/1/2023	2212 Russell St	21230	Rags, Roots, Trash	Dry	Gwynns Falls	192	Sewage and water escaping the manhole.	192	Relieved mainline choke with 165 ft of pressure hose.	Confirmed the line is now clear; CCTV will be performed.	1279051
2	12/5/2023	3615 W Forest Park Ave	21202	Rags, Roots, Trash	Wet	Jones Falls	104	Mainline choke causing a subsurface SSO that is infiltrating the storm drain system.	1040	Flushed and cleaned 8" mainline with 400 ft of pressure hose.	Confirmed the mainline is now clear.	1279944
3	12/6/2023	2430 Frederick Ave	21223	Roots	Dry	—	—	Gray water observed around the cleanout.	1	Relieved house connection choke with 30 ft of electric cable.	CCTV will be performed.	1280266
4	12/8/2023	4500 W Bay Ave	21225	Rags, Trash	Dry	Inner Harbor	1145	Sewage escaping the manhole and entering nearby storm drain.	5725	Relieved mainline choke with 300 ft of pressure hose.	Confirmed the line is clear; CCTV will be performed.	1280939
5	12/8/2023	1903 W North Ave	21217	Rags	Dry	—	—	Gray water observed at the rear of the property.	1	Relieved house connection choke with 30 ft of electric cable.	Confirmed the lateral is clear at this time.	1280941
6	12/11/2023	428 E Preston St - SSO Site #72	21202	Rain	Wet	Jones Falls	45	Structure monitored by metering equipment in the pipe. Not visually observed.	6030	SSO structure; not applicable.	SSO structure will be closed upon completion of capital improvement projects.	—
7	12/11/2023	3713 Clipper Rd	21211	Roots, Trash	Wet	—	—	Gray water observed around the cleanout at the front of the property.	1	Relieved house connection choke with 45 ft of electric cable.	CCTV confirmed the lateral is clear at this time.	1281081
8	12/11/2023	1301 Gorsuch Ave	21218	Rags, Roots	Wet	—	—	Gray water observed at the rear of the property.	2	Relieved house connection choke with 30 ft of electric cable.	Performed CCTV inspection; confirmed lateral is clear	1281064
9	12/11/2023	278 S Monastery Ave	21229	Rags, Grease, Trash	Wet	Maidens Choice	296	Manhole discharging water to nearby storm drain.	888	Relieved mainline choke with 200 ft of pressure hose.	Confirmed line is now clear; CCTV will be performed.	1281114
10	12/11/2023	4118 Orchard Ridge Blvd	21213	Rags, Trash	Wet	—	—	Gray water observed around the cleanout.	1	Relieved house connection choke with 30 ft of electric cable.	Confirmed the lateral is now clear.	1281331
11	12/12/2023	5412 Willowmere Way	21212	Structural Damage	Wet	Stony Run	23190	Defective house connection is leaking wastewater into nearby storm drain subsurface.	2319	Point repair was performed to stop leak and restore the system.	Abatement confirmed via dye test by OREP.	1280439
12	12/13/2023	3951 Wilsby Ave	21218	Rags, Roots	Wet	—	—	Gray water and debris around the cleanout.	2	Relieved house connection choke with 45 ft of electric cable.	Performed CCTV inspection; confirmed lateral is clear at this time	1281774
13	12/14/2023	42 E Cross St	21230	Rags, Grease, Trash	Dry	—	—	Discharge discovered from sump pump.	5	Used pressure truck to flush & clean 8" sanitary mainline.	Performed CCTV inspection; confirmed mainline is clear.	1282282
14	12/16/2023	111 W Ostend St	21230	Unknown	Dry	—	—	Gray water observed near the side of the property.	3	Ran 3 ft of electric cable through the lateral; unable to progress further.	Line may need repair; further investigation will take place.	1282741
15	12/16/2023	4625 Falls Rd	21209	Rags	Dry	Jones Falls	—	Gray water observed around the cleanout and storm drain.	2	Relieved house connection choke with 45 ft of electric cable.	Confirmed the lateral is clear; flushed and cleaned the mainline.	1282755
16	12/17/2023	1115 N Fremont Ave	21217	Unknown	Dry	—	—	Gray water observed at the front of the property.	1	Ran electric cable; no cause determined.	Lateral and mainline will have CCTV performed to determine next steps.	1282803
17	12/17/2023	3900 Belair Rd	21206	Rain	Wet	Herring Run	540	Manhole adjacent to creek overflowed due to heavy rain.	1576260	Overflow subsided following heavy rain event.	Location is equipped with an Event Notification System meter.	—
18	12/17/2023	1901 Falls Rd - SSO Site #67	21217	Rain	Wet	Jones Falls	715	Structure monitored by metering equipment in the pipe. Not visually observed.	6022445	SSO structure; not applicable.	SSO structure will be closed upon completion of capital improvement projects.	—
19	12/17/2023	428 E Preston St - SSO Site #72	21202	Rain	Wet	Jones Falls	825	Structure monitored by metering equipment in the pipe. Not visually observed.	2134275	SSO structure; not applicable.	SSO structure will be closed upon completion of capital improvement projects.	—
20	12/17/2023	Charing Cross Rd & Greenwich Ave - SSO Site #156	21229	Rain	Wet	Maidens Choice	275	Structure monitored by metered equipment in the pipe. Not visually observed.	37950	SSO structure; not applicable.	SSO structure will be closed upon completion of capital improvement projects.	—

## SSO Notification List

December 2023

21	12/18/2023	1500 N Charles St	21202	Rain, Infiltration	Wet	Jones Falls	—	Large discharge discovered after heavy rain event.	500	Lock top manhole cover will be replaced to prevent sewer water from escaping at this location.	Overflow likely due to pipe capacity issue; SSO occurred from rain infiltration.	1282881
22	12/18/2023	317 Loneys Ln	21224	Rags, Roots	Wet	—	—	Gray water observed at the rear of the property.	1	Relieved house connection choke with 30 ft of electric cable.	Performed CCTV inspection; confirmed lateral is clear.	1282942
23	12/18/2023	731 Hollen Rd	21212	Roots	Wet	—	—	Gray water observed around the cleanout.	1	Relieved house connection choke with 45 ft of electric cable.	CCTV inspection confirmed the lateral is now clear.	1283308
24	12/18/2023	E Cold Spring Ln & Stadium Way	21214	Rags, Trash	Wet	—	—	Gray water and debris observed in parking lot.	3	Relieved 12" mainline choke with 200 ft of pressure hose.	Confirmed the mainline is now clear at this time.	1283322
25	12/18/2023	2205 Arden Rd	21209	Roots, Trash	Wet	—	—	Gray water and debris observed at the front of the property.	1	Relieved choke with 45 ft of electric cable.	Performed CCTV inspection.	1283356
26	12/19/2023	2505 Queen Anne Rd	21216	Roots, Trash	Wet	—	—	Gray water observed at the front of the property.	1	Relieved house connection choke with 45 ft of electric cable.	Confirmed mainline and lateral are clear.	1283505
27	12/19/2023	1903 W North Ave	21217	Rags	Wet	—	—	Gray water observed at the rear of the property.	1	Relieved house connection choke with 30 ft of electric cable.	CCTV inspection will be performed.	1283593
28	12/20/2023	1820 Spence St	21230	Rags, Grease, Trash	Wet	—	1420	Gray water escaping the manhole.	355	Relieved mainline choke with 250 ft of pressure hose.	Confirmed the line is clear; CCTV will be performed.	1283605
29	12/20/2023	9 Gorman Ave	21223	Rags, Trash	Wet	—	—	Gray water and debris observed near the cleanout.	1	Relieved house connection choke with 45 ft of electric cable.	CCTV confirmed the lateral is now clear.	1283750
30	12/23/2023	2213 Roslyn Ave	21216	Rags, Roots	Dry	—	—	Mainline choke causing lateral to overflow.	5	Relieve mainline choke with pressure hose.	Mainline will need to be cut with sewer rodder to prevent reoccurrence.	1284570
31	12/24/2023	5431 Springlake Way	21212	Rags	Dry	—	—	Gray water observed at the front of the property.	5	Relieved house connection choke with 60 ft of electric cable.	CCTV confirmed the lateral is clear.	1284633
32	12/26/2023	1203 Mosher St	21217	Rags, Other	Dry	Gwynns Falls	—	Gray water and debris observed near the cleanout and storm drain.	3	Relieved house connection choke with 25 ft of electric cable.	CCTV will be performed; advised consumer against flushing that material.	1284758
33	12/27/2023	3510 Wabash Ave	21215	Rags, Trash	Wet	—	—	Gray water observed around the manhole.	3	Relieved mainline choke with pressure hose.	CCTV inspection will be performed.	1284899
34	12/27/2023	3900 Belair Rd	21206	Rain	Wet	Herring Run	195	Manhole adjacent to creek overflowed due to heavy rain.	915,135	Overflow subsided following heavy rain event.	Location is equipped with an Event Notification System meter.	—
35	12/27/2023	428 E Preston St - SSO Site #72	21202	Rain	Wet	Jones Falls	320	Structure monitored by metering equipment in the pipe. Not visually observed.	450,000	SSO structure; not applicable.	SSO structure will be closed upon completion of capital improvement projects.	—
36	12/28/2023	3529 Gelston Dr	21229	Rags, Trash	Wet	Gwynns Falls	456	Gray water escaping the manhole in the street.	1,368	Relieved mainline choke with 500 ft of pressure hose.	CCTV will be performed; confirmed mainline is clear.	1285164
37	12/28/2023	1901 Falls Rd - SSO Site #67	21217	Rain	Wet	Jones Falls	260	Structure monitored by metered equipment in the pipe. Not visually observed.	797,160	SSO structure; not applicable.	SSO structure will be closed upon completion of capital improvement projects.	—
38	12/29/2023	2400 Keyworth Ave	21215	Rags, Trash	Wet	Jones Falls	603	Gray water escaping the manhole at the rear of the property.	603	Relieved mainline choke with 200 ft of pressure hose.	Confirmed mainline is clear; CCTV will be performed.	1285697
39	12/29/2023	115 W Lee St	21201	Roots	Wet	—	—	Gray water observed around the cleanout.	1	Relieved house connection choke with 45 ft of electric cable.	Confirmed lateral is clear; CCTV will be performed.	1285744
40	12/29/2023	2112 Garrison Blvd	21216	Unknown	Wet	Gwynns Falls	—	Choke causing sewage to infiltrate nearby storm drain system.	TBD*	Ran 100 ft of pressure hose; determined structural damage exists.	Mainline will need to be repaired or lined to stop the overflow.	1285772
41	12/30/2023	3502 Wabash Ave	21215	Structural Damage	Wet	—	134	Mainline issue causing sump pump to overflow.	134	Flushed mainline with pressure hose to stop SSO; discovered damage to pipe.	Repair will be needed by construction crew or contractor.	1285826
				# WWO	30			TOTAL	11,952,424*	UNDER 100 GALLONS	22	