

SSO Notification List												
June 2025												
Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	6/1/2025	6001 Pimlico Rd	21209	Rags, Trash	Wet	—	—	Observed wastewater coming from rear house connection	1	Relieved house connection choke with 30 ft electric cable	Confirmed house connection is clear at this time. CCTV will be performed	1447789
2	6/3/2025	2611 W Fairmount Ave	21223	Trash	Dry	—	—	Wastewater with debris	0.5	Setup Bypass pumping	CCTV Inspection will be performed	1448882
3	6/3/2025	2700 Wegworth Ln	21230	Rags, Trash	Dry	Gwynns Falls	1364	Observed wastewater coming from manhole	682	Relieved mainline choke with 250 ft pressure hose	Confirmed mainline is clear at this time. CCTV will be performed	1449294
4	6/3/2025	1716 Sulgrave Ave	21209	Rags	Dry	—	—	Wastewater with rags	1	Relieved choke using electric cable with sawtooth	CCTV Inspection will be performed	1449324
5	6/4/2025	5010 Loch Raven Blvd	21239	Rags, Grease, Trash	Dry	Chinquapin Run	188	Wastewater with grease, rags and debris. Choked sanitary manhole overflowing into adjacent manhole.	188	Flushed the mainline with the Vac Truck 410 feet and relieved the mainline choke	CCTV Inspection will be performed	1449419
6	6/4/2025	702 S Broadway	21231	Rags, Roots	Dry	—	—	Wastewater with roots and rags	1	Relieved choke using electric cable with expander cutter	CCTV Inspection will be performed	1449540
7	6/5/2025	419 N Athol Ave	21229	Rags, Grease, Trash	Dry	—	108	Observed wastewater coming from manhole	216	Relieved mainline choke with 100 ft pressure hose	Confirmed mainline is clear at this time. CCTV will be performed	1449655
8	6/5/2025	1801 N Payson St	21217	Rags, Grease	Dry	—	—	Observed wastewater coming from manhole in rear	3	Relieved mainline choke flushed and cleaned with 200 ft pressure hose	Confirmed mainline is clear at this time. Referred for CCTV inspection	1449774
9	6/6/2025	6608 Danville Ave	21224	Roots, Trash	Dry	—	—	Wastewater with roots and debris	0.5	Relieved choke using electric cable with sawtooth and spearhead	CCTV Inspection will be performed	1450066
10	6/6/2025	6228 Eastern Ave	21224	Rags, Trash	Dry	—	185	Observed wastewater coming from manhole	92.5	Relieved mainline choke with 350 ft pressure hose	Confirmed mainline is clear at this time. CCTV will be performed	1450189
11	6/9/2025	4285 Labyrinth Rd	21215	Rags, Roots	Wet	—	—	Wastewater with rags and roots	0.5	Relieved choke using electric cable with expander cutter	CCTV Inspection was performed	1450606
12	6/9/2025	Edmondson Ave & N Hilton Pkwy	21229	Structural	Wet	Gwynns Falls	2611	Wastewater overflowing into adjacent stream	261100	Set up bypass pumping so contractor can make repairs.	CCTV Inspection has been scheduled	1450611
13	6/11/2025	2413 Maryland Ave	21218	Rags	Wet	—	—	Observed wastewater coming from rear house connection	2	Relieved house connection choke with 45 ft electric cable	Confirmed house connection is clear at this time. CCTV was performed.	1451051
14	6/18/2025	4310 Lasalle Ave	21206	Rags, Trash	Wet	Biddison Run	528	Choked sanitary sewer pipe caused overflow into adjacent storm drainpipe.	7920	Relieved choke with pressure hose	CCTV Inspection will be performed	1452889
15	6/19/2025	509 S Exeter St	21202	Rags	Wet	—	—	Wastewater with rags	1	Relieved choke using H-Cutter	CCTV Inspection was performed	1453045
16	6/19/2025	2728 Reistertown Rd	21215	Rags	Wet	—	—	Observed wastewater coming from rear house connection	2	Relieved house connection choke with 45 ft electric cable	Confirmed house connection is clear at this time. CCTV will be performed	1453070
17	6/20/2025	306 W Coldspring Ln	21210	Roots	Wet	—	—	Wastewater with heavy roots	1.5	Relived choke with 60ft of electric machine cables	CCTV Inspection was performed	1453231
18	6/20/2025	2436 Harriet Ave	21230	Rags, Grease	Wet	—	324	Observed wastewater coming from manhole	972	Relieved mainline choke with 300 ft pressure hose	Confirmed mainline clear and flowing freely. CCTV will be performed	1453340
19	6/21/2025	5512 Park Heights Ave	21215	Rags, Trash	Wet	—	—	Wastewater with rags and debris	1	Relieved connection choke using 60ft of electric cable, with various cutters.	CCTV Inspection was performed	1453414
20	6/25/2025	3600 Harford Rd	21206	Unknown	Dry	—	—	Observed evidence (toilet paper) in grass	5	No measures taken at this time	Revisit manhole for reinspection	0

SSO Notification List												
June 2025												
21	6/27/2025	3716 Gibbons Ave	21206	Rags	Wet	Biddison Run	5831	Sewage from choke is getting into nearby storm drain system	29155	Relieved choke with pressure truck	CCTV Inspection will be performed	1454958
22	6/29/2025	3026 W Lanvale St	21216	Rags, Grease	Wet	—	—	Observed wastewater coming from manhole	4	Relieved mainline choke with 250 ft pressure hose	Confirmed mainline is clear and flowing freely at this time. CCTV will be performed	1455146
23	6/30/2025	7030 Surrey Dr	21215	Rags	Wet	—	—	Observed wastewater at front house connection	2	Relieved house connection choke with 45 ft electric cable	Confirmed house connection is clear at this time. CCTV was performed	1455284
				# WWO	13			TOTAL	300,352	UNDER 100 GALLONS	16	