

SSO Notification List

October 2023

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	10/1/2023	436 Kane St	21224	Rags, Grease	Dry	N/A	424	Gray water escaping the manhole.	106	Relieved mainline choke with 250 ft of pressure hose.	Confirmed the line is now clear; CCTV will be performed.	1263443
2	10/2/2023	N Ellamont St & N Franklintown Rd	21216	Grease, Structural	Dry	Gwynns Falls	6848	Gray water escaping the manhole.	34240	4 ft of broken mainline was repaired to stop the SSO.	System has been restored to regular functionality.	1263756
3	10/2/2023	26th St & Guilford Ave	21218	Rags, Trash	Dry	Jones Falls	80	Sewer water was leaking onto the CXS train tracks.	1200	Relieved mainline choke with 300 ft of pressure hose.	CCTV inspection will be performed to determine if further action needs to be taken.	1263791
4	10/6/2023	1216 Riverside Ave	21230	Rags, Trash	Dry	N/A	—	Gray water observed at the rear of the property.	1	Relieved house connection choke with 45 ft of electric cable.	Performed lateral CCTV inspecton.	1265232
5	10/7/2023	5012 The Alameda	21239	Rags	Wet	N/A	—	Gray water and debris observed around the cleanout.	1	Relieved house connection choke with 60 ft of electric cable.	Performed CCTV inspection; confirmed lateral and mainline are clear.	1265285
6	10/8/2023	3201 Frisby St	21218	Rags, Grease	Wet	Jones Falls	—	Evidence of SSO due to a mainline choke.	2	Relieved mainline choke with 250 ft of pressure hose.	Confirmed line is clear; CCTV will be performed.	1265316
7	10/11/2023	2859 W Lanvale St	21216	Rags, Grease, Trash	Dry	Gwynns Falls	89	Sewage water discharging from manhole cover.	178	Relieved mainline choke with 200 ft of pressure hose.	Confirmed the line is clear; CCTV will be performed.	1265971
8	10/17/2023	402 Key Hwy	21230	Rags, Grease	Wet	Northwest Harbor	760	Gray water escaping the manhole in parking lot.	3800	Relieved mainline choke using high-pressure jet truck.	CCTV inspection will determine if further steps need to be taken.	1267344
9	10/18/2023	2312 Cloville Ave	21214	Other	Dry	Herring Run	10472	House lateral is connected to an abandoned sanitary pipe which discharges into a storm drain.	2618	Performed repair to attached property lateral to new y-connection on sewer main.	Abatement confirmed via Office of Research & Environmental Protection.	1267684
10	10/18/2023	709 Linnard St	21229	Rags, Roots	Dry	N/A	—	Gray water observed around the cleanout.	1	Relieved house connection choke with 30 ft of electric cable.	Performed CCTV inspection; confirmed lateral is clear.	1267609
11	10/19/2023	3808 Ridgewood Ave	21215	Rags, Grease	Dry	N/A	—	Gray water observed at the front of the property.	1	Relieved house connection choke with 45 ft of electric cable.	CCTV confirmed lateral and mainline are clear.	1267914
12	10/20/2023	6527 Cleveland Ave	21222	Structural	Dry	N/A	—	Wastewater is leaking from the sanitary sewer and infiltrating the storm drain below ground.	TBD	Line will need to be structurally repaired.	CCTV will determine how to best fix the mainline.	1268262
13	10/23/2023	5928 Falls Rd	21209	Rags	Dry	N/A	—	Gray water observed around the cleanout.	2	Relieved choke with 50 ft of pressure hose.	Confirmed lateral and mainline are clear at this time.	1268614
14	10/23/2023	6108 Ridgeview Ave	21206	Rags, Roots	Dry	N/A	—	Gray water observed around the cleanout.	1	Relieved house connection choke with 30 ft of electric cable.	CCTV confirmed the lateral and mainline are clear.	1268639
15	10/24/2023	2325 Hollins Ferry Rd	21230	Rags, Grease	Dry	Gwynns Falls	167	Gray water escaping the manhole in the street.	334	Relieved mainline choke with 200 ft of pressure hose.	Confirmed line is flowing freely; CCTV will be performed.	1268902
16	10/24/2023	2315 Maryland Ave	21218	Rags, Roots	Dry	N/A	—	Gray water observed at the rear of the property.	1	Relieved house connection choke with electric cable.	CCTV confirmed the lateral is now clear.	1268990
17	10/24/2023	4238 Roland View Ave	21215	Rags	Dry	N/A	—	Gray water observed on the sidewalk.	1	Relieved house connection choke with electric cable; flushed mainline.	Further investigation will take place to determine if structural damage exists.	1269064
18	10/27/2023	1639 Moreland Ave	21216	Roots, Trash	Dry	N/A	116	Gray water escaping the manhole.	58	Relieved mainline choke with 400 ft of pressure hose.	Confirmed mainline is now clear; CCTV will be performed.	1270102
19	10/28/2023	1143 N Stricker St	21217	Rags	Dry	N/A	—	Gray water observed at the rear of the property.	1	Flushed and cleaned the line with 200 ft of pressure hose.	CCTV will be performed.	1270144
20	10/28/2023	4207 Liberty Heights Ave	21207	Roots	Dry	N/A	—	Gray water observed around the cleanout.	1	Relieved house connection choke with 45 ft of electric cable.	Confirmed the lateral and mainline are clear.	1270152

SSO Notification List

October 2023

21	10/30/2023	4622 Frederick Ave	21229	Rags, Roots, Grease	Dry	Maidens Choice	129	Routine sampling discovered a subsurface SSO occurring.	645	Relieved mainline choke with 300 ft of pressure hose.	CCTV will be performed to ensure all obstructions were removed.	1270361
				# WWO	3			TOTAL	43,192	UNDER 100 GALLONS	12	