

## SSO Notification List

October 2024

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	10/1/2024	1823 N Regester St	21213	Rags	Wet	—	—	Wastewater observed near rear house connection	1	Relieved house connection choke with 30 ft pressure hose	CCTV confirmed house connection is clear	1380248
2	10/5/2024	3107 Parkington Ave	21215	Rags, Trash	Dry	—	—	Wastewater observed near front house connection	2	Relieved house connection choke with 40 ft pressure hose	CCTV confirmed house connection clear at this time	1381510
3	10/7/2024	2455 Etting St	21217	Roots, Trash	Dry	—	—	Gray water observed at the cleanout.	2	Relieved house connection choke with 45 ft of electric cable.	CCTV inspection will be performed.	1381851
4	10/10/2024	611 Oldham St	21224	Rags, Grease, Trash	Dry	Inner Harbor	89	Choked sanitary sewer pipe overflowing into adjacent storm drain	89	Relieved mainline choke using pressure hose.	Location will CCTV'd.	1382607
5	10/12/2024	2828 Rosalind Ave	21215	Rags	Dry	Jones Falls	150	Wastewater discharging in the alleyway.	75	Relieved mainline choke with 340 ft of pressure hose.	CCTV inspection will determine if further action is needed.	1382896
6	10/12/2024	1333 Glenwood Ave	21239	Rags, Grease, Trash	Dry	Chinquapin Run	85	Gray water observed coming from sewer manhole	255	Relieved mainline choke with 280 ft high pressure cable	Flushed and cleaned mainline with 320 ft pressure hose. CCTV will be performed	1382891
7	10/14/2024	2701 Allendale Rd	21216	Trash	Dry	—	—	Gray water with debris	1	Used electric cable and cutters to relieve blockage.	No action is needed at this time	1383248
8	10/16/2024	4617 W Forest Park Ave	21207	Rags, Trash	Dry	—	—	Observed wastewater coming from manhole	2	Relieved mainline choke with 300 ft pressure cable	Confirmed mainline is clear at this time	1383495
9	10/21/2024	1230 E Chase St	21202	Rags	Dry	—	—	Gray water with rags and clothing	2	Relieved choke using electric machine with cutters.	No action taken at this time.	1384206
10	10/23/2024	5714 Bowleys Ln	21206	Rags, Trash	Dry	Herring Run	—	Wastewater observed coming from manhole	2	Relieved mainline choke with 450 ft pressure hose	Confirmed mainline is clear at this time	1384830
11	10/24/2024	500 W University Pkwy	21210	Rags, Roots, Trash	Dry	Stony Run	172	Sewer water overflowing into parking lot and adjacent stream.	8600	Pressure truck enabled removal of rags and debris	Location will be scheduled for CCTV Review	1385128
12	10/24/2024	3701 Mactavish Ave	21229	Rags, Trash	Dry	—	—	Wastewater observed coming from manhole	2	Relieved mainline choke with 200 ft pressure hose	Confirmed mainline is clear at this time	1385267
13	10/28/2024	1324 Cambria St	21225	Grease, Trash	Dry	—	—	Wastewater observed coming from manhole	2	Relieved mainline choke flushed and cleaned with vacuum truck and 200 ft pressure hose	Mainline is clear at this time. CCTV will be performed	1385699
14	10/28/2024	429 Wingate Rd	21210	Rags, Grease	Dry	—	—	Wastewater observed coming from manhole	5	Relieved mainlined choke with 450 ft pressure hose	Confirmed mainline is clear at this time. CCTV will be performed	1385694
15	10/28/2024	5900 Willet Ave	21206	Rags, Grease, Trash	Dry	Moores Run	—	Mainline choke observed in manhole	1	Relieved mainline choke with 225 ft pressure hose	Mainline is clear at this time	1385873
16	10/28/2024	931 Montpelier St	21218	Rags, Roots	Dry	—	—	Evidence of overflow at rear house connection.	1	Relieved house connection with machine.	No preventative actions will be taken at this time.	1385852
17	10/28/2024	Edmondson Ave & Braddish Ave	21223	Rags, Grease, Trash	Dry	Gwynns Falls	—	Sewage entering storm drain discovered during routine sampling.	5	Relieved mainline choke with 200 ft of pressure hose.	CCTV inspection will be performed to determine if further action is needed.	1385804
18	10/28/2024	2208 Fleet St	21231	Rags, Roots	Dry	—	—	Evidence of sewer overflow from front house connection choke.	1	Relieved house connection choke, using electric machine.	Possible candidate for CCTV Investigation	1385907
19	10/31/2024	2807 Inglewood Ave	21234	Roots, Other	Dry	—	—	Gray water came from house connection	1	Relieved choke with 45 feet of electric cable	Video inspection performed on mainline sewer.	1387694
20	10/31/2024	1800 Ensor St	21202	Rags, Trash	Dry	—	—	Gray water discharged around manhole	2	Cleaned mainline sewer with 200ft of pressure hose	Location has been referred to CCTV team.	1388002

SSO Notification List

October 2024

21	10/31/2024	4629 Chatford Ave	21206	Rags, Grease, Trash	Dry	Herring Run	1002	Gray water observed coming from manhole	1002	Relieved mainline choke flushed and cleaned with 450 ft pressure hose	Confirmed mainline is clear at this time and referred for cctv inspection	1388046
				# WWO	1			TOTAL	10,053	UNDER 100 GALLONS	18	