

SSO Notification List

February 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	2/1/2012	4324 Reisterstown Rd	21215	Rags	WWO	Gwynns Falls	3:44	9:43 AM - 1:27 PM	Sewer Water	244	Ran Electric Machine cable into Basement	Left Plumber's notice	134147
2	2/1/2012	Elliott St & Gusryan St	21224	Rags & Debris	WWO	Patapsco	2:50	5:25 PM - 8:15 PM	Sewer Water	1,700	Pressure Jet relieved Mainline choke	Turn over to CCTV	134175
3	2/1/2012	Ednor Rd & Greystone Rd	21218	Rags & Debris	WWO	Herring Run	2:55	7:35 PM - 10:30 PM	Sewer Water	875	Pressure Jet relieved Mainline choke	Turn over to CCTV	134181
4	2/2/2012	3630 Elm Ave	21211	Rags & Roots	DWO	Jones Falls	Overflow Not Witnessed	Overflow Not Witnessed	Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134211
5	2/4/2012	1349 Spelman Rd	21225	Rags & Grease	WWO	Patapsco	2:11	9:31 AM - 11:42 AM	Heavy Gray Water	655	Pressure Jet relieved Mainline choke	Turn over to CCTV	134320
6	2/4/2012	630 Deepdene Rd	21210	Rags & Roots	WWO	Jones Falls	1:47	1:13 PM - 3:00 PM	Heavy Gray Water	107	Electric Machine relieved House Connection choke	Turn over to CCTV	134342
7	2/5/2012	1528 N Mount St	21217	Rags, Grease, Trash	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Clear Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134371
8	2/5/2012	4009 Edmondson Ave	21229	Rags & Grease	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Clear Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134372
9	2/5/2012	2419 Reisterstown Rd	21217	Rags, Grease, Debris	DWO	Jones Falls	19:41	2/5/12 2:19 PM - 2/6/12 10:00 AM	Heavy Gray Water	3,543	Pressure Jet relieved Mainline choke	Turn over to CCTV	134378
10	2/6/2012	5110 Windsor Mill Rd	21207	Rags & Roots	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134394
11	2/6/2012	811 Druid Park Lake Dr	21217	Rags & Debris	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134400
12	2/8/2012	2519 Marbourne Ave	21230	Unknown	WWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around Clean-Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134507
13	2/9/2012	1346 Glyndon Ave	21223	Grease	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around Clean-Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134574
14	2/9/2012	2611 Dulany St	21223	Rags & Grease	DWO	None	1:00	12:30 PM - 1:30 PM	Gray Water	60	Pressure Jet relieved Mainline choke	Turn over to CCTV	134569
15	2/9/2012	2611 Dulany St	21223	Rags & Grease	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around Clean-Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134577
16	2/9/2012	615 N Carrollton Ave	21217	Grease	DWO	None	1:00	1:30 PM - 2:30 PM	Gray Water	30	Electric Machine relieved House Connection choke	Turn over to CCTV	134585
17	2/9/2012	4300 Robertson Ave	21206	Debris	DWO	Herring Run	1:05	6:20 PM - 7:25 PM	Sewer Water	325	Pressure Jet relieved Mainline choke	Turn over to CCTV	134603
18	2/10/2012	1845 W North Ave	21217	Rags & Grease	WWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around Clean-Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134612
19	2/10/2012	2103 Cliftwood Ave	21213	Rags, Grease, Trash	WWO	Northwest Harbor	1:20	12:40 PM - 2:00 PM	Clear Water	400	Pressure Jet relieved Mainline choke	Turn over to CCTV	134620
20	2/12/2012	2507 Talbot Rd	21216	Rags & Roots	DWO	Gwynns Falls	1:45	12:25 PM - 2:10 PM	Heavy Gray Water	315	Pressure Jet relieved Mainline choke	Turn over to CCTV	134681
21	2/12/2012	Fallstaff Rd & Clarks Ln	21209	Rags & Grease	DWO	Jones Falls	3:10	3:05 PM - 6:15 PM	Grease & Gray Water	570	Pressure Jet relieved Mainline choke	Turn over to CCTV	134687
22	2/12/2012	421 N Glover St	21224	Mud	DWO	Jones Falls	16: 50	2/12/12 5:10 PM - 2/13/12 10:00 AM	Gray Water	1,010	By-pass Pump around Leak	Repair Leaking Stack	134688
23	2/12/2012	4106 Harris Ave	21206	Rags, Roots, Grease	DWO	Herring Run	1:12	7:40 PM - 8:52 PM	Grease & Gray Water	144	Electric Machine relieved House Connection choke	Turn over to CCTV	134692
24	2/13/2012	3018 Overland Ave	21214	Roots, Grease, Trash	DWO	Herring Run	2:35	11:55 AM - 2:30 PM	Brown & Gray Water	1,085	Pressure Jet relieved Mainline choke	Turn over to CCTV	134728

SSO Notification List

February 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
25	2/13/2012	4029 Greenmount Ave	21218	Rags	DWO	Jones Falls	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134741
26	2/13/2012	3032 Seamon Ave	21225	Roots	DWO	Patapsco	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134742
27	2/13/2012	3203 Elmora Ave	21206	Roots	DWO	Herring Run	15:40	2/13/12 10:00 PM - 2/14/12 1:40 PM	Gray Water	Unknown (Intermittent Flow)	Electric Machine relieved House Connection choke	Turn over to CCTV	134755
28	2/14/2012	6214 Pimlico Rd	21209	Roots	DWO	Jones Falls	1:38	1:22 PM - 3:00 PM	Heavy Gray Water	196	Pressure Jet relieved Mainline choke	Turn over to CCTV	134782
29	2/14/2012	110 N Kenwood Ave	21224	Rags, Grease, Trash	DWO	Northwest Harbor	0:35	2:40 PM - 3:15 PM	Gray Water	105	Pressure Jet relieved Mainline choke	Turn over to CCTV	134785
30	2/14/2012	2202 E Fairmount Ave	21231	Rags & Roots	DWO	Northwest Harbor	16:05	2/14/12 5:55 PM - 2/15/12 10:00 AM	Brown & Gray Water	Unknown (Intermittent Flow)	Electric Machine relieved House Connection choke	Turn over to CCTV	134809
31	2/14/2012	5713 Edgepark Rd	21239	Rags, Grease, Debris	DWO	Herring Run	1:13	9:52 PM - 11:05 PM	Sewer Water	365	Pressure Jet relieved Mainline choke	Turn over to CCTV	134806
32	2/15/2012	2722 Clafin Ct	21225	Rags & Grease	DWO	Patapsco	2:00	8:41 AM - 10:41 AM	Heavy Gray Water	360	Pressure Jet relieved Mainline choke	Turn over to CCTV	134815
33	2/15/2012	800 Bethune Rd	21225	Sand, Gravel, Rocks	DWO	Patapsco	2:00	10:00 AM - 12:00 PM	Heavy Gray Water	240	Pressure Jet relieved Mainline choke	Turn over to CCTV	134826
34	2/15/2012	1801 Washington Blvd	21230	Rags	DWO	Patapsco	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134855
35	2/18/2012	2844 Hilldale Ave	21215	Rags	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134986
36	2/18/2012	210 W 29th St	21211	Rags & Debris	DWO	Jones Falls	0:45	1:15 PM - 2:00 PM	Gray Water	45	Pressure Jet relieved Mainline choke	Turn over to CCTV	134988
37	2/18/2012	Harford Rd & Parkside Dr	21214	Pipe Break & Vandalism	DWO	Herring Run	19:00	2/18/12 4:30 PM - 2/19/12 11:30 AM	Gray Water	2,280	Pressure Jet relieved Mainline choke	Turn over to CCTV	134993
38	2/19/2012	600 E 35th St	21218	Rags & Grease	DWO	Jones Falls	2:00	9:00 AM - 11:00 AM	Gray Water	600	Pressure Jet relieved Mainline choke	Turn over to CCTV	135009
39	2/19/2012	3027 Walbrook Ave	21216	Rags & Roots	DWO	Gwynns Falls	1:30	12:00 PM - 1:30 PM	Gray Water	180	Electric Machine relieved House Connection choke	Turn over to CCTV	135017
40	2/19/2012	1405 Belt St	21230	Rags	DWO	Inner Harbor	1:00	12:30 PM - 1:30 PM	Gray Water	300	Electric Machine relieved House Connection choke	Turn over to CCTV	135019
41	2/19/2012	234 McMechen St	21217	Unknown	DWO	Jones Falls	2:05	12:30 PM - 2:35 PM	Gray Water	625	Pressure Jet relieved Mainline choke	Turn over to CCTV	135020
42	2/19/2012	Laplata Ave & Woodheights Ave	21211	Rags, Roots, Trash	DWO	Jones Falls	7:55	2:20 PM - 10:15 PM	Brown & Gray Water	1,425	Pressure Jet relieved Mainline choke	Turn over to CCTV	135027
43	2/19/2012	1118 Gorsuch Ave	21218	Rags & Grease	DWO	Jones Falls	2:00	5:30 PM - 7:30 PM	Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	135036
44	2/20/2012	2300 Allendale Rd	21216	Pipe Break	DWO	Gwynns Falls	24:23	2/20/12 9:37 AM - 2/21/12 10:00 AM	Heavy Gray Water	1,463	By-pass Pump around Pipe Break	Sent to Construction for Pipe Repair	135055
45	2/20/2012	4400 Laplata Ave	21211	Rags & Grease	DWO	Jones Falls	1:00	12:00 PM - 1:00 PM	Heavy Gray Water	300	Pressure Jet relieved Mainline choke	Turn over to CCTV	135061
46	2/20/2012	508 S Hanover St	21201	Debris	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Mud & Paper around Cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	135065
47	2/20/2012	2616 Talbot Rd	21216	Debris	DWO	Gwynns Falls	Overflow Not Witnessed	Overflow Not Witnessed	Heavy Gray Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	135072
48	2/20/2012	3113 Bancroft Rd	21209	Rags	DWO	Jones Falls	2:21	6:24 PM - 8:45 PM	Sewer Water	1,410	Pressure Jet relieved Mainline choke	Turn over to CCTV	135076

SSO Notification List

February 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
49	2/20/2012	4815 Lindsay Rd	21229	Rags	DWO	Gwynns Falls	Overflow Not Witnessed	Overflow Not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	135078
50	2/21/2012	208 S Augusta Ave	21229	Rags	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	135119
51	2/21/2012	2111 N Ellamont St	21216	Rags	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	135126
52	2/21/2012	3732 Manchester Ave	21215	Rags	DWO	Gwynns Falls	17:47	2/21/12 4:13 PM - 2/22/12 10:00 AM	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	135143
53	2/22/2012	5804 Kipling Ct	21212	Roots & Grease	DWO	Herring Run	4:55	9:05 AM - 2:00 PM	Brown & Gray Water	295	Electric Machine relieved House Connection choke	Turn over to CCTV	135160
54	2/22/2012	3026 Seamon Ave	21225	Rags & Grease	DWO	Patapsco	1:00	10:19 AM - 11:19 AM	Heavy Gray Water	600	Pressure Jet relieved Mainline choke	Turn over to CCTV	135168
55	2/22/2012	526 S Beechfield Ave	21229	Rags, Roots, Grease	DWO	Gwynns Falls	3:17	10:43 AM - 2:00 PM	Heavy Gray Water	394	Pressure Jet relieved Mainline choke	Turn over to CCTV	135173
56	2/22/2012	121 S Augusta Ave	21229	Roots	DWO	Gwynns Falls	14:10	2/22/12 6:55 PM - 2/23/12 9:05 AM	Heavy Gray Water	850	Electric Machine relieved House Connection choke	Turn over to CCTV	135218
57	2/22/2012	3011 Wolcott Ave	21216	Rags & Debris	DWO	Gwynns Falls	2:40	7:00 PM - 9:40 PM	Sewer Water	320	Pressure Jet relieved Mainline choke	Turn over to CCTV	135216
58	2/23/2012	3011 Wolcott Ave	21216	Rags & Debris	DWO	Gwynns Falls	7:08	7:52 AM - 3:00 PM	Heavy Gray Water	428	Pressure Jet relieved Mainline choke	Turn over to CCTV	135249
59	2/25/2012	620 Parkwyth Ave	21218	Rags & Grease	DWO	None	50:00	2/25/12 10:00 AM - 2/27/12 12:00 PM	Wet around Clean-Out	Unknown (Intermittent Flow)	Electric Machine relieved House Connection choke	Turn over to CCTV	135403
60	2/25/2012	3328 W Caton Ave	21229	Rags & Grease	DWO	None	0:30	2:30 PM - 3:00 PM	Gray Water	30	Pressure Jet relieved Mainline choke	Turn over to CCTV	135334
61	2/26/2012	1273 Walker Ave	21239	Roots	DWO	Herring Run	1:10	4:50 PM - 6:00 PM	Grease & Gray Water	140	Electric Machine relieved House Connection choke	Turn over to CCTV	135374
62	2/27/2012	2905 Woodland Ave	21215	Rags	DWO	Jones Falls	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	135447
63	2/27/2012	4307 Edgehurst Rd	21209	Rags, Roots, Grease	DWO	Jones Falls	30:01	2/27/12 8:35 AM - 2/28/12 2:36 PM	Heavy Gray Water	5,403	Pressure Jet relieved Mainline choke	Turn over to CCTV	135477
64	2/27/2012	3665 Dudley Ave	21213	Bad Spot	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	135432
65	2/28/2012	508 S Hanover St	21201	Mud	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	135488
66	2/28/2012	4216 Friar Field Run	21213	Roots & Grease	DWO	Herring Run	20:00	2/28/12 12:30 PM - 2/29/12 8:30 AM	Gray Water	3,600	Pressure Jet relieved Mainline choke	Turn over to CCTV	135493
67	2/28/2012	6500 Riverview Ave	21222	Grease & Debris	DWO	Patapsco	3:10	2/28/12 10:00 PM - 2/29/12 1:10 AM	Sewer Water	950	Pressure Jet relieved Mainline choke	Turn over to CCTV	135530
68	2/29/2012	2324 Druid Hill Ave	21217	Rags	WVO	Jones Falls	3:29	10:31 AM - 2:00 PM	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	135542
69	2/29/2012	105 Millbrook Rd	21218	Grease & Debris	WVO	Jones Falls	3:10	8:05 PM - 11:15 PM	Sewer Water	950	Pressure Jet relieved Mainline choke	Turn over to CCTV	135581
				# WVO	8				TOTAL	19,547			