

SSO Notification List

January 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	1/2/2012	1531 N Rosedale St	21229	Rags & Grease	DWO	Gwynns Falls	1:00	10:53 AM - 11:53 AM	Gray Water	180	Pressure Jet relieved Mainline choke	Turn over to CCTV	132726
2	1/3/2012	3032 Seamon Ave	21225	Rags	DWO	Patapsco	2:06	11:52 AM - 1:58 PM	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	132788
3	1/3/2012	3026 Woodring Ave	21234	Rags & Grease	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	132826
4	1/4/2012	225 Northway	21218	Roots & Trash	DWO	None	1:50	8:40 AM - 10:30	Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	132819
5	1/4/2012	1329 Greenmount Ave	21213	Rags, Grease, Trash	DWO	Inner Harbor	1:05	12:30 PM - 1:35 PM	Brown & Gray Water	325	Pressure Jet relieved Mainline choke	Turn over to CCTV	132828
6	1/4/2012	1734 E 30th St	21218	Rags	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	132825
7	1/4/2012	2337 Edmonson Ave	21223	Rags	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	132860
8	1/5/2012	4805 Williston St	21229	Rags & Grease	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	132896
9	1/5/2012	609 E 38th St	21218	Rags, Grease, Trash	DWO	Jones Falls	18:05	1/4/12 6:10 PM - 1/5/12 12:15 PM	Brown & Gray Water	7,595	Pressure Jet relieved Mainline choke	Turn over to CCTV	132899
10	1/5/2012	3727 Clarenell Rd	21229	Roots	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	132900
11	1/6/2012	1329 Greenmount Ave	21202	Rags, Grease, Trash	DWO	Jones Falls	1:30	11:00 AM - 12:30 PM	Brown & Gray Water	900	Pressure Jet relieved Mainline choke	Turn over to CCTV	132952
12	1/7/2012	2801 Goodwood Rd	21214	Roots & Grease	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133006
13	1/8/2012	3707 Cheshome Rd	21216	Rags	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133018
14	1/8/2012	3019 Elizabeth Ave	21230	Rags, Roots, Grease	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133036
15	1/8/2012	242 N Payson St	21223	Rags, Grease, Trash	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133052
16	1/9/2012	1329 Greenmount Ave	21202	Rags & Grease	WWO	None	1:00	1:45 PM - 2:45 PM	Paper & Gray Water	60	Pressure Jet relieved Mainline choke	Turn over to CCTV	132850
17	1/10/2012	39 N Bentalou St	21223	Rags & Grease	DWO	Gwynns Falls	0:27	10:58 AM - 11:25 AM	Heavy Gray Water	135	Pressure Jet relieved Mainline choke	Turn over to CCTV	133148
18	1/10/2012	2215 W Baltimore St	21223	Rags & Grease	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Heavy Gray Water	Evidence of Overflow	No action take (cannot relieve old style traps)	Left Plumber's notice for consumer	90918
19	1/11/2012	618 N Carrollton Ave	21217	Rags & Roots	WWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133213
20	1/11/2012	1723 Ruxton Ave	21216	Rags & Grease	WWO	Gwynns Falls	3:44	11:16 AM - 3:00 PM	Heavy Gray Water	224	Electric Machine relieved House Connection choke	Turn over to CCTV	133224
21	1/11/2012	107 N Rock Glen Rd	21229	Rags, Roots, Grease	WWO	Gwynns Falls	2:12	1:28 PM - 3:40 PM	Heavy Gray Water	660	Pressure Jet relieved Mainline choke	Turn over to CCTV	133232
22	1/11/2012	3001 Erdman Ave	21213	Rags	WWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133242
23	1/12/2012	3635 Elkader Rd	21218	Rags, Roots, Grease	WWO	Jones Falls	0:35	10:45 AM - 11:20 AM	Gray Water	175	Pressure Jet relieved Mainline choke	Turn over to CCTV	133272

SSO Notification List

January 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
24	1/13/2012	2942 Keswick Rd	21211	Roost	WWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133312
25	1/13/2012	2600 Hollins Ferry Rd	21230	Rags & Grease	WWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Sewer Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	133329
26	1/13/2012	2221 Gable Ave	21230	Rags & Grease	WWO	Gwynns Falls	2:36	3:58 PM - 6:34 PM	Heavy Gray Water	312	Pressure Jet relieved Mainline choke	Turn over to CCTV	133334
27	1/13/2012	5609 Sinclair Ln	21206	Rags & Roots	WWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around manhole	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	133341
28	1/14/2012	1550 N Monroe St	21217	Rags	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133349
29	1/14/2012	5601 Gwynn Oak Ave	21207	Sand, Gravel, Rocks	DWO	Gwynns Falls	4:00	2:00 PM - 6:00 PM	Gray Water	240	Pressure Jet relieved Mainline choke	Turn over to CCTV	133355
30	1/14/2012	100 N Wolfe St	21213	Rags & Grease	DWO	Inner Harbor	1:37	6:23 PM - 8:00 PM	Grease & Gray Water	194	Pressure Jet relieved Mainline choke	Turn over to CCTV	133366
31	1/15/2012	1100 Vincent St	21217	Debris	DWO	Patapsco	0:50	1:40 PM - 2:30 PM	Grease & Gray Water	100	Pressure Jet relieved Mainline choke	Turn over to CCTV	133390
32	1/17/2012	4016 Massachusetts Ave	21229	Roots	WWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133451
33	1/18/2012	1633 Ceddox St	21226	Rags	DWO	Curtis Bay	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133527
34	1/18/2012	3748 Ellerslie Ave	21218	Rags & Roots	DWO	Jones Falls	15:25	1/18/12 6:40 PM - 1/19/12 10:05 AM	Gray Water	2,775	Pressure Jet relieved Mainline choke	Turn over to CCTV	133536
35	1/19/2012	4534 Hazelwood Ave	21206	Roots & Trash	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133550
36	1/19/2012	217 Southway	21218	Roots	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133556
37	1/19/2012	1800 Park Ave	21217	Heavy Debris	DWO	Jones Falls	1:55	6:20 PM - 8:15 PM	Sewer Water	1,150	Pressure Jet relieved Mainline choke	Turn over to CCTV	133565
38	1/20/2012	608 Markham Rd	21229	Roots	WWO	Gwynns Falls	2:46	9:46 AM - 12:32 PM	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133579
39	1/21/2012	617 Lennox St	21217	Rags & Debris	WWO	Jones Falls	1:00	12:55 PM - 1:55 PM	Sewer Water	600	Pressure Jet relieved Mainline choke	Turn over to CCTV	133625
40	1/22/2012	1500 E Fayette St	21231	Grease	WWO	Inner Harbor	0:55	1:05 PM - 2:00 PM	Grease & Gray Water	165	Pressure Jet relieved Mainline choke	Turn over to CCTV	133655
41	1/22/2012	1200 Pennsylvania Ave	21217	Rags & Grease	WWO	Jones Falls	21:00	1/22/12 2:30 PM - 1/23/12 11:30 AM	Gray Water	6,300	Pressure Jet relieved Mainline choke	Turn over to CCTV	133664
42	1/24/2012	820 Harford Ct	21202	Rags, Grease, Trash	DWO	Jones Falls	2:15	8:15 AM - 10:30 AM	Brown & Gray Water	675	Pressure Jet relieved Mainline choke	Turn over to CCTV	133715
43	1/24/2012	2308 McCulloh St	21217	Rags & Debris	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133728
44	1/24/2012	1500 N Wolfe St	21213	Grease & Debris	DWO	Northwest Harbor	4:13	3:02 PM - 7:15 PM	Sewer Water	3,795	Pressure Jet relieved Mainline choke	Turn over to CCTV	133739
45	1/24/2012	5601 Gwynn Oak Ave	21207	Pipe Break & Sand, Gravel, Rocks	DWO	Gwynns Falls	39:30	1/24/12 6:30 PM - 1/26/12 10:00 AM	Heavy Gray Water	7,110	By-pass Pump to stop overflow	Set to Construction	133753
46	1/24/2012	3203 Elmora Rd	21213	Roots	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133770

SSO Notification List

January 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
47	1/25/2012	3507 W Belvedere Ave	21215	Rags	DWO	Gwynns Falls	4:54	8:36 AM - 1:30 PM	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133781
48	1/25/2012	2905 Whitney Ave	21215	Roots	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133784
49	1/25/2012	6226 O'Donnell St	21224	Rags & Grease	DWO	Northwest Harbor	3:47	3:13 PM - 7:00	Sewer Water	454	Pressure Jet relieved Mainline choke	Turn over to CCTV	133796
50	1/25/2012	933 Montpelier St	21218	Rags	DWO	Herring Run	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133808
51	1/25/2012	2822 Alvarado Sq	21234	Rags & Roots	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Cables & Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133825
52	1/26/2012	6317 Wallis Ave	21215	Unknown	DWO	Jones Falls	3:31	9:04 AM - 12:35 PM	Heavy Gray Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	133839
53	1/26/2012	4016 Massachusetts Ave	21229	Unknown	DWO	Gwynns Falls	Overflow Not Witnessed	Overflow Not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133844
54	1/27/2012	707 Linnard St	21229	Rags	WVO	None	Overflow Not Witnessed	Overflow Not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133895
55	1/27/2012	N Fremont Ave & Riggs Ave	21217	Rags & Grease	WVO	Jones Falls	1:41	12:19 PM - 2:00 PM	Heavy Gray Water	202	Pressure Jet relieved Mainline choke	Turn over to CCTV	133905
56	1/27/2012	1800 W Baltimore St	21223	Rags & Grease	WVO	Patapsco	1:00	12:46 PM - 1:46 PM	Heavy Gray Water	300	Pressure Jet relieved Mainline choke	Turn over to CCTV	133900
57	1/27/2012	5106 Saint Georges Ave	21212	Rags	WVO	None	Overflow Not Witnessed	Overflow Not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	133918
58	1/29/2012	Pulaski Hwy & N Highland Ave	21224	Rags, Grease, Trash	DWO	Northwest Harbor	1:05	10:10 AM - 11:15 AM	Gray Water	650	Vac Com Machine relieved Mainline choke	Turn over to CCTV	133969
59	1/29/2012	1308 W Franklin St	21223	Rags & Grease	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Rags & Grease	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	131386
60	1/29/2012	1226 S Charles St	21230	Unknown	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	91638
61	1/30/2012	3305 Bancroft Rd	21215	Roots & Debris	DWO	Jones Falls	21:08	1/30/12 1:22 PM - 1/31/12 10:30 AM	Heavy Gray Water	3,804	Pressure Jet relieved Mainline choke	Turn over to CCTV	133984
62	1/30/2012	1226 S Charles St	21230	Mud	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134036
63	1/31/2012	2601 Boone St	21218	Grease	DWO	None	Overflow Not Witnessed	Overflow Not Witnessed	Wet around cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	134073
64	1/31/2012	2135 Homewood Ave	21218	Unknown	DWO	Jones Falls	Overflow Not Witnessed	Overflow Not Witnessed	Gray Water	Evidence of Overflow	No action take (cannot relieve old style traps)	Left Plumber's notice for consumer	134082
65	1/31/2012	1500 N Wolfe St	21213	Rags, Grease, Trash	DWO	Northwest Harbor	1:00	10:45 AM - 11:45 AM	Brown & Gray Water	600	Pressure Jet relieved Mainline choke	Turn over to CCTV	134083
66	1/31/2012	3812 Reisterstown Rd	21215	Rags & Heavy Debris	DWO	Gwynns Falls	1:03	8:07 PM - 9:10 PM	Sewer Water	126	Pressure Jet relieved Mainline choke	Turn over to CCTV	134122
				# WVO	15				TOTAL	33,670			