

## SSO Notification List

August 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	8/2/2012	4709 Norwood Ave	21207	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	142361
2	8/2/2012	144 W. Lanvale St	21217	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet around cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	142375
3	8/3/2012	2010 Wilkens Ave	21223	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet around cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	142420
4	8/6/2012	2007 W. Rogers Ave	21209	Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	142486
5	8/7/2012	3341 W. Belvedere Ave	21215	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	142600
6	8/8/2012	3304 W. North Ave	21216	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	142634
7	8/9/2012	133 S. Loudon Ave	21229	Rags & Grease	WWO	Gwynns Falls	1:35	9:25AM - 11:00AM	Heavy Gray Water	190	Pressure Jet relieved Mainline choke	Turn over to CCTV	142678
8	8/9/2012	3705 W. Belvedere Ave	21215	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	142682
9	8/11/2012	1704 Chilton St	21218	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet around cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	142765
10	8/13/2012	2423 Chesterfield Ave	21213	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet around cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	142857
11	8/13/2012	3700 Harford Rd	21218	Rags & Grease	DWO	Herring Run	15:26	8/13/12 6:34PM - 8/14/12 10:00PM	Heavy Gray Water	4,630	Pressure Jet relieved Mainline choke	Turn over to CCTV	142882
12	8/15/2012	Club Rd & Beechdale Rd	21210	Rags & Grease	DWO	Jones Falls	1:20	8:40AM - 10:00AM	Heavy Gray Water	240	Pressure Jet relieved Mainline choke	Turn over to CCTV	142974
13	8/15/2012	2709 Round Rd	21225	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143000
14	8/17/2012	1201 E. Belvedere Ave	21239	Rags & Trash	WWO	Herring Run	1:00	10:45AM - 11:45AM	Gray Colored Water	60	Pressure Jet relieved Mainline choke	Turn over to CCTV	143083
15	8/18/2012	5713 Edgepark Rd	21239	N/A	WWO	Herring Run	0:26	2:15PM - 2:41PM	Gray Water Grease	52	Pressure Jet relieved Mainline choke	Turn over to CCTV	143118
16	8/18/2012	1327 W. Fayette St	21223	Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143129
17	8/19/2012	1801 Sulgrave Ave	21209	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	143144
18	8/19/2012	1015 N. Mount St	21217	Debris	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143146
19	8/20/2012	2737 Prospect St	21216	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143215
20	8/20/2012	6307 Lincoln Ave	21209	Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143216
21	8/21/2012	1600 E. 28th St	21218	Rags & Grease	DWO	Baltimore Harbor	2:00	9:30AM - 11:30AM	Grease	600	Pressure Jet relieved Mainline choke	Turn over to CCTV	143239
22	8/21/2012	4300 Robertson Ave	21206	Debris	DWO	Herring Run	1:14	8:58PM - 10:12PM	Sewer Water	370	Pressure Jet relieved Mainline choke	Turn over to CCTV	143323
23	8/22/2012	5100 Loch Raven Blvd	21239	N/A	DWO	Herring Run	2:05	8:00AM - 10:05AM	Gray Colored Water	625	Pressure Jet relieved Mainline choke	Turn over to CCTV	143286
24	8/23/2012	3919 Boarman Ave	21215	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143341
25	8/23/2012	6513 Detroit Ave	21222	Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	143368
26	8/24/2012	6300 Fortview Way	21224	Rags & Grease	DWO	None	2:00	8:00AM - 10:00AM	Gray Colored Water	360	Pressure Jet relieved Mainline choke	Turn over to CCTV	143382
27	8/24/2012	6100 The Alameda	21218	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	143380

**SSO Notification List**

**August 2012**

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
28	8/24/2012	3300 The Alameda	21218	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143396
29	8/26/2012	1148 Homestead St	21218	Rags & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	143442
30	8/26/2012	604 Venable Ave	21218	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143454
31	8/26/2012	1900 Bik Falls Rd	21201	Heavy Rain	WWO	Jones Falls	2:25	5:00PM - 7:25PM	Sewer Water	1,450	Stood by until rain event ended & surcharged went down	N/A	143463
32	8/27/2012	5614 Winthrop Ave	21214	Sand, Gravel, Rocks	DWO	Herring Run	1:25	5:50PM - 7:15PM	Sewer Water	170	Pressure Jet relieved Mainline choke	Turn over to CCTV	143518
33	8/30/2012	2513 Hamilton Ave	21214	Rags, Roots & Trash	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143681
34	8/30/2012	708 Harvey St	21230	Rags & Trash	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143693
35	8/30/2012	3341 W. Belvedere Ave	21215	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143702
36	8/30/2012	123 W. Lanvale St	21217	Unknown	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Left plumber notice to locate or install cleanout in the rear	N/A	143728
37	8/31/2012	1234 N. Broadway	21213	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143765
38	8/31/2012	1236 N. Broadway	21213	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143766
39	8/31/2012	462 Roundview Rd	21225	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	143784
				# WWO	16				TOTAL	8,747	EVIDENCE ONLY	27	