

SSO Notification List

August 2014

| Serial No. | Date of Occurrence | Location | Zip Code | Reason | Dry or Wet-Weather Overflow? | Stream Affected | Duration (Hrs:Min) | Time | Description of Discharge | Est. Quantity of Discharge (gallons) | Measures taken to Minimize Discharge | Preventive Action to Stop Recurrence | Work Order # |
|------------|--------------------|----------------------------|----------|---|------------------------------|-----------------|--------------------|------------------------|---------------------------------------|--------------------------------------|---|--|--------------|
| 1 | 8/1/2014 | 2820 Winwood Ct | 21225 | N/A | WET | N/A | Not Witnessed | Overflow not Witnessed | Water on side walk | Evidence of Overflow | Used elec-mach. T/O to housing (private) | UAMD | 203249 |
| 2 | 8/1/2014 | 4545 N Charles St | 21210 | Rags, grease | WET | N/A | Not Witnessed | Overflow not Witnessed | Wet around MH in grass | Evidence of Overflow | Used press machine | UAMD | 203225 |
| 3 | 8/2/2014 | Pascal Ave & Everett St | 21225 | Rags, roots, debris | WET | N/A | Not Witnessed | Overflow not Witnessed | Sewer water | Evidence of Overflow | Pressure jet relieved ML choke | UAMD | 203284 |
| 4 | 8/6/2014 | 3700 Greenspring Ave | 21215 | Pipe break, sand, gravel, rocks | DRY | Jones Falls | 2:56 | 7:00 AM - 10:00 AM | Heavy gray water | 880 | Relieved M/L choke with pressure truck 200ft of 8in san M/L CCTV | N/A | 203730 |
| 5 | 8/7/2014 | 309 Rossiter Ave | 21218 | Roots, trash | DRY | N/A | Not Witnessed | Overflow not Witnessed | Small amount of paper around cleanout | Evidence of Overflow | Cleaned line with elec mach | UAMD | 203809 |
| 6 | 8/7/2014 | 3128 Weaver Ave | 21214 | Roots | DRY | N/A | Not Witnessed | Overflow not Witnessed | Paper around clean out | Evidence of Overflow | Used elec. mach. | UAMD | 203945 |
| 7 | 8/8/2014 | 2021 Druid Hill Ave | 21217 | Rags | DRY | N/A | Not Witnessed | Overflow not Witnessed | Wet around clean out | Evidence of Overflow | Used elec. mach. | UAMD | 204064 |
| 8 | 8/11/2014 | 2716 Saint Paul St | 21218 | Rags | DRY | N/A | Not Witnessed | Overflow not Witnessed | Paper debris | Evidence of Overflow | Drain cleaning machine relieved h/c choke | UAMD | 138368 |
| 9 | 8/12/2014 | 1200 Armistead Way | 21205 | Rags, Grease | WET | N/A | 0:30 | 6:00 PM - 6:30 PM | Water, paper coming from Manhole | 90 | Used press. mach. | UAMD | 204414 |
| 10 | 8/12/2014 | 1550 Orleans St | 21205 | Heavy Rain | WET | N/A | Not Witnessed | Overflow not Witnessed | Sewer Water | Evidence of Overflow | Wait for rain event to stop | N/A | N/A |
| 11 | 8/12/2014 | 1800 S Clinton St | 21224 | Heavy Rain | WET | N/A | Not Witnessed | Overflow not Witnessed | Sewer Water | Evidence of Overflow | Wait for rain event to stop | N/A | N/A |
| 12 | 8/12/2014 | 3300 Clipper Mill Rd | 21211 | Heavy Rain | WET | N/A | Not Witnessed | Overflow not Witnessed | Sewer Water | Evidence of Overflow | Wait for rain event to stop | N/A | N/A |
| 13 | 8/12/2014 | 1901 Falls Rd | 21217 | N/A | WET | N/A | 7:41 | 2:19 PM - 10:00 PM | Heavy gray water | 23050 | Overcharging ongoing | overflow stop at 10:00AM | 204400 |
| 14 | 8/12/2014 | Dundalk Ave & Holabird Ave | 21224 | Heavy Rain | WET | N/A | Not Witnessed | Overflow not Witnessed | Sewer Water | Evidence of Overflow | Wait for rain event to stop | N/A | N/A |
| 15 | 8/12/2014 | 2121 Wicomico St | 21230 | Heavy rain | WET | Gwynns Falls | 1:35 | 2:00 PM - 3:35 PM | N/A | 46996.5 | N/A | Part of the consent decree improvement project | N/A |
| 16 | 8/12/2014 | 1819 Eager st | 21205 | Heavy rain | WET | Low Level | 5:50 | 1:00 PM - 6:50 PM | N/A | 7704998 | N/A | Part of the consent decree improvement project | N/A |
| 17 | 8/12/2014 | 1731 E Chase St | 21213 | Heavy rain | WET | Low Level | 4:25 | 1:15 PM - 5:40 PM | N/A | 1462800 | N/A | Part of the consent decree improvement project | N/A |
| 18 | 8/13/2014 | 2525 Insulator Dr | 21230 | Rags, grease, sand, gravel, rocks | DRY | N/A | 2:00 | 12:30 PM - 2:30 PM | Heavy gray water | 360 | Relieved M/L choke with pressure truck 25ft of 2in ft of san | N/A | 204577 |
| 19 | 8/14/2014 | 2525 Insulator Dr | 21230 | Grease, sand, gravel, rocks | DRY | N/A | 1:02 | 11:13 AM - 12:15 PM | Heavy gray water | 186 | Relieved M/L choke with 25ft of 2in T/O construction | N/A | 204723 |
| 20 | 8/14/2014 | 2627 Cross Country Blvd | 21215 | Rags, roots | DRY | N/A | Not Witnessed | Overflow not Witnessed | N/A | Evidence of Overflow | Relieved house conn choke with elec mach 45ft TV 5 bottom 22 ft main line | N/A | 204673 |
| 21 | 8/14/2014 | 2379 Sundew Ter | 21209 | Infiltration/Inflow, Other | DRY | N/A | Not Witnessed | Overflow not Witnessed | Paper debris | Evidence of Overflow | Turned over to HABC | N/A | 204703 |
| 22 | 8/16/2014 | 2720 Latona Rd | 21214 | Rags, roots | DRY | N/A | Not Witnessed | Overflow not Witnessed | Small amount of paper around cleanout | Evidence of Overflow | Cleaned line with elec mach | UAMD | 204953 |
| 23 | 8/16/2014 | 3814 Millford Ave | 21207 | Roots | DRY | N/A | Not Witnessed | Overflow not Witnessed | Paper debris in yard | Evidence of Overflow | Drain cleaning machine relieved h/c choke | UAMD | 204929 |
| 24 | 8/19/2014 | 6004 Woodcrest Ave | 21209 | Rags | DRY | N/A | 1:30 | 5:00 PM - 7:30 PM | Water, paper coming from manhole | 150 | Used pressure machine | UAMD | 205313 |
| 25 | 8/20/2014 | 334 S Calhoun St | 21223 | Rags, grease | DRY | N/A | Not Witnessed | Overflow not Witnessed | Wet around manhole | Evidence of Overflow | Used press machine | UAMD | 205499 |
| 26 | 8/20/2014 | 1107 Slater Rd | 21225 | Rags, grease, debris | DRY | N/A | 1:25 | 2:50 PM - 5:15 PM | Gray water | 290 | Pressure truck flush & rel. main line choke, 300 ft pressure hose | UAMD CCTV Main line & Storm drain | 205466 |
| 27 | 8/21/2014 | 811 Powers St | 21211 | N/A | DRY | N/A | Not Witnessed | Overflow not Witnessed | Dampness | Evidence of Overflow | Plumber notice, locate or install cleanout closer to city mainline | UAMD | 205594 |
| 28 | 8/21/2014 | 3301 Parkside Dr | 21206 | Heavy Rain | WET | N/A | Not Witnessed | Overflow not Witnessed | Paper debris | Evidence of Overflow | N/A | N/A | N/A |
| 29 | 8/22/2014 | 1004 Roland Heights Ave | 21211 | Rags | DRY | N/A | Not Witnessed | Overflow not Witnessed | Paper | Evidence of Overflow | Used Elec mach | UAMD | 205916 |
| 30 | 8/22/2014 | 2213 Roslyn Ave | 21216 | N/A | DRY | N/A | Not Witnessed | Overflow not Witnessed | N/A | Evidence of Overflow | Water run off in ditch | N/A | 205780 |
| 31 | 8/22/2014 | 2227 Bank St | 21231 | Rags | DRY | N/A | Not Witnessed | Overflow not Witnessed | Paper water on side walk | Evidence of Overflow | Used elec mach | UAMD | 205804 |
| 32 | 8/24/2014 | 6608 Danville Ave | 21224 | Roots | DRY | N/A | Not Witnessed | Overflow not Witnessed | Toilet paper | Evidence of Overflow | Run Elec-Machine cable 45ft relieve choke | UAMD | 205909 |
| 33 | 8/26/2014 | 307 E 22nd St | 21218 | Pipe break | DRY | N/A | Not Witnessed | Overflow not Witnessed | Sewer water | Evidence of Overflow | Left a final plumbers notice | N/A | 206068 |
| 34 | 8/26/2014 | 3107 E Fairmount Ave | 21224 | Rags | DRY | N/A | Not Witnessed | Overflow not Witnessed | Sewer water and paper debris | Evidence of Overflow | Drain cleaning machine relieved h/c choke | UAMD | 206105 |
| 35 | 8/27/2014 | Boston St & Joplin St | 21224 | Rags, grease, infiltration/inflow, debris | DRY | N/A | 2:24 | 5:26 AM - 7:50 AM | Sewer water, grease | 7200 | Pressure jet relieved M/L choke | UAMD | 206177 |
| 36 | 8/27/2014 | 2830 Winwood Ct | 21225 | Infiltration/Inflow, Other | DRY | N/A | Not Witnessed | Overflow not Witnessed | Paper debris | Evidence of Overflow | Turned over to housing dept. | N/A | N/A |

SSO Notification List

August 2014

| Serial No. | Date of Occurrence | Location | Zip Code | Reason | Dry or Wet-Weather Overflow? | Stream Affected | Duration (Hrs:Min) | Time | Description of Discharge | Est. Quantity of Discharge (gallons) | Measures taken to Minimize Discharge | Preventive Action to Stop Recurrence | Work Order # |
|------------|--------------------|------------------------|----------|----------------------------|------------------------------|-----------------|--------------------|------------------------|-----------------------------|--------------------------------------|--|--------------------------------------|--------------|
| 37 | 8/27/2014 | 3512 Old Frederick Rd | 21229 | Infiltration/Inflow, Other | DRY | N/A | 8:25 | 2:11 PM - 10:36 PM | Sewer water | 2525 | Pressure jet cleaned the mainline | UAMD | 206283 |
| 38 | 8/28/2014 | 1100 Clendenin St | 21217 | Rags, grease, dirt | DRY | N/A | Not Witnessed | Overflow not Witnessed | Toilet paper | Evidence of Overflow | Pressure truck relieved Main line 200ft pressure hose | CCTV Mainline | 206354 |
| 39 | 8/28/2014 | 5816 Berkeley Ave | 21215 | Rags | DRY | N/A | Not Witnessed | Overflow not Witnessed | Wet paper arround clean out | Evidence of Overflow | Used elec mach | UAMD | 206429 |
| 40 | 8/29/2014 | 1900 E Fayette St | 21231 | Rags, grease | DRY | N/A | 0:60 | 8:30 PM - 9:30 PM | Gray colored | 300 | Used sewer jet | UAMD CCTV | 206607 |
| 41 | 8/29/2014 | 5139 Wetheredsville Rd | 21207 | Roots | DRY | N/A | 1:42 | 9:25 AM - 11:07 AM | Toilet paper | 102 | Ran Elec Mavhine Rel 30ft Elec Machine cables | UAMD | 206497 |
| 42 | 8/30/2014 | 2103 Westfield Ave | 21214 | Grease | DRY | N/A | Not Witnessed | Overflow not Witnessed | Paper, sticks | Evidence of Overflow | T.V connection use electric auger and left plumbers notice | UAMD | 206628 |
| | | | | # WWO | 13 | | | | TOTAL | 9249927.5 | EVIDENCE ONLY | 28 | |