

SSO Notification List

December 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	12/1/2012	1036 Braddish Ave	21216	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	148353
2	12/1/2012	2548 Marbourne Ave	21230	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	148364
3	12/1/2012	4523 Pimlico Rd	21215	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	N/A	N/A	148326
4	12/2/2012	4403 Wakefield Rd	21216	Roots	DWO	Gwynns Falls	3:28	10:12AM - 1:40PM	Heavy Gray Water	1,040	Pressure Jet relieved Mainline choke	Turn over to CCTV	148375
5	12/2/2012	5928 Glen Falls Ave	21206	Pipe Break	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Left Plumber a notice	N/A	148393
6	12/3/2012	2727 E. Strathmore Ave	21214	Pipe Break & Sand, Gravel, Rocks	DWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	N/A	148475
7	12/3/2012	3001 Saint Paul St	21218	Pipe Break	DWO	Jones Falls	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	N/A	148460
8	12/4/2012	1028 N. Calvert St	21202	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	148540
9	12/4/2012	3700 Clifton Ave	21216	Rags, Grease & Debris	DWO	Gwynns Falls	1:00	10:15AM - 11:15AM	Sewer Water	300	Pressure Jet relieved Mainline choke	Turn over to CCTV	148515
10	12/4/2012	4909 Liberty Heights Ave	21207	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	148560
11	12/4/2012	5101 Harford Rd	21214	Roots & Grease	DWO	Herring Run	14:45	12/4/12 7:30PM - 12/5/12 10:15AM	Clear Colored Water	885	Electric Machine relieved House Connection choke	Turn over to CCTV	148576
12	12/5/2012	1318 N. Luzerne Ave	21213	Rags & Grease	DWO	None	0:30	11:00AM - 11:30AM	Gray Colored Water	30	Pressure Jet relieved Mainline choke	Turn over to CCTV	148602
13	12/5/2012	Dundalk Ave & Gusryan St	21224	Rags & Debris	DWO	Inner Harbor	1:00	7:20PM - 8:20PM	Sewer Water	600	Pressure Jet relieved Mainline choke	Turn over to CCTV	148651
14	12/6/2012	921 E. Fort Ave	21230	Grease & Debris	DWO	Inner Harbor	1:40	7:20PM - 9:00PM	Sewer Water	200	Pressure Jet relieved Mainline choke	Turn over to CCTV	148734
15	12/6/2012	2002 Greenmount Ave	21218	Rags & Grease	DWO	Jones Falls	1:05	1:55PM - 3:00PM	Gray Water & Grease	130	Pressure Jet relieved Mainline choke	Turn over to CCTV	148713
16	12/6/2012	2101 Pentland Drive	21239	Rags & Grease	DWO	Herring Run	2:06	11:44AM - 1:50PM	Rags & Grease	630	Pressure Jet relieved Mainline choke	Unable to CCTV	148700
17	12/6/2012	2461 Perring Manor Rd	21234	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	N/A	N/A	SR#102605
18	12/6/2012	3616 Hickory Ave	21211	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	148715
19	12/6/2012	5006 Litchfield Ave	21215	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	148701
20	12/6/2012	Gwynns Falls Pkwy & Tioga Pkwy	21215	Rags & Debris	DWO	Gwynns Falls	1:45	6:05PM - 7:50PM	Sewer Water	210	Pressure Jet relieved Mainline choke	Turn over to CCTV	148728
21	12/7/2012	601 E. 34th St	21218	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	N/A	148819
22	12/7/2012	4909 Ross Rd	21216	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Possible root control	148801
23	12/8/2012	112 Elmhurst Rd	21210	Rags & Grease	WVO	Jones Falls	3:00	12:18PM - 3:18PM	Gray Water	360	Pressure Jet relieved Mainline choke	Turn over to CCTV	148836
24	12/8/2012	201 E. Pratt St	21202	Rags & Grease	WVO	Jones Falls	1:06	9:06PM - 10:15PM	Grease & Rags	138	Pressure Jet relieved Mainline choke	Turn over to CCTV	148858
25	12/10/2012	2629 Rayner Ave	21216	N/A	DWO	None	1:57	9:33AM - 11:30AM	Debris, Rags & Grease	351	Pressure Jet relieved Mainline choke	Turn over to CCTV	148832
26	12/11/2012	810 Glade Ct	21225	Rags & Grease	WVO	Patapsco	15:14	12/11/12 8:12PM - 12/12/12 11:26AM	Heavy Gray Water	4,570	Pressure Jet relieved Mainline choke	Turn over to CCTV	149031
27	12/12/2012	812 S. Sharp St	21230	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	149046

SSO Notification List

December 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
28	12/13/2012	2509 Shellydale Dr	21209	Roots	DWO	Jones Falls	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	149156
29	12/14/2012	214 Tunbridge Rd	21212	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	149330
30	12/14/2012	831 Brooks Ln	21217	Rags	DWO	Jones Falls	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	N/A
31	12/14/2012	3533 Lucille Ave	21215	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	N/A	N/A	140941
32	12/14/2012	4828 Pimlico Rd	21215	Rags & Roots	DWO	Gwynns Falls	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	149239
33	12/14/2012	5600 Woodmont Ave	21239	Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Grease	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	149339
34	12/15/2012	102 E. 25th St	21202	Rags & Grease	DWO	Jones Falls	2:34	4:56PM - 7:30PM	Toilet Paper & Grease	308	Electric Machine relieved House Connection choke	Turn over to CCTV	149370
35	12/15/2012	102 E. 25th St	21202	Rags & Grease	DWO	Jones Falls	2:35	4:45PM - 7:20PM	Gray Water & Grease	620	Pressure Jet relieved Mainline choke	Turn over to CCTV	149371
36	12/15/2012	502 S. Belnord Ave	21231	Grease	DWO	Inner Harbor	6:07	12:23PM - 6:30PM	Gray Water & Grease	1,101	Electric Machine relieved House Connection choke	Turn over to CCTV	149366
37	12/15/2012	1051 Cameron St	21212	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	149358
38	12/15/2012	1638 Ruxton Ave	21216	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	149354
39	12/15/2012	4210 Nadine Dr	21215	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	149361
40	12/15/2012	4801 Lorelly Ave	21216	N/A	DWO	Inlet	1:00	12:00PM - 1:00PM	Wet Around Sidewalk	30	Electric Machine relieved House Connection choke	Turn over to CCTV	149352
41	12/15/2012	6608 Danville Ave	21224	N/A	DWO	Patapsco	Overflow not Witnessed	Overflow not Witnessed	Toilet Paper	Evidence of Overflow	Left Plumber a notice	N/A	149360
42	12/16/2012	4005 Carlisle Ave	21216	Rags & Grease	WVO	Gwynns Falls	1:00	1:55PM - 2:55PM	Toilet Paper	180	Electric Machine relieved House Connection choke	Turn over to CCTV	149401
43	12/17/2012	3250 E. Fayette St	21224	Grease & Debris	WVO	Inner Harbor	2:55	7:20PM - 10:15PM	Sewer Water	1,750	Pressure Jet relieved Mainline choke	Turn over to CCTV	146536
44	12/18/2012	3415 Clarks Ln	21215	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	149690
45	12/18/2012	3902 Hillsdale Rd	21207	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	149570
46	12/18/2012	5314 Wendley Rd	21229	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	149539
47	12/19/2012	103 Woodlawn Rd	21210	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	149768
48	12/19/2012	214 Tunbridge Rd	21212	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	None	Evidence of Overflow	Electric Machine relieved House Connection choke	Possible root control	149757
49	12/19/2012	5807 Royal Oak Ave	21207	Rags & Dirt, Debris	DWO	Gwynns Falls	1:19	8:38PM - 9:57PM	Sewer Water	158	Pressure Jet relieved Mainline choke	Turn over to CCTV	149780
50	12/19/2012	6608 Danville Ave	21222	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Possible root control	149721
51	12/20/2012	4004 W. Strathmore Ave	21215	Rags	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	149857
52	12/21/2012	Denison St & Walbrook Ave	21216	Rags & Roots	WVO	Gwynns Falls	2:50	6:30PM - 7:20PM	Sewer Water & Paper Debris	850	Electric Machine relieved House Connection choke	Turn over to CCTV	149996
53	12/22/2012	Bridgeview Rd & Round Rd	21225	Rags & Grease	DWO	Patapsco	3:00	2:42PM - 5:42PM	Heavy Gray Water	360	Pressure Jet relieved Mainline choke	Turn over to CCTV	150018
54	12/23/2012	307 Rossiter Ave	21212	Roots	DWO	Herring Run	4:24	10:36AM - 3:00PM	Heavy Gray Water	264	Electric Machine relieved House Connection choke	Turn over to CCTV	150039

SSO Notification List

December 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
55	12/23/2012	412 E. Cold Spring Ln	21212	Grease	DWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	N/A
56	12/26/2012	2200 Kirk Ave	21218	Rags, Grease & Debris	WWO	Jones Falls	1:23	9:30PM - 10:53PM	Sewer Water & Grease	166	Pressure Jet relieved Mainline choke	Turn over to CCTV	150198
57	12/26/2012	2706 E. Strathmore Ave	21214	Roots	WWO	Herring Run	2:39	12:21PM - 3:00PM	Clear Colored Water	795	Pressure Jet relieved Mainline choke	Turn over to CCTV	150147
58	12/27/2012	700 Belle Terre Ave	21218	Roots & Trash	WWO	Herring Run	0:40	10:50AM - 11:30AM	Gray Colored Water	80	Pressure Jet relieved Mainline choke	Turn over to CCTV	150221
59	12/27/2012	817 Stoll St	21225	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150239
60	12/27/2012	1322 W. Pratt St	21223	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150214
61	12/27/2012	2701 Mount Holly St	21216	Rags & Roots	WWO	Gwynns Falls	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150295
62	12/27/2012	4017 Kathland Ave	21207	Roots & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150253
63	12/27/2012	4829 Reisterstown Rd	21215	Rags & Grease	WWO	Gwynns Falls	1:26	9:42AM - 11:08AM	Heavy Gray Water	258	Pressure Jet relieved Mainline choke	Turn over to CCTV	150211
64	12/27/2012	5713 Edgepark Rd	21239	Rags & Roots	WWO	Herring Run	1:20	9:30AM - 10:50AM	Gray Colored Water	400	Pressure Jet relieved Mainline choke	Turn over to CCTV	150217
65	12/28/2012	700 W. University Pkwy	21211	Rags & Roots	DWO	Jones Falls	3:00	8:42AM - 11:42AM	Heavy Gray Water	360	Pressure Jet relieved Mainline choke	Turn over to CCTV	150302
66	12/28/2012	2014 McCulloh St	21217	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Left Plumber a notice	N/A	150332
67	12/29/2012	Falls Rd & Hillside Rd	21210	Rags, Roots & Grease	WWO	Jones Falls	2:36	9:24AM - 12:00PM	Heavy Gray Water	780	Pressure Jet relieved Mainline choke	Turn over to CCTV	150448
68	12/29/2012	Harford Rd & Parkside Dr	21214	Sand, Gravel, Rocks	WWO	Herring Run	45:27	12/29/12 12:33PM - 12/31/12 10:00AM	Heavy Gray Water	13,635	Pressure Jet relieved Mainline choke	Turn over to CCTV	150502
69	12/30/2012	2949 Frederick Ave	21223	Rags & Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150545
70	12/31/2012	900 Druid Hill Ave	21201	Rags & Grease	DWO	High Level	0:24	2:36PM - 3:00PM	Heavy Gray Water	48	Pressure Jet relieved Mainline choke	Turn over to CCTV	150579
71	12/31/2012	5701 O'Donnell St	21224	Rags & Grease	DWO	Northwest Harbor	0:55	9:55AM - 10:50AM	Gray Colored Water	165	Pressure Jet relieved Mainline choke	Turn over to CCTV	150553
				# WWO	20				TOTAL	31,752	EVIDENCE ONLY	38	