

SSO Notification List

December 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	12/1/2014	1300 Kitmore Rd	21239	Roots, Trash, Sand, Gravel, Rocks	DWO	Herring Run	42	Gray colored water	210	Jetted line with pressure truck	CCTV asap	218096
2	12/2/2014	4002 Edmondson Ave	21229	Rags, Grease	WVO	Gwynns Falls	168	Heavy gray water	840	Relieved M/L choke with pressure truck	275 ft of 8 inch T/O for CCTV	218247
3	12/2/2014	900 Ellicott Dwy	21216	Rags, Roots, Grease	DWO	N/A	81	Heavy gray water	1,215	Relieved M/L choke with pressure truck	50 ft of 6 inch T/O for CCTV	218215
4	12/4/2014	128 N Linwood Ave	21224	Rags	DWO	N/A	160	Wet paper around clean out	800	CCTV	Used electric machine	218646
5	12/4/2014	4507 Wakefield Rd	21216	Unknown	DWO	N/A	Not Witnessed	Toilet Paper	Evidence of Overflow	Mainline cleaning	CCTV MainLine	218632
6	12/7/2014	3111 Echodale Ave	21214	Rags, Roots, Grease	DWO	N/A	50	Heavy gray water	100	Relieved M/L choke with pressure truck T/O for CCTV	Pressure truck T/O for CCTV	218862
7	12/8/2014	1117 N Caroline St	21213	Pipe Break	DWO	N/A	Not Witnessed	Wet around clean out	Evidence of Overflow	Used electric machine	CCTV	219080
8	12/8/2014	2313 Hamilton Ave	21214	Trash, Sand, Gravel, Rocks	DWO	N/A	Not Witnessed	Heavy paper	Evidence of Overflow	Relieved with electric machine	CCTV	218889
9	12/8/2014	307 E 22nd St	21218	Pipe Break	DWO	N/A	Not Witnessed	Paper and gray colored water	Evidence of Overflow	Cleaned line with Elec. Machine	Line to be TV'd after owner fixes pipe	218986
10	12/8/2014	5214 Beaufort Ave	21215	Unknown	DWO	N/A	Not Witnessed	Standing sewage, rear yard (possible broken consumer line)	Evidence of Overflow	Turned over to health deptment	Turned over to health deptment	219126
11	12/9/2014	1120 Hamburg St	21230	Rags	DWO	N/A	Not Witnessed	toilet paper	Evidence of Overflow	ran elec. mach	cctv	219215
12	12/9/2014	2301 Windsor Ave	21216	Rags	WVO	N/A	Not Witnessed	Toilet paper	Evidence of Overflow	Relieved with elec. machine	CCTV	219164
13	12/9/2014	3028 Pinewood Ave	21214	Rags, Roots	WVO	N/A	Not Witnessed	Heavy paper and rags	Evidence of Overflow	Cleaned line with elec. mach.	Line turned over to be TV'd ASAP	219213
14	12/9/2014	3701 Southwestern Blvd	21229	Rags, Grease	WVO	N/A	142	Gray water	720	Pressure truck used to clear line	CCTV	219241
15	12/10/2014	2523 S Paca St	21230	Rags, Trash, Sand, Gravel, Rocks	DWO	Gwynns Falls	393	Sanitary mainline choke causing wastewater to hold and infiltrate stormdrain underground	1,965	Clear mainline	Use pressure truck to clear mainline	219467
16	12/11/2014	109 N Fremont Ave	21201	Rags, Grease	DWO	Inner Harbor	2,010	High ammonia at outfall, sewage scum in storm drain	2,010	Bypass pumping was needed to clear line	Bypass pumping and pressure machine were both used	219612
17	12/13/2014	1208 Saint Paul St	21202	Rags	DWO	N/A	Not Witnessed	Gray water	Evidence of Overflow	Relieved with Electric machine	CCTV	219795
18	12/14/2014	2600 DuPont Ave	21215	Rags, Roots, Trash, Sand, Gravel, Rocks	DWO	N/A	73	Rags, grease, debris	365	Pressure truck relieved from clean out	CCTV	219835
19	12/15/2014	2725 Hampden Ave	21211	Rags	DWO	N/A	Not Witnessed	gray water & debris	Evidence of Overflow	Ran electric machine	CCTV	219907
20	12/16/2014	531 Coventry Rd	21229	Rags, Roots, Grease	WVO	N/A	152	Grease & debris	304	Rel. with electric machine	CCTV	220072
21	12/16/2014	4310 Lasalle Rd	21206	Pipe Break	DWO	Moore's Run	150	Discharge into adjacent storm drain	300	Main was cleaned/flushed	CCTV after main was cleaned/flushed	220017
22	12/17/2014	15 Edgevale Rd	21210	Rags, Grease	DWO	N/A	Not Witnessed	Found mainline choke no overflow, evidence of overflow SSO report needed	Evidence of Overflow	Relieved m/l choke with pressure truck, 15 ft of 6" lamphole	CCTV	220205
23	12/17/2014	3917 Boarman Ave	21215	Rags	DWO	N/A	Not Witnessed	Front house connection choke. Evidence of overflow, Gray water. SSO report needed.	Evidence of Overflow	Relieved with electric machine	CCTV	220252
24	12/18/2014	2801 W Mulberry St	21223	Rags, Grease	DWO	Gwynns Falls	122	Sewage in storm inlet	1,220	Relieved m/l choke with press truck 300 ft of 8"	CCTV	220352
25	12/18/2014	307 E 22nd St	21218	Pipe Break	DWO	N/A	Not Witnessed	Clean water and paper	Evidence of Overflow	This location is turned over to housing dept.	To have housing turn water off	220405
26	12/18/2014	802 E Coldspring La	21212	Unknown, Other	DWO	Jones Falls	98	Gray colored water	196	Bypass pumping and pressure machine	CCTV	220446
27	12/19/2014	500 Poplar Grove St	21223	Pipe Break	DWO	Gwynns Falls	411	Sanitary line has a dip in it and the sewage is leaving and entering the storm drain along Pop Grove St	411	CCTV mainline, found mainline break	Turned over to construction for mainline repair	220550
28	12/20/2014	1650 Union Ave	21211	Rags, Trash, Sand, Gravel, Rocks	DWO	Jones Falls	195	Heavy paper and rags	3,900	Cleaned line with vactor truck	Line to be tied a.s.a.p.	220627
29	12/21/2014	4008 Hamilton Ave	21206	Rags, Trash, Sand, Gravel, Rocks	DWO	N/A	77	Cloudy and Dark water running from cleanout onto front lawn	77	30 Ft. Elec. cable relieved choke	CCTV	220661
30	12/22/2014	2507 Oswego Ave	21215	Rags, Roots, Rain, Grease	WVO	N/A	Not Witnessed	Evidence of overflow coming from basement	Evidence of Overflow	Relieved M/L choke with press truck 205 ft of 8" 1/0 evidence of overflow from basement	CCTV	220770

