

SSO Notification List

February 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	2/1/2013	2500 Queen Anne Rd	21216	Rags, Roots & Debris	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Ice	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	153007
2	2/2/2013	2801 Goodwood Rd	21214	N/A	WWO	Herring Run	1:43	9:46AM - 12:29PM	Not Noted	103	Electric Machine relieved House Connection choke	Turn over to CCTV	153028
3	2/2/2013	3008 Parkside Dr	21214	N/A	WWO	Herring Run	0:37	2:22PM - 2:59PM	Heavy Gray Water	37	Electric Machine relieved House Connection choke	Turn over to CCTV	153037
4	2/3/2013	103 Elmwood Rd	21210	Rags, Roots & Grease	DWO	Jones Falls	5:29	12:31PM - 6:00PM	Heavy Gray Water	987	Pressure Jet relieved Mainline choke	N/A	SR#:105227
5	2/3/2013	214 Edgevale Rd	21210	Rags, Roots & Grease	DWO	Jones Falls	5:29	12:31PM - 6:00PM	Heavy Gray Water	987	Pressure Jet relieved Mainline choke	Turn over to CCTV	SR#:105224
6	2/3/2013	5009 Falls Road Ter	21210	Rags & Grease	DWO	Jones Falls	4:47	1:13PM - 6:00PM	Heavy Gray Water	861	Pressure Jet relieved Mainline choke	Turn over to CCTV	153057
7	2/5/2013	408 E. 31st St	21218	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Possible grease control	SR#: 105318
8	2/5/2013	834 Chauncey Ave	21217	Rags & Grease	DWO	Jones Falls	0:30	10:40AM - 11:10AM	Gray Water	90	Pressure Jet relieved Mainline choke	Turn over to CCTV	153383
9	2/5/2013	4605 Briarcliff Rd	21229	Rags & Grease	DWO	Gwynns Falls	0:20	10:25AM - 10:45AM	Gray Water	60	Pressure Jet relieved Mainline choke	Turn over to CCTV	153384
10	2/6/2013	1637 Northwick Ct	21218	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water & Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	153511
11	2/6/2013	5423 O'Donnell St	21224	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	153510
12	2/8/2013	1700 E. Cold Spring Ln	21218	Grease	WWO	Herring Run	3:45	5:15PM - 9:00PM	Sewer Water	1,125	Pressure Jet relieved Mainline choke	Turn over to CCTV	153812
13	2/9/2013	817 Stoll St	21225	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	153687
14	2/9/2013	1935 Penrose Ave	21223	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	153634
15	2/9/2013	2716 St. Paul St	21218	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper around Cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	153629
16	2/10/2013	1000 N. Bond St.	21205	Rags & Grease	DWO	Outfall	1:53	12:07PM - 2:00PM	Heavy Gray Water	565	Pressure Jet relieved Mainline choke	Turn over to CCTV	153652
17	2/10/2013	2860 Gatehouse Dr	21207	Rags & Grease	DWO	Gwynns Falls	5:05	4:30pm - 9:35PM	Gray Water & Rags	915	Pressure Jet relieved Mainline choke	Turn over to CCTV	153670
18	2/11/2013	4300 Sidehill Rd	21229	Rags	WWO	Gwynns Falls	20:18	2/11/13 5:01PM - 2/12/13 1:19PM	Heavy Gray Water	3,654	Pressure Jet relieved Mainline choke	Turn over to CCTV	153730
19	2/12/2013	1701 Sulgrave Ave	21209	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	153738
20	2/13/2013	341 E. 27th St	21218	Rags & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Paper around Cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	153862
21	2/14/2013	332 N. Pulaski St	21223	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Found Old Slyle Trap in Rear Yard	N/A	153888
22	2/14/2013	801 North Point Blvd	21224	Broken Pipe	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet dirt near Sidewalk	Evidence of Overflow	Consumer has broken water line	N/A	SR#: 105716
23	2/14/2013	2500 E. Northern Pkwy	21214	Rags, Grease & Debris	DWO	Herring Run	0:30	9:15PM - 9:45PM	Sewer Water	150	Pressure Jet relieved Mainline choke	Turn over to CCTV	153920
24	2/14/2013	4408 Bowleys Ln	21206	Grease	DWO	Herring Run	0:26	6:04PM - 6:30PM	Sewer Water	130	Pressure Jet relieved Mainline choke	Turn over to CCTV	153906
25	2/17/2013	733 E. 22nd St	21218	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154032
26	2/17/2013	5407 Catalpha Rd	21214	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154027
27	2/18/2013	6701 Quad Ave	21237	Rags	DWO	Herring Run	1:35	8:25AM - 10:00AM	Heavy Gray Water	95	Electric Machine relieved House Connection choke	Turn over to CCTV	154043

SSO Notification List

February 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
28	2/19/2013	699 Frankfurst Ave	21226	Rags, Grease & Sand, Gravel, Rocks	WVO	Patapsco	23:50	2/19/13 7:10PM - 2/20/13 7:00PM	Heavy Gray Water	7,150	Pressure Jet relieved Mainline choke	Replacement	154148
29	2/20/2013	17 N. Ann St	21231	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	154178
30	2/21/2013	520 N. Carrollton Ave	21223	Roots	DWO	Baltimore Harbor	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154232
31	2/21/2013	605 E. 34th St	21218	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Paper around Cleanout	Evidence of Overflow	Left Plumber a notice	N/A	154203
32	2/21/2013	2231 Rogene Dr	21209	Rags, Grease & Sand, Gravel, Rocks	DWO	Jones Falls	2:01	11:31AM - 2:30PM	Heavy Gray Water	242	Pressure Jet relieved Mainline choke	Turn over to CCTV	154216
33	2/21/2013	4410 Lewin Ave	21215	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Consumer stated no problem	N/A	154231
34	2/22/2013	2205 Arden Rd	21209	N/A	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154259
35	2/22/2013	2500 W. North Ave	21216	N/A	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	154312
36	2/22/2013	4410 Lewin Ave	21215	N/A	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154277
37	2/24/2013	1007 N. Iris Ave	21205	Improper Cleanout Installation	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Tissue on ground	Evidence of Overflow	Have contractor install pipe correctly	N/A	154387
38	2/24/2013	1800 W. Saratoga St	21223	N/A	DWO	Gwynns Falls	2:24	2:04PM - 4:28PM	Heavy Gray Water	432	Pressure Jet relieved Mainline choke	Turn over to CCTV	154368
39	2/24/2013	4623 Kernwood Ave	21212	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Little Tissue	Evidence of Overflow	Found Cleanout Cap in Pipe	N/A	154389
40	2/24/2013	4711 Herring Run Dr	21214	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Wooded Area	N/A	154374
41	2/25/2013	700 W. University Pkwy	21210	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	154380
42	2/26/2013	300 Armory Pl	21201	Rags	WVO	Jones Falls	9:15	9:50AM - 7:05PM	Sewer Water	2,775	Pressure Jet relieved Mainline choke	Turn over to CCTV	154472
43	2/26/2013	1001 E. Northern Pkwy	21212	Roots & Trash	WVO	Herring Run	0:35	11:10AM - 11:45AM	Clear Colored Water	70	Pressure Jet relieved Mainline choke	Turn over to CCTV	154468
44	2/26/2013	2313 Allendale Rd	21216	N/A	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	N/A	154469
45	2/26/2013	2617 Woodland Ave	21215	Rags & Grease	WVO	Gwynns Falls	4:29	7:31AM - 12:00PM	Heavy Gray Water	269	Pressure Jet relieved Mainline choke	Turn over to CCTV	154459
46	2/26/2013	3000 W. Lanvale St	21216	Rags, Grease & Sand, Gravel, Rocks	WVO	Gwynns Falls	1:41	1:34PM - 3:15PM	Heavy Gray Water	202	Pressure Jet relieved Mainline choke	Turn over to CCTV	154492
47	2/26/2013	E. Northern Pkwy & Northwood Dr	21212	Grease	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Grease	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	154501
48	2/27/2013	3027 Walbrook Ave	21216	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154540
49	2/27/2013	3846 Oakford Ave	21215	N/A	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	154575
50	2/28/2013	3101 Pulaski Hwy	21224	Rags, Grease & Debris	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris & Grease	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	154517
				# WVO	19				TOTAL	20,899	EVIDENCE ONLY	29	