

**SSO Notification List**

**February 2014**

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	2/3/2014	107 N Rock Glen Rd	21229	Rags, Roots, Grease	WWO	Patapsco	4:30	10:42AM - 3:11PM	Heavy Gray Water	1350	Relieved M/L choke with pressure truck 200ft of 8in san M/L, T/O for CCTV	N/A	181808
2	2/3/2014	520 N Carrollton Ave	21223	Rags, Roots, Grease	WWO	Patapsco	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with pressure truck 100ft og 8in T/O for CCTV	N/A	181841
3	2/3/2014	3106 Gwynns Falls Pkwy	21216	Rags, Roots, Grease	WWO	Patapsco	1:31	11:39AM - 1:10PM	Heavy Gray Water	910	Relieved M/L choke with pressure truck, 275ft of 8in san M/L, T/O for CCTV	N/A	181814
4	2/3/2014	Greenspring Ave & Coldspring Ln	21209	Pipe break, Sand, Gravel, Rocks	WWO	Patapsco	12:00	10:00AM - 10:00PM	Heavy Gray Water	7200	M/L break stop overflow	Bypass pumping, T/O construction	181836
5	2/5/2014	3714 Elmley Ave	21213	Rags, Grease	WWO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around clean out	Evidence of Overflow	Used Elec. Machine	UAMD	181915
6	2/5/2014	6465 Frankford Ave	21206	Rags, Grease	WWO	Herring Run	23:57	02/05/2014 12:44PM - 02/06/2014 2:41PM	Gray water, paper debris, grease	7185	Pressure jet relieved M/L choke	UAMD	181953
7	2/5/2014	Ridgewood Rd & Roland Ave	21210	Rags, Grease	WWO	N/A	Not Witnessed	Overflow not Witnessed	Gray colored water	Evidence of Overflow	Used sewer jet	UAMD	181929
8	2/5/2014	5214 The Alameda	21217	Rags, Roots	WWO	Herring Run	2:19	11:51AM - 14:10PM	Sewer Water	278	Pressure jet relieved M/L choke	UAMD	181891
9	2/8/2014	Holabird Ave & Manor Ave	21224	Grease, Trash	DWO	Dundalk	4:10	10:45AM - 2:55PM	Clear colored water	750	Jetted line with vac com	UAMD	182038
16	2/8/2014	1906 Cedric Rd	21216	Rags	DWO	N/A	4:50	3:00PM - 7:30PM	Gray colored water	540	Used sewer jet	UAMD-CCTV	182057
10	2/11/2014	2616 Talbot Rd	21216	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Rel. 45ft Elec-Machine cable	UAMD	182153
11	2/11/2014	2850 Round Rd	21225	Rags, Roots, Debris	DWO	Patapsco	0:15	9:45AM - 10:00AM	Gray water	30	Rel. 200ft pressure machine hose	CCTV Mainline	182134
12	2/11/2014	3510 Eldorado Ave	21207	Rags	DWO	Patapsco	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach, 80ft of 8in	N/A	182162
15	2/12/2014	4801 Lorelly Ave	21206	Roots	WWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Drain cleaning relieved the h/c choke	UAMD	182210
13	2/14/2014	3205 Fairfield Rd	21226	Grease	DWO	Patapsco	12:22	7:18AM - 7:40PM	Heavy Gray Water	3710	M/L choke used bypass pumping to stop overflow at 1901 Chesapeake Ave	N/A	184724
14	2/15/2014	302 Edgevale Rd	21210	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	Water in cleanout, Wet paper	Evidence of Overflow	Used Elec. Machine	UAMD	185532
17	2/19/2014	3314 Pinkney Rd	21215	Rags, Debris	WWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water, Paper	Evidence of Overflow	Relieved house conn choke, 60ft. Elec-machine cables	UAMD	186180
18	2/19/2014	2433 Washington Blvd	21230	Pipe break	WWO	Patapsco	3:09	12:15PM - 3:24PM	Gray water	378	Turn over to Anchor Construction corporation	N/A	186194
19	2/19/2014	3714 Elmley Ave	21213	Rags	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved H/C choke	UAMD	186210
21	2/19/2014	5800 Greenspring Ave	21209	Rags, Roots, Debris	WWO	Jones Falls	15:38	02/19/2014 7:46PM - 02/20/2014 11:24AM	Gray water	1876	Pressure truck relieved M/L choke 150ft pressure mach. hose	UAMD CCTV M/L	186251
20	2/20/2014	1800 Ensor St	21202	Rags, Grease	DWO	Patapsco	3:13	10:09AM - 13:22PM	Sewer water	965	Pressure jet relieved the M/L choke	UAMD	186267
23	2/21/2014	311 Somerset Rd	21210	Roots	WWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water, Paper	Evidence of Overflow	Relieved H/C choke with 75ft Elec-Mach.	UAMD	186320
24	2/21/2014	5900 Simmonds Ave	21215	Rags, Grease	WWO	Jones Falls	0:60	7:00PM - 8:00PM	Gray colored water	60	Used sewer jet	UAMD	186349
25	2/22/2014	1600 Rutland Ave	21213	Rags, Debris	DWO	Jones Falls	3:32	11:48AM - 3:20PM	Gray water	212	Pressure truck rel. M/L choke	UAMD CCTV M/L	186367
27	2/23/2014	310 Radnor Rd	21212	Roots	WWO	Patapsco	0:28	12:07PM - 12:35PM	Gray water, Paper	56	Relieved with 30ft Elec.-Machine cables	UAMD-CCTV	186388
28	2/23/2014	3935 Boarman Ave	21215	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water, Paper	Evidence of Overflow	Relieved with electric machine	UAMD-CCTV	186422
22	2/24/2014	435 N Linwood	21205	Rags	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved H/C choke	UAMD	186457

**SSO Notification List**

**February 2014**

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
26	2/24/2014	2433 Washington Blvd	21230	Rags, Grease	WWO	Patapsco	6:50	02/22/2014 3:09PM - 02/23/2014 9:59AM	Gray water	410	Rel 280ft pressure machine hose	UAMD CCTV M/L	186380
29	2/24/2014	Cross Country Blvd & Kelly Ave	21209	Rags, Grease	WWO	Jones Falls	0:60	5:00PM - 6:00PM	Gray colored water	180	Used sewer jet	UAMD	186463
30	2/24/2014	1626 Braddish Ave	21215	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Used Elec. Mach.	UAMD	186468
31	2/25/2014	1317 Lemmon St	21223	Rags, Debris	WWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Rel. Elec-Machine, 30ft. Elec-Machine	UAMD	186514
33	2/25/2014	101 Deepdene Rd	21210	Rags, Roots	WWO	Jones Falls	1:30	4:00PM - 5:30PM	Gray colored water	90	Used sewer jet	UAMD-CCTV	186516
34	2/25/2014	3024 Gwynns Falls Pkwy	21216	Rags, Grease	WWO	High Level	0:30	10:30AM - 11:00AM	Gray colored water	30	Used sewer jet	UAMD-CCTV	186564
35	2/25/2014	1321 Lemmon St	21223	Rags	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper, Rags	Evidence of Overflow	Used Elec. Mach.	UAMD-CCTV	186506
36	2/25/2014	508 S Hanover St	21201	Rags, Grease	WWO	N/A	Not Witnessed	Overflow not Witnessed	Wet-paper	Evidence of Overflow	Used Elec. Mach.	UAMD	186540
32	2/26/2014	102 S Fagley St	21224	Grease	WWO	Patapsco	0:15	11:05AM - 12:05PM	Paper	30	Relieved with electric machine and house cutter	UAMD-CCTV	186579
37	2/26/2014	2571 W Fayette St	21223	Rags, Grease	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper-wet-water	Evidence of Overflow	Used Elec. Mach.	UAMD	186620
38	2/28/2014	Dupont Ave & Greenspring Ave	21209	Rags, Trash	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet-paper-rags around clean-out	Evidence of Overflow	Used Elec. Mach. downhill no top on clean-out	UAMD	186742
39	2/28/2014	6500 Riverview Ave	21222	Rags, Grease	DWO	Dundalk	0:60	10:30AM - 11:30AM	Gray colored water	60	Used sewer jet	CCTV	186767
				# WWO	29				TOTAL	26300	EVIDENCE ONLY	18	