

## SSO Notification List

January 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	1/1/2013	602 Parkyrth Ave	21218	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150632
2	1/2/2013	208 S. Augusta Ave	21229	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150693
3	1/2/2013	424 E. Oliver St	21202	Rags & Grease	DWO	Inlet	1:30	8:30AM - 10:00AM	Gray Colored Water	90	Pressure Jet relieved Mainline choke	Turn over to CCTV	150656
4	1/2/2013	1108 N. Gilmor St	21217	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150706
5	1/2/2013	2438 Dorton Ct	21230	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	150713
6	1/4/2013	717 N. Fremont Ave	21217	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray & Grease	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150821
7	1/4/2013	900 Belgian Ave	21218	Rags & Grease	DWO	Inlet	1:30	11:00AM - 12:30PM	Gray Colored Water	90	Pressure Jet relieved Mainline choke	Turn over to CCTV	150795
8	1/4/2013	2807 Overland Ave	21214	Roots & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet on sidewalk	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150756
9	1/4/2013	3201 Georgetown Rd	21230	Roots	DWO	None	4:20	10:03AM - 2:23PM	Heavy Gray Water	260	Pressure Jet relieved Mainline choke	Turn over to CCTV	150799
10	1/4/2013	3677 Eastwood Dr	21206	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	N/A	N/A	SR#103834
11	1/4/2013	6383 Elliott St	21224	Rags & Grease	DWO	Herring Run	12:10	1/4/13 10:20PM - 1/5/13 10:30AM	Gray Water, Rags & Grease	1,460	Pressure Jet relieved Mainline choke	Turn over to CCTV	150840
12	1/5/2013	18 Gorman Ave	21223	Rags & Grease	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150865
13	1/5/2013	201 N. Carey St	21223	Pipe Break	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	N/A	Left Consumer a notice	150874
14	1/5/2013	907 Cator Ave	21218	Rags & Grease	WVO	Herring Run	2:05	12:10PM - 2:15PM	Gray Water	125	Electric Machine relieved House Connection choke	Turn over to CCTV	150854
15	1/5/2013	3626 Greenmount Ave	21218	Rags & Grease	WVO	Herring Run	1:20	12:10PM - 1:30PM	Debris, toilet paper & Grease	240	Electric Machine relieved House Connection choke	N/A	150851
16	1/7/2013	2608 Maryland Ave	21218	Roots & Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150926
17	1/7/2013	6003 Pinehurst Rd	21212	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Grease & Toilet Paper	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	150916
18	1/8/2013	1322 E. Cold Spring Ln	21239	Rags & Grease	DWO	Herring Run	1:25	9:30AM - 10:55AM	Gray Water & Grease	340	Pressure Jet relieved Mainline choke	Turn over to CCTV	150978
19	1/8/2013	1500 Brentwood Ave	21202	Rags & Grease	DWO	Jones Falls	1:30	10:25AM - 11:55AM	Gray Water	270	Pressure Jet relieved Mainline choke	Turn over to CCTV	150983
20	1/8/2013	2400 Round Rd	21225	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	150985
21	1/8/2013	4200 N. Franklinton Rd	21229	Rags, Roots & Debris	DWO	Gwynns Falls	1:30	3:00PM - 4:30PM	Sewer Water & Paper Debris	6,750	Pressure Jet relieved Mainline choke	Turn over to CCTV	151023
22	1/8/2013	Morris Rd & Franklinton Rd	21216	Rags & Grease	DWO	Gwynns Falls	1:01	11:51AM - 12:52PM	Heavy Gray Water	61	Pressure Jet relieved Mainline choke	Turn over to CCTV	150993
23	1/9/2013	126 N. Clinton St	21224	Rags & Grease	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151074
24	1/9/2013	201 N. Carey St	21223	Rags	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151072
25	1/9/2013	1704 W. Rogers Ave	21209	Rags, Pipe Break & Sand, Gravel, Roots	WVO	Jones Falls	3:54	10:06AM - 2:00PM	N/A	234	Pressure Jet relieved Mainline choke	Turn over to CCTV	151060
26	1/9/2013	2815 E. Northern Pkwy	21214	Rags & Grease	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	SR#104075
27	1/10/2013	630 Gutman Ave	21218	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Water at Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Possible root control	151130

## SSO Notification List

January 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
28	1/10/2013	2118 Clifton Ave	21217	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper on ground around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151216
29	1/11/2013	2118 Clifton Ave	21217	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151217
30	1/11/2013	2800 Sethlow Rd	21225	Rags & Grease	WWO	Patapsco	4:02	11:48AM - 3:50PM	Heavy Gray Water	726	Pressure Jet relieved Mainline choke	Turn over to CCTV	151193
31	1/11/2013	2801 Beechland Ave	21214	Rags & Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151198
32	1/12/2013	1908 Ramblewood Rd	21239	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Tissue & Stain on ground	Evidence of Overflow	N/A	N/A	151252
33	1/12/2013	4807 Cordelia Ave	21215	Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151241
34	1/13/2013	3632 Beach Ave	21211	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151278
35	1/14/2013	2803 Elgin Ave	21216	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Left Plumber a notice	N/A	151319
36	1/14/2013	13 E. Lake Ave	21212	Rags & Trash	WWO	Herring Run	13:30	1/14/13 10:00PM - 1/15/13 11:30AM	Brown & Gray Colored Water	2,430	Pressure Jet relieved Mainline choke	Turn over to CCTV	151364
37	1/14/2013	1806 Ashburton St	21216	Object in cleanout	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Left Plumber a notice	N/A	151350
38	1/14/2013	5423 O'Donnell St	21224	Grease	WWO	Northwest Harbor	16:00	1/14/13 6:00PM - 1/15/13 10:00AM	Brown & Gray Colored Water	4,800	Pressure Jet relieved Mainline choke	Turn over to CCTV	151346
39	1/14/2013	5800 O'Donnell St	21224	Grease	WWO	Northwest Harbor	21:35	1/14/13 3:25PM - 1/15/13 1:00PM	Gray Colored Water	6,475	Pressure Jet relieved Mainline choke	Turn over to CCTV	151337
40	1/15/2013	112 N. Clinton St	21224	Grease	WWO	Northwest Harbor	2:45	6:40PM - 9:25PM	Gray Colored Water	825	Pressure Jet relieved Mainline choke	Turn over to CCTV	151418
41	1/15/2013	219 E. North Ave	21202	Pipe Break	WWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151407
42	1/15/2013	2409 E. Biddle St	21213	Rags & Trash	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151412
43	1/15/2013	2723 Louise Ave	21214	Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151424
44	1/15/2013	2801 Beechland Ave	21214	Rags, Roots & Trash	WWO	Herring Run	1:35	11:25AM - 1:00PM	Gray Colored Water	95	Electric Machine relieved House Connection choke	Turn over to CCTV	151375
45	1/16/2013	2308 McCulloh St	21217	N/A	WWO	Gwynns Falls	3:15	6:45PM - 10:00PM	Heavy Gray Water	195	Electric Machine relieved House Connection choke	Turn over to CCTV	151500
46	1/16/2013	2602 N. Calvert St	21218	Rags & Trash	WWO	Gwynns Falls	15:00	01/16/13 10:00PM - 01/17/13 1:00PM	Brown & Gray Colored Water with paper	2,700	Pressure Jet relieved Mainline choke	Turn over to CCTV	151510
47	1/16/2013	2807 Overland Ave	21214	Roots & Grease	WWO	Inlet	1:30	10:00AM - 11:30AM	Gray Colored Water	90	Electric Machine relieved House Connection choke	Turn over to CCTV	151438
48	1/16/2013	3427 Mondawmin Ave	21216	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	151434
49	1/17/2013	1201 E. Belvedere Ave	21212	Rags & Trash	DWO	Herring Run	2:25	11:45AM - 2:10PM	Gray Colored Water	435	Pressure Jet relieved Mainline choke	Turn over to CCTV	151581
50	1/17/2013	2124 Hollins St	21223	Rags & Grease	DWO	Gwynns Falls	12:00	01/16/13 9:00PM - 01/17/13 9:00AM	Gray Colored Water	720	Pressure Jet relieved Mainline choke	Turn over to CCTV	151504
51	1/18/2013	193 S. Penrose Ave	21223	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Paper around Cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151647
52	1/18/2013	2556 W. Baltimore St	21223	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Water in yard	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151621
53	1/18/2013	4539 Falls Rd	21209	Rags	DWO	Jones Falls	Overflow not Witnessed	Overflow not Witnessed	Sewer Water & Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151671
54	1/19/2013	2801 Goodwood Rd	21214	Roots	DWO	Herring Run	2:03	9:15AM - 11:18AM	Heavy Gray Water	123	Electric Machine relieved House Connection choke	Turn over to CCTV	151684

## SSO Notification List

January 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
55	1/19/2013	3435 Edmondson Ave	21216	Rags & Trash	DWO	Gwynns Falls	3:00	7:00PM - 10:00PM	Brown & Gray Colored Water	900	Pressure Jet relieved Mainline choke	Turn over to CCTV	151698
56	1/20/2013	87 S. Morely St	21229	N/A	DWO	Gwynns Falls	1:05	9:45AM - 10:50AM	Toilet Paper & Grease	65	Electric Machine relieved House Connection choke	Turn over to CCTV	151708
57	1/20/2013	2601 Oswego Ave	21215	Rags, Grease & Trash	DWO	Gwynns Falls	5:00	2:00PM - 7:00PM	Brown & Gray Colored Water	3,000	Pressure Jet relieved Mainline choke	Turn over to CCTV	151718
58	1/20/2013	Aliceanna St & President St	21202	Rags & Trash	DWO	Inner Harbor	2:30	7:30PM - 10:00PM	Brown Colored Water	1,500	Pressure Jet relieved Mainline choke	Turn over to CCTV	151729
59	1/20/2013	Edgevale Rd & Elmwood Rd	21210	Rags, Roots & Trash	DWO	Jones Falls	1:30	5:00PM - 6:30PM	Gray Colored Water	450	Pressure Jet relieved Mainline choke	Turn over to CCTV	151722
60	1/20/2013	Edgevale Rd & Elmwood Rd	21210	Rags & Grease	DWO	Jones Falls	2:12	1:18PM - 3:30PM	Gray Water	264	Pressure Jet relieved Mainline choke	Turn over to CCTV	151715
61	1/21/2013	Elmwood Rd & Edgevale Rd	21210	Rags & Grease	DWO	Inlet	1:00	11:30AM - 12:30PM	Gray Colored Water	30	Pressure Jet relieved Mainline choke	Turn over to CCTV	151773
62	1/22/2013	1603 N. Broadway	21231	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Water on Sidewalk	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151805
63	1/22/2013	201 N. Carey St	21223	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151799
64	1/22/2013	4306 Maine Ave	21207	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Left Plumber a notice	Turn over to CCTV	151834
65	1/23/2013	847 W. 35th St	21211	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151867
66	1/23/2013	2013 W. Rogers Ave	21209	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151907
67	1/23/2013	2601 Oswego Ave	21215	Rags	DWO	Gwynns Falls	Overflow not Witnessed	Overflow not Witnessed	Paper Debris & Ice	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	151910
68	1/23/2013	3702 Park Heights Ave	21215	Rags & Debris	DWO	Gwynns Falls	Overflow not Witnessed	Overflow not Witnessed	Paper Debris & Ice	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	151925
69	1/23/2013	5314 Wendley Rd	21229	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151932
70	1/23/2013	6600 Moravia Rd	21237	Rags & Debris	DWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Paper Debris & Ice	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	151922
71	1/24/2013	108 St. Johns Rd	21210	Rags	WVO	None	Overflow not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	152057
72	1/24/2013	5006 Litchfield Ave	21215	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris & Ice	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	152087
73	1/25/2013	408 E. 31st St	21218	Rags & Grease	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	152153
74	1/28/2013	1300 Franklinton Rd	21216	Rags, Roots & Grease	WVO	Gwynns Falls	1:00	2:00PM - 3:00PM	Heavy Gray Water	120	Pressure Jet relieved Mainline choke	Turn over to CCTV	152783
75	1/28/2013	3840 Elm Ave	21211	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	152852
76	1/31/2013	1104 E. 20th St	21218	N/A	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	152947
77	1/31/2013	2300 Frederick Ave	21228	Rags & Grease	WVO	Gwynns Falls	5:53	3:07AM - 9:00AM	Heavy Gray Water	1,765	Pressure Jet relieved Mainline choke	Turn over to CCTV	152903
78	1/31/2013	4505 Wilmslow Rd	21210	Rags, Roots & Grease	WVO	Jones Falls	0:25	11:58PM - 12:23PM	Heavy Gray Water	250	Pressure Jet relieved Mainline choke	Turn over to CCTV	152909
79	1/31/2013	4800 Falls Rd	21209	Rags, Roots & Grease	WVO	Jones Falls	1:23	1:37PM - 3:00PM	Heavy Gray Water	415	Pressure Jet relieved Mainline choke	Turn over to CCTV	152919
80	1/31/2013	5400 Belair Rd	21206	Pipe Break	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Light Paper around Cleanout	Evidence of Overflow	Turn over to HCD	N/A	152921
				# WVO	35				TOTAL	38,293	EVIDENCE ONLY	46	