

## SSO Notification List

July 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	7/1/2013	110 W University Pkwy	21218	Pipe Break, Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved M/L Choke with Press Truck 100ft of 8"inch San ML	N/A	162127
2	7/1/2013	1750 E Madison St	21205	Rags, Grease, Heavy Rain	WVO	Inner Harbor	1:00	12:00PM - 1:00PM	Clear Water	60	Used Press Jet to Relieve Mainline	UAMD Investigate	162129
3	7/1/2013	22 Horseradish Ln	21202	Rags, Grease	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain Cleaning Machine Relieved the H/C Choke	Turned Over to UAMD	162153
4	7/2/2013	1242 N Broadway	21213	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain Cleaning Machine Relieved Choke	UAMD	162213
5	7/4/2013	1006 Mosher St	21217	Other: Hardspot	WVO	Gwynns Falls	Not Witnessed	Overflow not Witnessed	Paper Debris, Sewer Water	Evidence of Overflow	Drain Cleaning Machine could not Relieve Choke	Turned Over to UAMD	162284
6	7/4/2013	1312 W 40th St	21211	Rags, Grease	WVO	Jones Falls	Not Witnessed	Overflow not Witnessed	Paper Debris, Grease & Rags	Evidence of Overflow	Drain Cleaning Machine Relieved the H/C Choke	Turned Over to UAMD	162282
7	7/5/2013	2559 W Fairmount Ave	21223	Rags, Grease	DWO	N/A	1:30	9:30AM - 11:00AM	Water, Gray Around Cleanout	67.5	Used Elec Mach to relieve Conn	CCTV Clean	162301
8	7/5/2013	4022 Pulaski Hwy	21224	Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Pressure Relieved ML Choke	T/O UAMD Investigate and CCTV	162306
9	7/5/2013	5013 Greenhill Ave	21206	Pipe Break	DWO	Herring Run	22:15	7/5/13 12:15PM - 7/6/13 10:30AM	Gray Water	2670	Used 45ft electric machine cable	UAMD Investigate	162330
10	7/6/2013	4022 Pulaski Hwy	21224	Rags, Roots	DWO	Patapsco	1:31	10:39AM - 12:10PM	Gray Water was coming out of Cleanout	182	Used Pressure Truck and Electric Machine	UAMD Investigate	162351
11	7/8/2013	119 Overhill Rd	21210	Rags, Roots	WVO	Jones Falls	18:21	7/8/13 4:39PM - 7/9/13 11:00AM	Heavy Gray Water	3303	Relieved M/L Choke with Press Truck 100 ft of 6 inch	T/O for CCTV	162433
12	7/8/2013	2537 Brookfield Ave	21217	Rags	WVO	Jones Falls	2:21	8:09PM - 10:30PM	Sewer Water	1410	Pressure Jet Relieved M/L Choke	Turned Over to UAMD	162442
13	7/9/2013	3101 Pulaski Hwy	21224	Grease	WVO	Herring Run	12:35	7/9/13 10:25PM - 7/10/13 11:00AM	Gray Water	2265	Used Pressure to Relieve turn over for repairs	Turn Over for UAMD to investigate	162506
14	7/10/2013	2535 Brookfield Ave	21217	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieve with Rods and Speeds Main Line Choke	N/A	162533
15	7/10/2013	Federal St and Orville Rd	21205	Heavy Rain Other Interceptor	WVO	Herring Run	68:30	7/10/13 6:00AM - 7/13/13 2:30PM	Gray Water	8220	Used Pressure Truck Waiting for Rain to slow down	Turn Over to UAMD to investigate	162548
16	7/13/2013	2315 Belair Rd	21213	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Wet, Paper around Clean-Out	Evidence of Overflow	Used Elec Mach to Relieve Conn	CCTV, Clear, Press Mach	162654
17	7/14/2013	4705 Kernwood Ave	21212	Rags, Other Toilet Paper	DWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet Paper/Rags	Evidence of Overflow	Used Electric Machine	Turned Over for UAMD to Investigate	162703
18	7/14/2013	5209 Eugene Ave	21206	Pipe Break, Vandalism	DWO	Herring Run	1:00	1:37PM - 2:37PM	Heavy Gray Water	60	Relieved M/L Choke with Press Truck	T/O for CCTV Construction	162691
19	7/15/2013	219 E North Ave	21202	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet around Clean Out	Evidence of Overflow	Used Elec Mach to Relieve Conn	CCTV Left Plumbers Notice	162756
20	7/17/2013	3320 Sinclair Ln	21213	Grease	DWO	Herring Run	1:26	9:14AM - 10:40AM	Gray Water and Rags	172	Used Electric Machine Cable	UAMD Investigate	162814
21	7/17/2013	414 S Lehigh St	21224	Other Cleanout Cap	DWO	Baltimore Harbor	Not Witnessed	overflow not Witnessed	Paper Debris	Evidence of Overflow	Left a Plumber's notice to remove cleanout cap	N/A	162838
22	7/17/2013	4222 Falls St	21211	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Turned Over for Main to Property	N/A	162880
23	7/18/2013	Powder Mill Ln & Wayne Ave	21207	Rags, Pipe Break, Roots, Grease	WVO	Gwynns Falls	5:39	9:21AM - 3:00PM	Heavy Gray Water	1695	Relieved ML Choke with Press Truck 100ft of 8 inch San ML		162879
24	7/19/2013	1006 Billie Holiday Ct	21205	Rags, Grease	WVO	Jones Falls	4:51	5:24PM - 10:15PM	Gray Water Grease	582	Used Electric Machine	Turned Over to UAMD	162926
25	7/22/2013	35 N Ellwood Ave	21224	Trash	WVO	N/A	Not Witnessed	overflow not Witnessed	Paper	Evidence of Overflow	Relieved with Electric Machine	UAMD Investigate/ CCTV	162972
26	7/23/2013	324 E Belvedere Ave	21212	Roots	WVO	Herring Run	1:16	6:58PM - 8:14PM	Heavy Gray Water	76	Relieved House Conn Choke with Elec Mach 30ft of 6inch CCTV	N/A	163030
27	7/24/2013	1805 N Chapel St	21213	Rags, Trash	DWO	N/A	1:00	7:00PM - 8:00PM	Wet, Water Near Clean Out	30	Used Elec Mach to Relieve Conn	CCTV	163077
28	7/24/2013	2325 Hollins St	21223	Rags, Grease	DWO	N/A	1:00	4:00PM - 5:00PM	Clear Water, Waste, Paper	30	Used Elec Mach to Relieve Conn	CCTV	163072
29	7/24/2013	30 Merrymount Rd	21210	Other: Debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved ML Choke with Press Truck 150ft of 6" Inch San M/L	N/A	163044
30	7/24/2013	3800 E Baltimore St	21205	Rags, Grease	DWO	N/A	1:00	1:30PM - 2:30PM	Gray Colored Water	60	Used Pressure Jet	UA MD Investigate	163049
31	7/27/2013	2223 Gable Ave	21230	Pipe Break, Sand, Gravel, Rocks	WVO	Baltimore Harbor	2:50	2:54PM - 5:44PM	Sewer Water	340	Pressure Jet Relieved M/L Choke	Turn Over to UAMD	163166
32	7/27/2013	28 E Ostend St	21230	Rags, Grease	WVO	N/A	1:00	3:00PM - 4:00PM	Gray Colored Water	60	Used Press Machine to Relieve Mainline	Will CCTV Mainline	163165
33	7/29/2013	401 E Madison St	21202	Rags, Grease	DWO	Jones Falls	0:26	2:13PM - 2:39PM	Gray Water Grease	78	Used Pressure Truck to Relieve 50ft	Turn Over for UAMD to Investigate	163231
34	7/30/2013	1700 Coldspring Ln	21218	Rags	DWO	Herring Run	0:42	7:18PM - 8:00PM	Gray Water	84	Pressure Jet, Relieve Mainline choke	UAMD	163298
35	7/30/2013	219 E North Ave	21202	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray Water	Evidence of Overflow	Run Electric Machine	UAMD	163305
36	7/31/2013	2724 Bookert Dr	21225	Rags, Grease	DWO	N/A	2:00	6:04PM - 8:04PM	Gray Water, Grease, Rags	240	Used Electric Machine	Will Turn Over for UAMD to Investigate	163338
37	7/31/2013	4000 Linkwood Rd	21210	Roots, Vandalism	DWO	N/A	4:00	10:00AM - 2:00PM	Heavy Gray Water	720	Relieved ML Choke with Press Truck 200ft of San ML	N/A	163328
38	7/31/2013	4714 Greenspring Ave	21209	Rags, Grease	DWO	N/A	6:00	2:41PM - 8:41PM	Grease and Rags	1440	Used Electric Machine	Will Turn Over for UAMD to Investigate	163334
				# WVO	18				TOTAL	23,845	EVIDENCE ONLY	15	