

SSO Notification List

July 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	7/2/2014	6207 Blackburn Ln	21212	Rags, Roots	WWO	N/A	Not Witnessed	Overflow not Witnessed	Wet around clean out, paper	Evidence of Overflow	Used elec. mach.	UAMD	199723
2	7/3/2014	3332 W Belvedere Ave	21215	Roots	WWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 30ft of tv	N/A	199780
3	7/3/2014	1148 Steelton Ave	21224	Grease, Paper	WWO	Baltimore Harbor	3:00	11:44 AM - 2:44 PM	Sewer Water	2700	Pressure jet relieved m/l choke	UAMD	199806
4	7/4/2014	1200 Evesham Ave	21239	Roots	WWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Used sewer jet	UAMD	199930
5	7/7/2014	3329 Brighton St	21216	Roots	DWO	Patapsco	2:32	12:28 PM - 3:00 PM	Heavy gray water	304	Relieved house conn choke press truck 60ft & CCTV 10.0ft	N/A	200126
6	7/7/2014	1824 McCulloh St	21217	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper around clean out	Evidence of Overflow	Used elec. machine	UAMD	200161
7	7/7/2014	2400 Wilgrey Ct	21230	Rags, Debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Pressure jet relieved m/l choke	UAMD	200213
8	7/7/2014	3101 Pulaski Hwy	21224	Roots, Debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved h/c choke	UAMD	200061
9	7/9/2014	3004 Frisby St	21218	Wood, Steel bar	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Left a plumbers notice	UAMD	200349
10	7/9/2014	307 E 22nd St	21218	Unknown	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Left a plumbers notice	N/A	200385
11	7/10/2014	3442 Roland Ave	21211	Debris	DWO	N/A	2:29	1:31 PM - 4:00 PM	Heavy gray water	745	Relieved m/l choke with press truck 50ft of 10' san m/l	N/A	200559
12	7/12/2014	3112 Brentwood Ave	21218	Rags, Grease	DWO	Hearing Run	2:00	8:53 PM - 10:53 PM	Gray water	240	Press truck rel 30ft pressure hose	UAMD CCTV Main Line	200794
13	7/12/2014	3608 Duvall Ave	21216	Debris	DWO	Gwynns Falls	Not Witnessed	Overflow not Witnessed	Sewer water around m/h lid	Evidence of Overflow	Pressure jet relieved m/l choke	UAMD	200791
14	7/13/2014	2100 Washington Blvd	21230	Pipe Break	WWO	Gwynns Falls	358:42	07/13/2014 7:48 PM - 07/28/2014 6:30 PM	Sewer Water	43044	Overpumping operation started	UAMD	N/A
15	7/14/2014	1700 Ridgely St	21230	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	House conn choke	By pass pumping	200849
16	7/14/2014	1006 Billie Holiday Ct	21205	Rags, Grease	WWO	N/A	1:26	9:32 AM - 10:58 AM	Gray water	86	Run elec machine 30ft relieve	UAMD	200845
17	7/16/2014	307 E 22nd St	21218	Unknown	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Left a plumbers notice	N/A	201092
18	7/16/2014	1218 Bayard St	21230	Cap in c/o	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved h/c choke	Left plumbers notice cap in cleanout	201124
19	7/16/2014	5200 Beaufort Ave	21215	Unknown	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Left a plumbers notice to locate or install c/o	Cleanout inaccessible	201214
20	7/19/2014	1945 W Lafayette Ave	21217	Trash	DWO	N/A	Not Witnessed	Overflow not Witnessed	Trash can leaking garbage	Evidence of Overflow	Ran Elec-Machine	UAMD	201549
21	7/20/2014	1313 S Clinton St	21224	Debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Pressure jet cleaned the sanitary m/l	N/A	201576
22	7/20/2014	4212 LaSalle Ave	21206	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved h/c choke	UAMD	201583
23	7/21/2014	100 Block W 29th St	21218	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	BGE pole flush; wasted	Down Alley	201712
24	7/21/2014	2431 Arunah Ave	21216	Rags, Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Used Elec. Mach.	UAMD - CCTV	201728
25	7/21/2014	2709 Round Rd	21225	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 45ft of 6in bottom	N/A	201708
26	7/21/2014	3324 Lyndale Ave	21213	Other, cleanout cap at bottom cleanout	DWO	N/A	Not Witnessed	Overflow not Witnessed	small amount of paper around cleanout	Evidence of Overflow	cleaned line with elec mach	UAMD	201685
27	7/21/2014	2999 Belair Rd	21213	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved h/c choke	UAMD	201737
28	7/22/2014	3200 Reisterstown Rd	21215	Grease, Debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	relieved m/l choke with press truck 200ft of 8" san m/l t/o for CCTV	N/A	201871
29	7/23/2014	5403 O'Donnell St	21224	Rags, Grease, Trash, Plastic	WWO	Back River	1:15	10:15 AM - 11:30 AM	Heavy rags, plastic, trash, grease	375	jetted line with pressure truck	UAMD	201969
30	7/24/2014	Greenspring Ave & Park Hill Ave	21211	Rags, Grease	DWO	Jones Falls	0:30	9:30 PM - 10:00 PM	Gray colored water	30	used press machine	UAMD	202279
31	7/24/2014	520 Denison St	21229	Rags, Grease, Debris	DWO	N/A	1:01	2:31 PM - 3:30 PM	Gray water	61	Pressure truck rel. 100ft pressure hose	UAMD	202216
32	7/25/2014	2716 Rittenhouse Ave	21230	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet around cleanout	Evidence of Overflow	Used elec machine	UAMD	202394
33	7/26/2014	604 Venable Ave	21218	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 30ft CCTV 7.1 bottom	N/A	202449
34	7/26/2014	1307 Bayard St	21203	Roots, Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Small amount of paper	Evidence of Overflow	Cleaned line with elec mach	UAMD	202436
35	7/27/2014	4705 Kernwood Ave	21212	Roots, Grease	DWO	N/A	1:00	9:15 AM - 10:15 AM	Clear water around cleanout	120	Cleaned house connection with elec mach	UAMD	202465
36	7/28/2014	1220 Bayard St	21230	Rags	DWO	N/A	1:05	12:55 PM - 2:00 PM	Heavy gray water	65	Relieved house conn choke with elec mach 30ft of 8in CCTV	N/A	202574

SSO Notification List

July 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
37	7/28/2014	3635 Cottage Ave	21215	Rags, Roots, Grease	DWO	Jones Falls	2:11	8:49 AM - 1:00 PM	Heavy gray water	131	Relieved m/l choke with press truck 250ft of 8inch T/O for CCTV and sewer	N/A	202525
38	7/28/2014	3700 Greenspring Ave	21215	Rags, Pipe Break, Sand, Gravel, Rocks	DWO	Patapsco	1:20	7:40 AM - 9:00 AM	Heavy gray water	400	Relieved m/l choke with press truck 200ft of 8inch T/O for CCTV	N/A	202517
39	7/28/2014	4307 Pimlico Rd	21215	Rags, Grease	DWO	Gwynns Falls	1:00	2:10 PM - 3:10 PM	Heavy gray water	60	Relieved m/l choke with press truck 150ft of 8 inch san m/l T/O for CCTV	N/A	202610
40	7/29/2014	5319 Brabant Rd	21229	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 30ft CCTV 4ft bottom 23ft main	N/A	202740
41	7/29/2014	421 Westgate Rd	21229	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper around ground	Evidence of Overflow	Used elec mach	UAMD	202805
42	7/29/2014	1800 Park Ave	21217	Rags, Grease	DWO	Jones Falls	0:30	5:00 PM - 5:30 PM	Gray colored water	30	Used press. mach.	UAMD - CCTV	202776
43	7/29/2014	3800 E Baltimore St	21202	Grease, Trash	DWO	N/A	Not Witnessed	Overflow not Witnessed	Heavy grease and dough	Evidence of Overflow	Jetted line with a vac con truck	UAMD	202696
44	7/29/2014	Sumter Ave and Pimlico Rd	21215	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Water at the eyes of manhole	Evidence of Overflow	Used press. machine	UAMD	202802
45	7/29/2014	4109 Belvieu Ave	21215	Rags, Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around cleanout	Evidence of Overflow	Used elec. machine	UAMD	202773
46	7/29/2014	1147 Monroe Cir	21225	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved h/c choke	UAMD	21225
47	7/30/2014	3337 Winterbourne Rd	21216	Rags, Grease	DWO	Gwynns Falls	1:56	10:04 AM - 12:00 PM	Heavy gray water	580	Relieved m/l choke with press truck 200ft of 6" san m/l T/O for CCTV	N/A	202868
48	7/30/2014	3117 Baker St	21216	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with press truck 35ft; CCTV 60ft	N/A	202886
49	7/30/2014	1225 N Broadway	21213	Mud	DWO	N/A	Not Witnessed	Overflow not Witnessed	Water, paper around cleanout	Evidence of Overflow	Used elec. mach.	UAMD	202956
50	7/31/2014	3915 N Charles St	21218	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 45ft of 6inch CCTV	N/A	203073
51	7/31/2014	Greenspring Ave and Park Hill Ave	21211	Rags, Grease, Sand, Gravel, Rocks	DWO	Jones Falls	2:56	10:04 AM - 1:00 PM	Heavy gray water	880	Relieved m/l choke with press truck 75ft of 8inch T/O for CCTV	N/A	203019
				# WWO	8				TOTAL	49851	EVIDENCE ONLY	34	