

## SSO Notification List

March 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	3/1/2014	2845 W North Ave	21216	Rags, trash	DWO	N/A	Not Witnessed	Overflow not Witnessed	Clear colored water	Evidence of Overflow	Cleaned line with Elec. Mach.	UAMD	186805
2	3/1/2014	2900 Norfolk Ave	21215	Grease, trash	DWO	Gwynns Falls	2:05	6:40 - 8:40 PM	Gray colored water	375	Jetted line with pressure truck	UAMD	186791
3	3/1/2014	3100 Tioga Pkwy	21215	Rags, trash	DWO	Gwynns Falls	Not Witnessed	Overflow not Witnessed	Gray colored water	Evidence of Overflow	Jetted line with pressure truck	UAMD	186784
4	3/2/2014	2931 Windsor Ave	21216	Debris	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Ran 30ft. Elec. Machine cable	UAMD	186820
5	3/2/2014	3601 Pinkney Rd	21215	Rags, roots, trash	WVO	N/A	0:45	7:00 - 7:45 PM	Clear colored water	45	Cleaned line with Elec. Mach.	UAMD	186840
6	3/2/2014	5000 Sunny Ln	21210	Roots, grease	WVO	Jones Falls	6:25	4:15 - 10:30 PM	Gray and Brown colored water	1125	Jetted line with pressure truck	UAMD	186829
7	3/3/2014	5906 Edna Ave	21214	Rags, Grease	WVO	N/A	3:00	4:30 - 7:30 PM	Gray colored water	90	Used Elec. Mach.	UAMD-CCTV	187712
8	3/4/2014	5315 Wendley Rd	21229	Rags, grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Used Elec. Mach.	UAMD	188443
9	3/5/2014	1317 Lemmon St	21223	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Pressure truck wash down debris from yard, no overflow	N/A	188477
10	3/5/2014	4530 Fairfax Rd	21216	Roots, debris	DWO	Palapasco	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with Elec mach 75ft of 6in, CCTV 7.5ft bottom	N/A	188484
11	3/5/2014	2001 E 30th St	21218	Rags, infiltration, debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved h/c choke	UAMD	188461
12	3/6/2014	5800 Bowleys Ln	21206	Grease	DWO	N/A	0:60	10:13 - 11:13 AM	Sewer water	600	Pressure jet relieved m/l choke	UAMD	188528
13	3/6/2014	125 N Ann St	21231	Rags, grease trash	DWO	Inner harbor	1:45	1:00 - 2:45 PM	Gray colored water	315	Jetted line with vac conn	UAMD	188555
14	3/6/2014	4215 Audrey Ave	21225	Rags, roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water paper	Evidence of Overflow	Rel. house connection choke 60ft. Elec-machine	UAMD	188530
15	3/6/2014	408 W 28th St	21211	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper gray water	Evidence of Overflow	Plumber notice, locate or install proper clean out	Need private plumber	188540
16	3/6/2014	E 33rd & Guilford Ave	21218	Rags, grease	DWO	N/A	0:30	6:00 - 6:30 PM	Gray colored water	15	Used sewer jet	UAMD	188569
17	3/7/2014	4309 Erdman Ave	21213	N/A	DWO	N/A	6:00	6:20 PM - 12:20 AM	Clear water and paper	360	Bypass pump	UAMD	188636
18	3/8/2014	5621 Belair Rd	21706	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	N/A	Plumber notice could not pass 2ft	188679
19	3/8/2014	3106 Hamilton Ave	21214	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn. choke, 30ft of Elec. Mach. TV 80, 10.4 & flush, clean 300ft of 8in san M/L	UAMD	188642
20	3/8/2014	Dupont Ave & Greenspring Ave	21209	Rags	DWO	Jones Falls	2:41	12:19 - 3:00 PM	Heavy gray water	322	Relieved house conn. choke with elec mach 75ft of 6in TV 3.6 bottom 46.8	N/A	188656
21	3/8/2014	1402 Patapasco St	21230	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 15ft of 6 in TV 24ft bottom, 12.9ft	N/A	188660
22	3/8/2014	1013 Darley Ave	21218	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn. choke with elec mach 30ft TV 5.4ft bottom 14ft	N/A	188661
23	3/10/2014	1520 E Biddle St	21213	Paper	DWO	N/A	Not Witnessed	Overflow not Witnessed	Small amount of paper	Evidence of Overflow	Clean line with electric machine	UAMD-CCTV	188716
24	3/10/2014	2905 Whitney Ave	21215	Rags, roots	DWO	N/A	1:30	1:52 PM - 3:22 PM	Paper, debris	90	Ran 30ft elec. mach.	UAMD	188749
25	3/10/2014	4510 Penhurst Ave	21215	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper around cleanout	Evidence of Overflow	Used Elec. Mach.	UAMD	188766
26	3/11/2014	434 S Hanover St	21201	Rags, grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around clean out	Evidence of Overflow	Used elec-mach	UAMD	188835
27	3/11/2014	508 S Hanover St	21201	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper on ground	Evidence of Overflow	Used elec-mach	UAMD	188838
28	3/11/2014	931 Wilmington Ave	21223	Rags, grease	DWO	Middle branch	2:00	1:52 - 3:22 PM	Gray colored water	600	Used sewer jet	UAMD	188822
29	3/11/2014	3424 Elmley Ave	21213	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around clean out	Evidence of Overflow	Used elec-mach	UAMD	188816
30	3/13/2014	1438 Cedarcroft Rd	21239	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris, feces	Evidence of Overflow	Drain cleaning machine relieved h/c choke	UAMD	188926
31	3/13/2014	Harper Way & Wright Ave	21205	Rags, grease, trash	DWO	Herring Run	2:05	12:25 - 2:30 PM	Small amounts of paper	625	Jetted line with vac con.	UAMD	188928
32	3/13/2014	2811 Druid Park Dr.	21215	Rags, grease	DWO	N/A	0:30	6:00 - 6:30 PM	Water, paper-wet on ground	30	Used sewer jet	UAMD	188943

## SSO Notification List

March 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
33	3/14/2014	2922 Norfolk Ave	21215	Rags, grease	DWO	Gwynns Falls	2:11	11:58 AM - 2:09 PM	Gray water	131	Pressure truck relieved M/L choke 180ft. pressure hose	UAMD	188979
34	3/14/2014	315 Overhill Rd	21210	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water paper	Evidence of Overflow	Red. Elec.-Machine 60ft. Elec Mac. cables	UAMD	188846
35	3/15/2014	926 N Montford Ave	21205	Pipe break	DWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper	Evidence of Overflow	Ran 45ft Elec. Mach. cable practical rel.	UAMD	189044
36	3/15/2014	3416 Garrison Blvd	21215	Rags, debris	DWO	Gwynns Falls	0:10	5:14 - 5:24 PM	Toilet paper	10	Ran 45ft Elec. Machine cable	UAMD	189046
37	3/15/2014	2557 Marbourne Ave	21230	Pipe break, debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper gray water	Evidence of Overflow	Rel. 10ft Elec. Machine cable could not pass further inves.	UAMD	189031
38	3/15/2014	625 E 34th St	21218	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Clean out water rear side of house, refer for private plumber	Evidence of Overflow	N/A	Plumber notice locate or install closer to city M/L	189037
39	3/17/2014	645 E Pontiac Ave	21225	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with Elec. Mach. 30ft bottom 6ft main 10.7ft	N/A	189942
40	3/19/2014	3304 W North Ave	21216	Roots	WWO	Gwynns Falls	3:20	3:10 - 6:30 PM	Wet paper on ground around clean-out	110	Used Elec-machine	UAMD	190297
41	3/19/2014	332 S Pulaski St	21223	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper debris	Evidence of Overflow	Could not run Elec-machine due to occupant has rear	UAMD	190284
42	3/19/2014	5301 Fernpark Ave	21207	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper	Evidence of Overflow	Plumber notice make foundation safe to work from	UAMD CCTV Mainline	190239
43	3/19/2014	2505 Brookfield Ave	21217	Pipe break	WWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper debris	Evidence of Overflow	Ran 6ft Elec-Machine cable, brought back mud	UAMD	190273
44	3/19/2014	3024 Gwynns Falls	21216	Rags, grease	WWO	Gwynns Falls	4:00	8:30 PM - 12:30 AM	Gray colored water, paper	240	Used sewer jet	UAMD	190323
45	3/20/2014	3560 Dudley Ave	21213	Roots, grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Small amount of paper near cleanout	Evidence of Overflow	Cleaned line with Elec. Mach.	UAMD	190341
46	3/20/2014	3012 White Ave	21214	Roots, trash	DWO	N/A	Not Witnessed	Overflow not Witnessed	Small amount of paper near cleanout	Evidence of Overflow	Cleaned line with Elec. Mach.	UAMD	190331
47	3/20/2014	2840 Sisson St	21211	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Water on ground around clean-out	Evidence of Overflow	Used Elec-machine	UAMD	190389
48	3/21/2014	1040 N Bentalou	21216	Pipe break	WWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper	Evidence of Overflow	Ran 9ft. Elec. Machine, brought back mud	UAMD CCTV Mainline	190421
49	3/22/2014	4217 Audrey Ave	21225	Roots, grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Small amount of paper near cleanout	Evidence of Overflow	Cleaned line with Elec. Mach.	UAMD	190479
50	3/23/2014	1810 Harman Ave	21230	Rags, debris	WWO	Patapsco	1:53	8:04 - 9:57 PM	Heavy gray water	229	Relieved M/L choke with pressure truck, 150ft of 8in san M/L	N/A	190553
51	3/23/2014	3024 Gwynns Falls Pkwy	21216	Roots, grease	WWO	N/A	1:49	10:24 AM - 12:13 PM	Grease, paper, & debris	1635	Pressure jet relieved the M/L choke	UAMD	190512
52	3/23/2014	2734 W North Ave	21216	Rags, roots	WWO	Patapsco	120	5:01 - 7:01 PM	Heavy gray water	600	Relieved M/L choke with pressure truck, 200ft. of 8in T/O for CCTV	N/A	190522
53	3/23/2014	2102 Homewood Ave	21218	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with Elec mach 45ft of 6in CCTV	N/A	190539
54	3/23/2014	3403 Parkside Dr	21214	Rags, grease	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Pressure jet relieved h/c choke	UAMD	190515
55	3/24/2014	1800 Etting St	21217	Grease	DWO	Gwynns Falls	4:47	10:13 AM - 3:00 PM	Heavy gray water	861	Relieved M/L choke with pressure truck 250ft of 16 in san M/L, T/O for CCTV	N/A	190578
56	3/24/2014	1302 Chesapeake Ave	21226	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with Elec mach 105ft of 6in T/O for CCTV	N/A	190583
57	3/24/2014	4545 N Charles St	21210	Roots	DWO	N/A	4:01	11:04 AM - 3:05 PM	Paper & debris	482	Pressure machine rel. 200ft pressure machine hose	UAMD CCTV Mainline	190561
58	3/24/2014	9 N Wheeler Ave	21215	Rags, roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper on ground around clean out	Evidence of Overflow	Used elec. mach. and sewer jet to wash area	UAMD	190590
59	3/24/2014	332 S Pulaski St	21223	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper & debris	Evidence of Overflow	Run elec. machine rel 30ft elec. machine cable	UAMD	190597

**SSO Notification List**

**March 2014**

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
60	3/25/2014	2819 Overland Ave	21214	N/A	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Relieved with electric machine	UAMD	190631
61	3/26/2014	6200 The Alameda	21239	Rags, grease	DWO	N/A	1:49	9:41 - 11:30 AM	Sewer water	545	Pressure jet relieved the m/i choke	UAMD	190667
62	3/27/2014	2324 W Fayette St	21223	Pipe break	DWO	N/A	1:27	10:28 AM - 11:55 AM	Debris	87	Ran 3ft Elec. machine cable rel. plumber noticed pipe shifted	UAMD could not TV due to shift pipe	190744
63	3/27/2014	2616 Talbot Rd	21216	Rags, roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Pressure truck relieved house conn choke 15ft CCTV 12.1ft	N/A	190703
64	3/27/2014	3020 Liberty Heights Ave	21215	Pipe break, rocks	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Ran Elec.-Machine 83ft not rel. turn over bypass pumping	UAMD	190748
65	3/28/2014	1945 W Lafayette Ave	21217	Grease	WWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water and debris	Evidence of Overflow	Rel. with 30ft Elec. Mach.	UAMD	190786
66	3/29/2014	1410 Darley Ave	21218	Rags, muck	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper and debris	Evidence of Overflow	Ran 45ft Elec. Machine cable	UAMD	190850
67	3/30/2014	Fenwick Ave & Pentwood Rd	21218	Paper, grease	WWO	N/A	Not Witnessed	Overflow not Witnessed	Paper, grease	Evidence of Overflow	Relieved with pressure truck	UAMD	190897
68	3/31/2014	4252 Shamrock Ave	21206	N/A	DWO	N/A	0:50	7:00 - 8:00 PM	Paper	120	Relieve with electric machine	UAMD	190976
				# WWO	20				TOTAL	9642	EVIDENCE ONLY	43	