

SSO Notification List

May 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	5/1/2014	8 Mount Olivet Ln	21229	Rags, grease	WVO	N/A	Not Witnessed	Overflow not Witnessed	Sidewalk wet	Evidence of Overflow	Used sewer jet	UAMD	193489
2	5/1/2014	2525 Insulator Dr	21230	Rags, Grease	WVO	N/A	3:02	12:13 PM - 3:15 PM	Debris	364	Rel with 30ft hand tools 2" pipe sanitary	UAMD	193442
3	5/1/2014	2859 W Lanvale St	21228	Grease	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved M/L choke with pressure truck 200ft of 8in T/O for CCTV	N/A	193458
4	5/1/2014	3008 Wilkens Ave	21223	N/A	WVO	Palapasco	26:39	05/01/14 3:21 PM - 05/02/14 6:00PM	Heavy gray water	39,975	used 30in bulkhead off 24in san M/L	N/A	193470
5	5/1/2014	6115 Ridgeview Ave	21206	Rags, roots, grease	WVO	N/A	30:26	05/01/14 2:04 PM - 05/02/14 8:30 PM	Gray water	9,130	Pressure truck flush and clean mainline 400ft	UAMD CCTV Mainline	193461
6	5/2/2014	1510 E 29th St	21218	Rags, grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet grass	Evidence of Overflow	Used Elec. Mach.	UAMD	193580
7	5/2/2014	1703 Bloomingdale Rd	21216	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke 6ft of 6in CCTV	N/A	193540
8	5/2/2014	2909 Whitney Ave	21215	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke 45ft of 6inch CCTV 24ft bottom 16ft to main	N/A	193554
9	5/2/2014	Springlake Way & St. Dunstons Rd	21212	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	N/A	N/A	193545
10	5/2/2014	2 W University Pkwy	21218	Rags, heavy rain	DWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water	Evidence of Overflow	Wait for rain event to stop	N/A	193559
11	5/3/2014	7118 Park Heights Ave	21215	Roots, grease	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Relieved with Electric machine	UAMD	193628
12	5/5/2014	104 S Durham St	21231	Pipe break	WVO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water	Evidence of Overflow	Turned over to construction for repairs	UAMD	193727
13	5/5/2014	1409 Battery Ave	21230	Infiltration/Inflow	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Left notice to remove debris from cleanout	N/A	193798
14	5/6/2014	5801 Clover Rd	21215	Rags, roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper wet - around clean out	Evidence of Overflow	Used elec mach	UAMD	193932
15	5/7/2014	2346 E Fayette St	21224	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	Wet around clean out	Evidence of Overflow	Used elec mach	UAMD	194043
16	5/7/2014	3601 Pinkney Ave	21215	Pipe break, sand, gravel, rocks	WVO	N/A	Not Witnessed	Overflow not Witnessed	Debris	Evidence of Overflow	Ran 20ft Elec machine cable brought back mud, plumber notice	UAMD	194020
17	5/8/2014	3901 Belair Rd	21206	Rags, roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	M/H cover off	Evidence of Overflow	Pressure jet relieved M/L choke	UAMD	194124
18	5/9/2014	Braddish Ave & Edmondson Ave	21223	Rags, grease	WVO	N/A	1:00	8:01 AM - 9:01 AM	Heavy gray water	300	Relieved M/L choke with pressure truck 100ft of 8inch san M/L T/O for CCTV	N/A	194219
19	5/10/2014	3747 Nortonia Rd	21216	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	Wet around clean out	Evidence of Overflow	Used elec mach	UAMD	194322
20	5/11/2014	1512 E 29th St	21218	N/A	DWO	N/A	1:08	5:52 PM - 7:00PM	Heavy gray water ground	68	Sewer leak in the street T/O for construction house conn break bypass pumping	N/A	194358
21	5/12/2014	2608 Maryland Ave	21218	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	Wet ground paper	Evidence of Overflow	Used elec mach	UAMD	194465
22	5/12/2014	5502 O'Donnell St	21224	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Relieved with pressure truck	UAMD CCTV	194386
23	5/12/2014	706 N Monroe St	21217	Rags, pipe break, grease, debris	WVO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Pressure truck relieved M/L choke	UAMD CCTV Mainline	194444
24	5/12/2014	2608 Manhattan Ave	21215	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around clean out	Evidence of Overflow	Used elec mach	UAMD	194477
25	5/13/2014	1412 Ward St	21230	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper	Evidence of Overflow	Ran Elec Machine	UAMD	194514
26	5/13/2014	6700 Pulaski Hwy	21205	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper and waste around clean-out	Evidence of Overflow	Used elec mach	UAMD	194541
27	5/14/2014	4511 Schenley Rd	21210	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper on ground around clean out	Evidence of Overflow	Used elec mach	UAMD	194711
28	5/15/2014	316 N Paca St	21201	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	N/A	N/A	194809
29	5/15/2014	1000 Haverhill Rd	21229	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with elec mach 30ft CCTV 12ft bottom 20ft to main	N/A	194762
30	5/15/2014	2005 E 30th St	21218	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Paper debris	UAMD	194748
31	5/16/2014	3700 Greenspring Ave	21215	Rags, sand gravel, rocks	WVO	N/A	3:00	4:00 PM - 7:00 PM	Water running down sidewalk and street	900	Used sewer jet	UAMD	194912
32	5/17/2014	W Mullberry St & N Pulaski St	21223	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Heavy gray	Evidence of Overflow	Relieved with pressure truck	UAMD CCTV	194972
33	5/18/2014	5423 O'Donnell St	21224	Rags, debris	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water	Evidence of Overflow	Pressure truck flush main-line 200ft pressure hose	CCTV Mainline	195012
34	5/19/2014	1424 W Mount Royal Ave	21217	Roots	DWO	Jones Falls	13:16	05/19/14 9:04 PM - 05/20/14 10:20 AM	N/A	796	Relieved house conn choke with elec. mach. 60ft of 6in 10ft bottom 38ft to main & 495ft of 8in san M/L	N/A	195190
35	5/20/2014	444 E Fort Ave	21230	Shift pipe	DWO	N/A	Not Witnessed	Overflow not Witnessed	Toilet paper	Evidence of Overflow	Ran elec machine	UAMD	195209

SSO Notification List

May 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
36	5/20/2014	6830 Overall Ave	21206	Rags, roots, debris	DWO	N/A	3:01	1:04 PM - 4:05 PM	Gray water	181	Pressure truck flush main line	UAMD	195228
37	5/22/2014	4 N Wheeler Ave	21223	Grease	WWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved M/L choke with pressure truck 150ft of 8inch T/O for CCTV	N/A	195431
38	5/22/2014	3826 W Bay Ave	21225	Infiltration/Inflow	WWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer water, feces	Evidence of Overflow	Pressure jet relieved M/L choke	UAMD	195443
39	5/24/2014	2430 Frederick Ave	21223	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Relieved with electric machine	UAMD	195592
40	5/24/2014	5209 Midwood Ave	21212	Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Relieved with electric machine	UAMD	195627
41	5/24/2014	1424 W Mount Royal Ave	21217	Roots, Infiltration/Inflow	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved HC choke	UAMD	195609
42	5/25/2014	1806 Druid Hill Ave	21217	Rags, debris	DWO	N/A	0:25	9:00 AM - 9:25 AM	Gray water	25	Ran 30ft Elec-machine	UAMD	195574
43	5/26/2014	1647 Northwick Rd	21218	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet around clean-out	Evidence of Overflow	Used elec mach.	UAMD	195705
44	5/26/2014	2904 Sylvan Ave	21214	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved M/L choke with pressure truck 175ft of 8in T/O for CCTV	N/A	195603
45	5/30/2014	1015 W 37th St	21211	Roots	WWO	N/A	Not Witnessed	Overflow not Witnessed	Wet around clean-out	Evidence of Overflow	Used Elec. Mach	UAMD	196182
46	5/30/2014	505 E Patapsco Ave	21225	Rags	WWO	N/A	Not Witnessed	Overflow not Witnessed	Gray water & debris	Evidence of Overflow	Ran Elec. Machine	UAMD CCTV House Conn	196139
47	5/31/2014	2119 Callow Ave	21217	Rags grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with Elec mach 90ft of 6inch san CCTV 4.4ft	N/A	196222
48	5/31/2014	3409 Park Heights Ave	21215	Rags, roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet-paper around, no cap clean-out	Evidence of Overflow	Used Elec. Mach	UAMD	196213
				# WWO	26				TOTAL	51,739	EVIDENCE ONLY	39	