

## SSO Notification List

November 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	11/1/2012	3034 Mathews St	21218	Rags & Grease	WVO	None	0:30	3:00PM - 3:30PM	Gray Colored Water	15	Electric Machine relieved House Connection choke	Turn over to CCTV	146725
2	11/2/2012	402 Key Hwy	21230	Grease	DWO	Inner Harbor	1:00	11:00AM - 12:00PM	Gray Colored Water	60	Pressure Jet relieved Mainline choke	Turn over to CCTV	146748
3	11/3/2012	511 S. Collins Ave	21229	Rags, Roots & Grease	DWO	Gwynns Falls	3:00	1:00PM - 4:00PM	Gray Colored Water	180	Pressure Jet relieved Mainline choke	Turn over to CCTV	146782
4	11/3/2012	2301 Windsor Ave	21216	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Toilet Paper	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	146784
5	11/4/2012	Darley Ave. & N. Wolfe St	21213	Rags & Grease	DWO	Herring Run	2:00	11:30AM - 1:30PM	Heavy Gray Water	600	Pressure Jet relieved Mainline choke	Turn over to CCTV	146816
6	11/5/2012	1108 N. Central Ave	21202	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	146893
7	11/5/2012	1651 Ceddox St	21226	Heavy Debris	DWO	Inner Harbor	3:15	7:00PM - 10:15PM	Sewer Water	975	Pressure Jet relieved Mainline choke	Turn over to CCTV	146896
8	11/6/2012	1802 Mosher St	21217	Rags	DWO	Jones Falls	1:51	11:09AM - 1:00PM	Heavy Gray Water	111	Electric Machine relieved House Connection choke	Turn over to Health Dept	146919
9	11/7/2012	1314 Cedarcroft Rd	21212	Rags & Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Paper around Cleanout	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	146947
10	11/8/2012	1656 W. North Ave	21217	Pipe Break & Sand, Gravel, Rocks	DWO	Jones Falls	0:51	1:09PM - 2:00PM	Heavy Gray Water	51	Pressure Jet relieved Mainline choke	Turn over to CCTV	146991
11	11/12/2012	1903 South Rd	21209	Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147045
12	11/12/2012	214 Tunbridge Rd	21212	Rags, Roots & Grease	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147138
13	11/12/2012	3205 Elmora Ave	21213	Rags & Roots	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147151
14	11/12/2012	3603 Buena Vista Ave	21211	Roots & Grease	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147152
15	11/14/2012	3710 Nortonia Rd	21216	Rags, Roots & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147240
16	11/14/2012	6200 O'Donnell St	21224	Rags & Grease	DWO	Patapsco	0:30	9:15AM - 9:45AM	Gray Water & Grease	120	Pressure Jet relieved Mainline choke	Turn over to CCTV	147239
17	11/14/2012	Darley Ave. & N. Wolfe St	21213	Rags, Grease & Debris	DWO	Herring Run	1:40	6:20PM - 8:00PM	Sewer Water	500	Pressure Jet relieved Mainline choke	Turn over to CCTV	147271
18	11/15/2012	Smallwood & North Ave	21217	Rags & Grease	DWO	Gwynns Falls	14:30	11/14/12 7:30PM - 11/15/12 10:00AM	Gray Colored Water	870	Pressure Jet relieved Mainline choke	Turn over to CCTV	147275
19	11/15/2012	2800 Rosalind Ave	21215	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	147288
	11/18/2012	917 Seagull Ave	21225	Rags & Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	147504
20	11/19/2012	6309 Eunice Ave	21214	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147541
21	11/19/2012	1246 N. Broadway	21213	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Left Plumber a notice	N/A	147552
22	11/19/2012	1326 N. Broadway	21213	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	147549
23	11/19/2012	400 S. Augusta Ave	21229	Pipe Break	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris & Sewer Water	Evidence of Overflow	Left Plumber a notice	N/A	147532
24	11/19/2012	805 W. Cross St	21230	Rags	DWO	Low Level	2:04	9:24AM - 11:24AM	Heavy Gray Water	124	Electric Machine relieved House Connection choke	Turn over to CCTV	147536
25	11/21/2012	412 S. Beechfield Ave	21229	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	No Cleanout. Left notice for plumber	N/A	147731
26	11/21/2012	2921 Stranden Rd	21230	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	147764

**SSO Notification List**

**November 2012**

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
27	11/23/2012	803 E. 22nd St	21218	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper & Rags wet in yard	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147804
28	11/23/2012	1100 Elliott St & Urban Way	21224	N/A	DWO	None	1:00	2:00PM - 3:00PM	Gray Colored Water	60	Pressure Jet relieved Mainline choke	Turn over to CCTV	147825
29	11/23/2012	5016 Frankford Ave	21206	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147810
30	11/23/2012	Urban Way	21224	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	147825
31	11/23/2012	1811 Bolton St	21217	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147829
32	11/24/2012	3001 Erdman Ave	21213	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Toilet Paper	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147862
33	11/25/2012	307 Rossiter Ave	21212	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Toilet Paper	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147895
34	11/26/2012	412 S. Beechfield Ave	21229	Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	147731
35	11/26/2012	916 N. Monroe St	21217	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	147972
36	11/26/2012	5736 Nasco Pl	21239	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	148042
37	11/26/2012	Wolfe St & Fayette St	21287	Rags & Grease	DWO	Jones Falls	1:50	9:20AM - 11:10AM	Gray Water & Toilet Paper	330	Pressure Jet relieved Mainline choke	Turn over to CCTV	147913
38	11/26/2012	W. Northern Pkwy & Falls Rd	21210	Rags, Grease & Rocks	DWO	Jones Falls	1:38	9:22AM - 11:00AM	Heavy Gray Water	98	Pressure Jet relieved Mainline choke	Turn over to CCTV	147914
39	11/27/2012	16 S. Monroe St	21223	Debris	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Left plumber a notice	148076
40	11/27/2012	1823 Eutaw Pl	21217	Rags & Debris	WVO	Jones Falls	3:33	7:57PM - 11:30PM	Sewer Water	1,491	Pressure Jet relieved Mainline choke	Turn over to CCTV	148091
41	11/27/2012	400 S. Augusta Ave	21229	Sand, Gravel, Rocks	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	148072
42	11/27/2012	1809 Bolton St	21217	Roots & Debris	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	148095
43	11/28/2012	1011 Woodson Rd	21212	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	None	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	148115
44	11/29/2012	1122 Braddish Ave	21216	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	148231
45	11/29/2012	1823 Eutaw Pl	21217	Rags & Debris	DWO	Jones Falls	1:30	10:00AM - 11:30AM	Heavy Gray Water	180	Pressure Jet relieved Mainline choke	Turn over to CCTV	148218
46	11/29/2012	2427 Etting St	21217	Rags & Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Not Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	148255
47	11/29/2012	Flaxter & Yellowwood Ave	21209	Rags	DWO	Jones Falls	2:23	9:45AM - 12:08PM	Heavy Gray Water	143	Electric Machine relieved House Connection choke	Turn over to CCTV	148291
48	11/29/2012	412 S. Beechfield Ave	21229	Rags & Roots	DWO	Gwynns Falls	3:36	10:48AM - 2:24PM	Heavy Gray Water	216	Pressure Jet relieved Mainline choke	Turn over to CCTV	148330
	11/29/2012	5216 Linden Heights Ave	21215	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Investigator found no active OVFL	N/A	SR# 102318
				# WVO	10				TOTAL	6,124	EVIDENCE ONLY	32	