

SSO Notification List

November 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	11/2/2013	315 N Payson St	21223	Rags, Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 60ft TV 3.2ft to Bottom 15.0 Main	N/A	168227
2	11/2/2013	701 Wyanoke Ave	21218	Unknown	DWO	N/A	3:16	9:44AM - 1:00PM	N/A	196	Not Relieved Back Broke Down at 28ft for bypass Pumping	N/A	168223
3	11/5/2013	2200 Crest Rd	21209	Unknown	DWO	Jones Falls, Patapsco	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	N/A	N/A	168365
4	11/5/2013	N Washington St & E Fayette St	21231	Rags	DWO	Outfall	2:04	11:43AM - 1:47PM	Heavy Gray Water	372	Pressure Truck Relieved	UAMD Investigate	168360
5	11/6/2013	1405 McCulloh St	21217	Rags, Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet Paper around Cleanout	Evidence of Overflow	Used Elec Mach	UAMD CCTV	168419
6	11/6/2013	2000 E Fayette St	21231	Rags, Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Used Sewer Jet	UAMD CCTV	168412
7	11/7/2013	5300 Beaufort Ave	21215	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Rel Elec Mach 30ft Cables	UAMD	168466
8	11/7/2013	6301 Western Run Dr	21215	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Rel 60ft Electric Machine Cables	UAMD	168465
9	11/9/2013	137 S Loudon Ave	21229	Roots	DWO	N/A	0:34	2:41PM - 3:15PM	Heavy Gray	68	Relieve with Pressure Truck	UAMD Investigate/CCTV	168581
10	11/10/2013	4315 Lasalle Ave	21206	Unknown	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Relieved with Electric Machine	UAMD/CCTV	168601
11	11/11/2013	2122 W Saratoga St	21223	Other Paper	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet Paper Around Trap	Evidence of Overflow	Left Plumbers Notice to Remove Old Style Trap	UAMD	168647
12	11/11/2013	601 E 34th St	21218	Roots	DWO	Jones Falls, Patapsco	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 30ft of 6inch TV 7.0 Bottom 15.0 Main Line	N/A	168639
13	11/11/2013	845 Pontiac Ave	21225	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach 30ft of 6inch TV 60ft Bottom 8.6ft	N/A	168649
14	11/12/2013	1824 N Fulton Ave	21217	Rags, Grease	WVO	N/A	Not Witnessed	Overflow not Witnessed	Gray Black Water	Evidence of Overflow	Used Elec Mach	UAMD CCTV	168689
15	11/13/2013	2109 E North Ave	21213	Unknown	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet on ground near Clean Out	Evidence of Overflow	Left Plumbers Notice to Remove Cleanout Cap	N/A	168773
16	11/13/2013	904 N Charles St	21201	Unknown	DWO	Jones Falls	Not Witnessed	Overflow not Witnessed	Grey Water	Evidence of Overflow	Plumber Resolved Issue	UAMD	168785
17	11/14/2013	412 E Biddle St	21202	Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Line Cleaned with Electric Machine	UAMD	168825
18	11/14/2013	4434 Falls Rd	21209	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Debris	Evidence of Overflow	Pressure Truck Relieve Main Line Choke 200ft Pressure Hose	UAMD CCTV Main Line	168824
19	11/15/2013	3 E Read St	21202	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	Gray colored water	Evidence of Overflow	Line Cleaned with Electric Machine	UAMD	168884
20	11/15/2013	225 Stoney Ford Rd	21210	Rags, Debris	WVO	Jones Falls	1:39	9:45AM - 11:24AM	Gray Water	495	Relieved 8" san. mainline 150ft pressure mach. hose	UAMD	168872

SSO Notification List

November 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
21	11/15/2013	133 S Loudon Ave	21229	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Ran 45ft Elec Mach.	UAMD	168871
22	11/15/2013	911 Washburn Ave	21225	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around cleanout	Evidence of Overflow	Used Elec Mach.	UAMD CCTV	168887
23	11/16/2013	400 Key Hwy	21202	Grease	WVO	N/A	0:30	6:00PM - 6:30PM	Gray colored water	30	Used sewer jet	UAMD	168933
24	11/18/2013	5736 Nasco Pl	21239	Unknown	WVO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around cleanout	Evidence of Overflow	Used Elec Mach.	UAMD	169054
25	11/19/2013	351 Gwynn Ave	21229	Rags	DWO	N/A	0:60	9:00PM - 10:00PM	Wet on ground near Clean Out	15	Used Elec Mach.	UAMD CCTV	169241
26	11/20/2013	531 Cumberland St	21217	Pipe Break	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet paper around Cleanout	Evidence of Overflow	Used Elec Mach.	UAMD CCTV	169343
27	11/21/2013	4909 Herring Run Dr	21214	Other Paper	DWO	N/A	0:10	10:10AM - 10:20AM	Gray Water	20	Relieved with Electric Machine	UAMD	169466
28	11/21/2013	3949 Greenmount Ave	21218	Rags, Grease	DWO	N/A	0:60	7:30PM - 8:30PM	Gray colored water, paper	30	Used sewer jet	UAMD CCTV	169586
29	11/23/2013	4408 Groveland Ave	21215	Rags, Roots, Other Stick	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Choke with Elec Mach distance of 6 Inch TV 3.7 Bottom to 18.5 Main	N/A	169773
30	11/23/2013	1900 Ashland Ave	21205	Rags, Grease, Sand, Gravel, Rocks	DWO	N/A	2:31	11:29AM - 2:00PM	Heavy Gray Water	302	Used bypass pumping to stop T/O for CCTV Monday AM, not relieved	N/A	169770
31	11/25/2013	5 Saint Georges Rd	21210	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper on ground	Evidence of Overflow	Used Elec Mach.	UAMD	170150
32	11/26/2013	1800 W Baltimore St	21223	Rags, Grease	WVO	Patapsco	18:18	11/26/13 2:53PM - 11/27/13 9:11AM	Heavy Gray Water	3,294	Relieved mainline choke with pressure truck, 250 ft. 8 in.	N/A	170294
33	11/26/2013	4740 Reisterstown Rd	21215	Grease	WVO	N/A	0:60	7:00PM - 8:00PM	Gray colored water	60	Used sewer jet	UAMD CCTV	170232
34	11/27/2013	504 S Gilmor St	21223	Rags, Grease	WVO	Patapsco	0:22	8:38AM - 9:00AM	Heavy Gray Water	66	Relieved mainline choke with pressure truck, 500 ft. 8 in.	N/A	170266
35	11/27/2013	301 E Madison St	21202	Rags, Grease, Trash	WVO	Jones Falls	5:30	11:00AM - 4:30PM	Plastic, Trash, Cups, and other debris	8,250	Set up over pump and jetting line with vac cop	UAMD	170278
36	11/27/2013	1321 Lemmon St	21223	Roots	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Ran 30 ft. Elec. Machine cable	UAMD	170298
37	11/27/2013	1600 N Pulaski St	21217	Rags, Grease	WVO	Jones Falls	2:01	9:26AM - 11:27AM	Heavy Gray Water	605	Relieved main choke with pressure truck, 275 ft. of 15 in.	N/A	170271
38	11/28/2013	Baker St & Warwick Ave	21216	Roots, Grease	DWO	Gwynns Falls	0:50	12:30PM - 1:20PM	Clear colored water	250	Jetted line with pressure truck	UAMD	170336
39	11/28/2013	618 E 30th St	21218	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn. choke with Elec. Mach. 45ft. CCTV 22ft. bottom 27.9ft. to main	N/A	170346
40	11/29/2013	2617 Woodland Ave	21215	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved house conn choke with Elec. Mach. 90ft TV 60 ft. bottom to main 17.5 ft.	N/A	170361

SSO Notification List

November 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
41	11/29/2013	500 Brunswick St	21223	Grease	DWO	N/A	0:60	10:30PM - 11:30PM	Gray colored water	30	Used sewer jet	UAMD CCTV	170418
42	11/29/2013	2801 Beechland Ave	21214	Grease	DWO	N/A	0:60	7:00PM - 8:00PM	Wet paper around cleanout	15	Elec. Mach.- Sewer jet	UAMD CCTV	170399
43	11/29/2013	1245 Gittings Ave	21239	Unknown	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Elec. Mach.- Sewer jet	UAMD CCTV	170365
44	11/30/2013	4530 Fairfax Rd	21216	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain cleaning machine relieved h/c choke	UAMD	170423
				# WWO	15				TOTAL	14,098	EVIDENCE ONLY	27	