

SSO Notification List

October 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	10/1/2014	2424 Annor Court	21230	Rags, Grease	DWO	N/A	90	Gray colored water	180	Used pressure machine	N/A	210749
2	10/1/2014	2709 Round Road	21225	Rags	DWO	N/A	Not Witnessed	Paper and debris	Evidence of Overflow	Ran 45 foot electric machine	CCTV	210644
3	10/1/2014	4714 Greenspring Avenue	21209	Rags, Grease	DWO	N/A	Not Witnessed	Wet paper on grass	Evidence of Overflow	Used electric machine	N/A	210721
4	10/2/2014	700 W. Saratoga Street	21201	Rags	DWO	N/A	Not Witnessed	Gray water	Evidence of Overflow	Ran 45 foot electric machine	CCTV	210862
5	10/2/2014	2110 Ridgehill Avenue	21217	Rags, Roots	DWO	N/A	Not Witnessed	Wet paper	Evidence of Overflow	Used elec. Machine	N/A	210938
6	10/2/2014	2907 The Alameda	21218	Unknown	DWO	N/A	Not Witnessed	Wet around clean out	Evidence of Overflow	Used elec. Machine	N/A	210950
7	10/2/2014	Dupont & Greenspring Avenue	21209	Rags, Grease	DWO	N/A	Not Witnessed	Paper debris, grease	Evidence of Overflow	Pressure jet relieved H/C choke	N/A	210858
8	10/4/2014	3132 Guilford Avenue	21218	Rags	DWO	N/A	Not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved H/C	N/A	211149
9	10/6/2014	6309 Eunice Avenue	21214	Roots	DWO	N/A	Not Witnessed	Clear water around clean out and paper	Evidence of Overflow	Cleaned line with elec machine	OMD	211286
10	10/7/2014	2601 Oswego Avenue	21215	Rags, Grease	WWO	N/A	Not Witnessed	N/A	Evidence of Overflow	Relieved house connection choke with pressure truck, 150 ft of 6 inch	N/A	211474
11	10/9/2014	2318 Ivy Avenue	21214	Roots, Infiltration/Inflow, Red solo cup	DWO	N/A	Not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved H/C choke	N/A	211838
12	10/9/2014	3800 E. Baltimore Street	21224	Grease, Infiltration/Inflow, Dough	DWO	N/A	100	Grease, Dough	2,500	VacCon relieved sanitary sewer M/L choke	N/A	211946
13	10/10/2014	1004 Roland Heights Avenue	21211	Rags	DWO	N/A	Not Witnessed	Gray water	Evidence of Overflow	Rel. 45ft Elec-Machine	UAMD	212115
14	10/10/2014	3839 Frisby Street	21218	Infiltration/Inflow, Inside problem	DWO	N/A	Not Witnessed	Sewer water	Evidence of Overflow	Referred to sewer health & housing	N/A	145195
15	10/12/2014	2801 Virginia Avenue	21209	Rags	DWO	N/A	47	Toilet paper & debris	94	Ran 60ft Elec. Machine	CCTV	212270
16	10/14/2014	2015 E. Federal Street	21213	Rags, Grease, Debris	DWO	N/A	Not Witnessed	Sewer water	Evidence of Overflow	Pressure jet relieved M/L choke	N/A	212416
17	10/14/2014	2921 Stranden Road	21230	Roots, Grease	DWO	N/A	Not Witnessed	Wet around manhole	Evidence of Overflow	Used sewer jet	N/A	212487
18	10/14/2014	826 Glenwood Avenue	21212	Rags, Roots, Vandalism	DWO	N/A	Not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved H/C choke	N/A	212462
19	10/15/2014	6619 Park Heights Avenue	21215	Unknown	WWO	N/A	Not Witnessed	Wet ground - paper	Evidence of Overflow	Used Elec. Mach.	N/A	212617
20	10/16/2014	400 Key Highway	21202	Grease	DWO	N/A	180	Gray colored water	360	Used sewer jet	UAMD	212845
21	10/16/2014	2015 E. Federal Street	21213	Rags, Grease, Infiltration/Inflow, Debris	DWO	N/A	285	Gray water, paper debris	570	Pressure jet relieved sanitary M/L choke	UAMD	212416
22	10/16/2014	334 S. Calhoun Street	21223	Grease	DWO	N/A	Not Witnessed	Gray colored water, black water	Evidence of Overflow	Used sewer jet	N/A	212852

SSO Notification List

October 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
23	10/16/2014	5070 Wabash Avenue	21215	Grease	WVO	N/A	181	Motor oil	362	Ran 90ft elec. Machine, Not rel.	UAMD	212737
24	10/16/2014	5268 Cordella Avenue	21215	Rags, Grease, Debris	DWO	N/A	73	Gray water	146	Pressure truck flush mainline	UAMD	212786
25	10/19/2014	932 Seagull Avenue	21225	Grease, Debris	DWO	N/A	35	Gray water and grease	70	Pressure truck flush mainline 300ft pressure hose	N/A	213057
26	10/19/2014	Colvin Street & E. Fayette Street	21202	Rags, Grease, Debris	DWO	N/A	81	Gray water and debris	2,025	Pressure truck rel. 100ft pressure hose	N/A	213060
27	10/20/2014	131 S. Loudon Avenue	21229	Rags, Roots	DWO	N/A	Not Witnessed	Toilet paper	Evidence of Overflow	Ran elec. Machine	CCTV	213150
28	10/20/2014	1650 Union Avenue	21211	Rags, Grease, Debris	DWO	N/A	80	Gray water	160	Pressure truck flush mainline	CCTV	213098
29	10/20/2014	3114 Kenyon Avenue	21213	Roots	DWO	N/A	Not Witnessed	Wet around clean-out	Evidence of Overflow	Elec. Mach.	N/A	213266
30	10/20/2014	4223 Belmar Avenue	21206	Pipe Break, Infiltration/Inflow, Mud	DWO	N/A	Not Witnessed	Paper debris	Evidence of Overflow	Drain cleaning machine relieved H/C choke	N/A	213224
31	10/20/2014	4260 Labyrinth Road	21215	Roots, Grease	DWO	N/A	Not Witnessed	Wet paper around clean out	Evidence of Overflow	Used elec. Mach.	N/A	213272
32	10/21/2014	3601 Bowers Avenue	21207	Rags, Grease, Debris	WVO	N/A	135	Gray water	2,025	Pressure truck flush mainline	N/A	213361
33	10/21/2014	5200 Eastbury Avenue	21206	Grease	WVO	N/A	207	Paper	1,035	Relieved with pressure truck	CCTV	213364
34	10/21/2014	N. Woodington Road & Stokes Drive	21229	Roots, Debris	WVO	N/A	120	Gray water	9,600	Pressure truck flush mainline	N/A	213387
35	10/22/2014	3434 Wilkens Avenue	21229	Heavy Rain, Infiltration/Inflow	WVO	N/A	225	Sewer water	22,500	Wait for rain event to end	N/A	213606
36	10/22/2014	515 E. 38th Street	21218	Roots	WVO	N/A	Not Witnessed	Wet around clean out	Evidence of Overflow	Used elec. Mach.	N/A	213625
37	10/22/2014	5514 Roland Avenue	21210	Unknown	WVO	N/A	Not Witnessed	Paper	Evidence of Overflow	Run Elec. Machine 30ft Elec. Cables found clear	N/A	213568
38	10/23/2014	800 Unetta Avenue	21229	Rags, Roots, Grease	WVO	N/A	180	Debris, Rags, Grease	36,000	Turn over to OAM and CCTV	Turn over for CCTV	213812
39	10/24/2014	1235 Sherwood Avenue	21239	Grease	WVO	N/A	Not Witnessed	Gray water	Evidence of Overflow	Relieved with electric machine	UAMD T/O CCTV	213878
40	10/24/2014	2801 Kinsey Avenue	21223	Roots	DWO	N/A	27	Paper	135	Ran Elec. Machine	N/A	213895
41	10/24/2014	3811 Millford Avenue	21207	Roots	DWO	N/A	66	Toilet paper	132	Ran elec. Machine	N/A	213907
42	10/25/2014	159 Thomas Guldera Circle	21229	Unknown	DWO	N/A	Not Witnessed	Wet around clean out	Evidence of Overflow	Used Elec. Mach.	N/A	213986
43	10/25/2014	1604 N. Chapel Street	21213	Unknown	DWO	N/A	Not Witnessed	N/A	Evidence of Overflow	Relieved with electric machine	UAMD / CCTV	213973
44	10/26/2014	5504 Craig Avenue	21212	Rags, Roots	DWO	N/A	Not Witnessed	Toilet paper & debris	Evidence of Overflow	Ran Elec- Machine	N/A	213992

SSO Notification List

October 2014

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
45	10/26/2014	6003 Pinehearth Road	21212	Roots	DWO	N/A	Not Witnessed	Toilet paper	Evidence of Overflow	Run Elec. machine	CCTV	214011
46	10/27/2014	1808 Woodbourne Avenue	21239	Roots	DWO	N/A	Not Witnessed	Wet around clean out	Evidence of Overflow	Used elec. machine	N/A	214160
47	10/27/2014	509 Westgate Road	21229	Unknown	DWO	N/A	Not Witnessed	Paper wet around	Evidence of Overflow	Used Elec. Mach.	N/A	214176
48	10/28/2014	2921 Straden Road	21230	Rocks, Debris	DWO	N/A	Gray water	Paper	150	Pressure truck flush Main-line	N/A	214238
49	10/28/2014	4302 Maine Avenue	21207	Unknown	DWO	N/A	Not Witnessed	Dried paper on ground	Evidence of Overflow	Used Elec. Mach.	N/A	214329
50	10/29/2014	700 N. Denison Street	21229	Pipe Break, Infiltration/inflow	DWO	N/A	131	Sewer leak into storm drain	131	Bypass pumping	CCTV	214439
51	10/29/2014	1517 N. Bond Street	21213	Unknown	DWO	N/A	Not Witnessed	Small amount of paper in yard	Evidence of Overflow	Cleaned mainline with vac con found clear	N/A	214474
52	10/29/2014	2804 Frederick Avenue	21223	Rags, Rocks, Debris	DWO	N/A	270	Gray colored water from manhole	8,100	Bypass pumping and hand tools	CCTV	214484
53	10/29/2014	3107 Artaban Place	21216	Rags, Roots, Grease	DWO	N/A	75	Gray water	75	Pressure truck	CCTV	214374
54	10/31/2014	3718 Elmley Avenue	21213	Rags, Roots	DWO	N/A	Not Witnessed	Clear colored water and paper	Evidence of Overflow	Cleaned line with elec. machine	UAMD	214752
55	10/31/2014	6211 Walthers Boulevard	21206	Rags, Trash	DWO	Herring Run	Not Witnessed	Small amount of paper & trash	Evidence of Overflow	Jetted line with Vac Con machine	UAMD	214766
				# WWO	11			TOTAL	86390	EVIDENCE ONLY	34	