

SSO Notification List

September 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	9/1/2013	3800 Greenmount Ave	21268	Trash, Grease	WVO	Jones Falls	0:36	10:35AM - 11:11AM	Murky Water	72	Flush Main Manhole to Manhole	Routine Cleaner	164804
2	9/2/2013	6012 Wallis Ave	21215	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Wet Paper Around Clean Out	Evidence of Overflow	Used Elec. Mach to relieve Conn	UAMD CCTV	164840
3	9/4/2013	2725 Hampden Ave	21211	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Wet Paper Around Clean Out	Evidence of Overflow	Used Elec Mach to relieve Conn	CCTV UAMD	164959
4	9/6/2013	15 W North Ave	21201	Rags Grease	DWO	N/A	1:00	8:00PM - 9:00PM	Gray Colored Water	60	Used Elec Mach to relieve Conn	UAMD CCTV	165062
5	9/6/2013	S Warwick Ave & Hollins St	21223	Rags Grease Other Debris	DWO	High Level	1:26	9:04AM - 10:30AM	Heavy Gray Water	180	Relieved ML Choke with Press Truck 200ft of 8"inch San ML	N/A	165043
6	9/7/2013	577 Wyndholme Way	21229	Roots	DWO	Gwynns Falls	1:10	6:30PM - 7:40PM	Heavy Gray Water	350	Pressure Jet relieved choke	UAMD Investigate T/O for CCTV	165083
7	9/8/2013	15 W North Ave	21201	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Private Plumber Took Care of Problem	UAMD	165094
8	9/9/2013	2100 Pulaski St	21217	Rags, Pipe Break, Grease Other Debris	DWO	Jones Falls	5:05	8:55AM - 2:00PM	Heavy Gray Water	915	Relieved ML Choke with Hook & Rodded 8 inch	T/O for CCTV	165129
9	9/10/2013	2730 W Lafayette Ave	21216	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Run 14ft Elec Machine Relieve	House Connection Choke UAMD	165201
10	9/10/2013	2549 Aisquith St	21218	N/A	DWO	N/A	0:25	11:00AM - 11:25AM	Gray Water	25	Left Plumber Notice to get plumber to snake inside	Turn Over for UAMD to Investigate	165210
11	9/11/2013	1911 Walbrook Ave	21217	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Rel Elec Machine	UAMD	165252
12	9/11/2013	4915 Greenspring Ave	21209	Rags, Grease	DWO	Jones Falls	4:30	7:00PM - 11:30PM	Gray Colored Water	810	Used Sewer Jet	UAMD CCTV	165277
13	9/13/2013	523 Linwood Ave	21205	Rags, Grease	WVO	Inner Harbor	2:00	7:00PM - 9:00PM	Gray Colored Water	120	Used Sewer Jet	UAMD CCTV	165364
14	9/13/2013	Edgevale Rd & Deepdene Rd	21210	Rags, Grease	WVO	N/A	4:30	6:30PM - 11:00PM	Gray Colored Water	540	Used Sewer Jet	UAMD CCTV	165366
15	9/13/2013	813 N Milton Ave	21205	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Relieved with Electric Machine UAMD Investigate	T/O CCTV	165352
16	9/15/2013	3813 Stokes Dr	21229	Rags, Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper rags and grease around	Evidence of Overflow	Used Elec Mach	Will turn over for UAMD to investigate	165392
17	9/15/2013	3101 Tilden Dr	21211	Other, Unknown Object	DWO	Jones Falls	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Left Consumer a Plumber's Notice	UAMD	165436
18	9/16/2013	3400 Pinkney Rd	21215	Rags	WVO	Gwynns Falls	13:14	09/17/13 9:16PM - 09/18/13 10:30AM	Heavy Gray Water	2382	Relieved ML Choke with Press Truck 250ft of 6inch	T/O for CCTV	165497
19	9/17/2013	5715 Park Heights Ave	21215	Rags	DWO	N/A	1:19	9:10AM - 10:29AM	Paper	158	Rel with Elec Machine 45ft Elec Cables with Expand. Cutter	UAMD	165501
20	9/17/2013	Cyburn Ave & Greenspring Ave	21215	Rags, Pipe Break, Grease	DWO	Gwynns Falls	1:08	8:52AM - 10:00AM	Heavy Gray Water	340	Relieved ML Choke with Press Truck 250ft of 10inch San ML	N/A	165500
21	9/17/2013	3300 The Alameda	21218	Roots, Grease	DWO	N/A	Not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Relieve with Electric Machine	UAMD Investigate/ T/O CCTV	165511
22	9/18/2013	340 S Augusta Ave	21229	Rags, Roots, Grease	DWO	Gwynns Falls	2:00	8:30PM - 10:30PM	Wet Around Clean Out	60	Used Elec Mach	UAMD CCTV	165597
23	9/18/2013	709 Linnard St	21229	Rags, Grease	DWO	Gwynns Falls	1:00	9:20PM - 10:20PM	Gray Colored Water	60	Used Elec Mach	UAMD CCTV	165601
24	9/18/2013	2700 Rittenhouse Ave	21230	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Drain Cleaning Machine Relieved H/C Choke	UAMD	165489
25	9/19/2013	250 N Fulton Ave	21223	N/A	DWO	N/A	Not Witnessed	overflow not Witnessed	Paper	Evidence of Overflow	Pressure Truck Flash Main Line San Sewer	UAMD	165652
26	9/21/2013	Bethune Rd & Spelman Rd	21225	Rags, Grease, Other Debris	WVO	Patapsco	1:56	10:04AM - 12:00PM	Heavy Gray Water	2900	Relieved ML Choke with Press Truck 200ft	T/O for CCTV	165710
27	9/21/2013	107 W 29th St	21218	N/A	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris near Manhole Cover	Evidence of Overflow	N/A	UAMD	165715
28	9/21/2013	3130 Guilford Ave	21218	Rags	WVO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain Cleaning Machine Relieved House Connection Choke	UAMD	165723
29	9/22/2013	320 E 33rd St	21218	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	Relieved House Conn Chokewith Elec Mach 30ft of 6inch	N/A	165745
30	9/22/2013	2604 Goodwood Rd	21214	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Drain Cleaning Machine Relieved H/C Choke	UAMD	165758
31	9/22/2013	4224 Falls Rd	21211	Pipe Break	DWO	N/A	Not Witnessed	Overflow not Witnessed	N/A	Evidence of Overflow	By Pass Pump	UAMD	165748
32	9/23/2013	501 Hawthorn Rd	21210	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Truck Rel. Main Line Choke	UAMD	165773
33	9/23/2013	813 N Milton Ave	21205	N/A	DWO	N/A	1:00	6:30PM - 7:30PM	Water in Yard Paper around	60	Used Elec Mach	UAMD CCTV	165836
34	9/23/2013	1621 N Warwick Ave	21216	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Damp Area	Evidence of Overflow	Pressure Truck Relieve Main Line Choke	UAMD	165786
35	9/23/2013	2012 Ramsay St	21223	N/A	DWO	N/A	6:00	2:00PM - 8:00PM	Water in Yard and Alley	180	Used Elec Mach	UAMD CCTV	165846
36	9/23/2013	Dupont Ave & Greenspring Ave	21209	N/A	DWO	N/A	1:00	5:00PM - 6:00PM	Gray Colored Water	60	Used Elec Mach.	UAMD CCTV	165831
37	9/23/2013	458 Roundview Rd	21225	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Drain Cleaning Machine Relieved H/C Choke	UAMD	165780
38	9/23/2013	1128 N Gilmer St	21217	Rags	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper & Debris	Evidence of Overflow	Drain cleaning machine relieved H/C Choke	UAMD	165832

SSO Notification List

September 2013

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
39	9/24/2013	3208 Piedmont Ave	21216	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper & Debris	Evidence of Overflow	Rel Elec Machine	UAMD	165866
40	9/25/2013	4200 Franklinton Rd	21229	Pipe Break	DWO	N/A	71:50	09/25/13 6:25PM - 09/28/13 6:15PM	Grey Water	21,550	Bulkheaded Line & Bypass Pumping	Construction Management	165957
41	9/26/2013	2121 Kentucky Ave	21218	N/A	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Used Elec Mach	UAMD CCTV	165962
42	9/26/2013	5656 The Alameda	21212	Rags, Roots	DWO	Herring Run	1:30	1:30PM - 3:00PM	Gray Colored Water	90	Cleaned Line with Elec Mach	UAMD	165978
43	9/27/2013	3900 Linkwood Rd	21210	Rags, Grease, Other: Paper Wipes	WWO	Jones Falls	2:30	5:00PM - 7:30PM	Gray Colored Water, Paper, Waste	Evidence of Overflow	Used Press Mach	UAMD	166037
44	9/29/2013	2606 Evergreen Ave	21214	Roots	DWO	N/A	Not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Rel 45ft Electric Machine Cables + Expansion Cutter	UAMD	166087
45	9/30/2013	2001 W Patapsco Ave	21230	Rags, Grease	DWO	Patapsco	1:00	7:00PM - 8:00PM	Gray Colored Water	180	Used Sewer Jet	UAMD CCTV	166145
46	9/30/2013	2836 Maryland Ave	21218	Rags, Grease	DWO	Jones Falls	1:30	5:30PM - 7:00PM	Gray Colored Water	90	Used Sewer Jet	UAMD CCTV	166132
47	9/30/2013	3111 Frisby St	21218	Rags, Grease	DWO	N/A	3:56	3:04PM - 7:00PM	Gray Colored Water	472	Used Sewer Jet	UAMD CCTV	166126
48	9/30/2013	5900 The Alameda	21239	Roots	DWO	N/A	0:55	10:20AM - 11:15AM	Gray Water	110	Electric Machine	UAMD Investigate	166102
49	9/30/2013	Dupont Ave & Greenspring Ave	21209	Rags	DWO	N/A	3:30	2:30PM - 6:00PM	Wet Paper Gray Colored Water	420	Used Elec Mach	UAMD CCTV	166124
				# WWO	11				TOTAL	32,184	EVIDENCE ONLY	24	