

SSO Notification List

April 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	4/1/2012	3747 Nortonia Rd	21216	Rags & Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137062
2	4/2/2012	Fredrick Ave & Stonecroft Rd	21229	Rags, Roots, Debris	WWO	Gwynns Falls	3:35	3:25PM - 7:00PM	Sewer Water, feces, rags	2,150	Pressure Jet relieved Mainline choke	Turn over to CCTV	137097
3	4/3/2012	2808 Montebello Ter	21214	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137150
4	4/3/2012	4002 Kathland Ave	21207	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137135
5	4/3/2012	1152 E. North Ave	21218	Debris	DWO	Jones Falls	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	137175
6	4/4/2012	6513 Detroit Ave	21222	Rags, Trash, Sand, Gravel, Rocks	DWO	Patapsco	Overflow not Witnessed	Overflow not Witnessed	Brown & Gray Colored Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	137180
7	4/5/2012	1411 John St	21217	Pipe Break	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137258
8	4/6/2012	2600 Wilkens Ave	21223	Rags & Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water & Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	137302
9	4/7/2012	106 S. Calverton Rd	21223	Grease & Debris	DWO	Gwynns Falls	3:38	7:22PM - 11:00PM	Gray Water	872	Pressure Jet relieved Mainline choke	Turn over to CCTV	137341
10	4/8/2012	Ednor Rd & Greystone Rd	21218	Rags, Grease, Debris	DWO	Herring Run	2:15	3:25PM - 5:40PM	Gray Water & Grease	405	Pressure Jet relieved Mainline choke	Turn over to CCTV	137358
11	4/8/2012	410 E. 31st St	21218	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137369
12	4/9/2012	4200 Falls Rd	21211	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137371
13	4/9/2012	2535 Brookfield Ave	21217	Rags & Pipe Break	DWO	Jones Falls	3:23	11:37AM - 3:00PM	Heavy Gray Water	203	None - House Connection broke down	Turn over to CCTV	137383
14	4/9/2012	601 N. Carrollton Ave	21217	Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137400
15	4/9/2012	3509 E. North Ave	21213	Roots	DWO	Herring Run	42:00	4/9/12 6:00PM - 4/11/12 12:00PM	Brown & Gray Colored Water	5,040	Pressure Jet relieved Mainline choke	Turn over to CCTV	137403
16	4/9/2012	427 S. Gilmor St	21223	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137409
17	4/10/2012	2016 E. 31st St	21218	Rags & Debris	DWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	137474
18	4/11/2012	112 Scott St	21201	Rags & Roots	WWO	None	1:18	1:22PM - 2:40PM	Heavy Gray Water	78	Electric Machine relieved House Connection choke	Turn over to CCTV	137520
19	4/11/2012	415 N. Glover St	21224	N/A	WWO	Baltimore Harbor	Overflow not Witnessed	Overflow not Witnessed	Sewer Water & Paper Debris	Evidence of Overflow	Turn over to the Health Dept.	Need a plumber	137537
20	4/11/2012	2760 Wilkens Ave	21223	Sand, Gravel, Roots	WWO	Gwynns Falls	7:00	8:00AM - 3:00PM	Heavy Gray Water	840	Pressure Jet relieved Mainline choke	Turn over to CCTV	137528
21	4/12/2012	201 N. Highland Ave	21224	Rags & Grease	DWO	Northwest Harbor	Overflow not Witnessed	Overflow not Witnessed	Brown & Gray Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137576
22	4/12/2012	428 E. Preston St	21202	Grease & Trash	DWO	Jones Falls	2:40	12:20PM - 3:00PM	Paper & Brown Colored Water	320	Pressure Jet relieved Mainline choke	Turn over to CCTV	137571
23	4/12/2012	3018 Overland Ave	21214	Rags, Roots & Trash	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137559
24	4/12/2012	6701 Quad Ave	21237	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137505
25	4/13/2012	623 Lucia Ave	21229	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137665
26	4/13/2012	2401 W. Belvedere Ave	21215	Rags, Roots & Grease	DWO	Jones Falls	2:19	8:08AM - 10:27AM	Heavy Gray Water	2,780	Pressure Jet relieved Mainline choke	Turn over to CCTV	137637
27	4/13/2012	2702 Grindon Ave	21214	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137668

SSO Notification List

April 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
28	4/13/2012	6501 E. Lombard St	21224	Rags & Grease	DWO	Low Level	18:56	4/13/12 5:04PM - 4/14/12 12:00PM	Heavy Gray Water	3,408	Pressure Jet relieved Mainline choke	Turn over to CCTV	137664
29	4/14/2012	2723 Overland Ave	21214	Rags & Grease	WVO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137745
30	4/14/2012	4200 Mondawmin Ave	21216	Rags & Roots	WVO	Gwynns Falls	1:01	2:22PM - 3:23PM	Heavy Gray Water	61	Pressure Jet relieved Mainline choke	Turn over to CCTV	137699
31	4/16/2012	2905 Benson Ave	21223	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137771
32	4/17/2012	133 S. Loudon Ave	21229	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Light Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137815
33	4/17/2012	4101 The Alameda	21218	Rags	DWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137833
34	4/17/2012	Ednor Rd & Greystone Rd	21218	Rocks & Mud	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Medium Gray Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	137810
35	4/18/2012	6465 Frankford Ave	21206	Roots & Grease	WVO	Herring Run	1:20	9:00AM - 10:20AM	Brown & Gray Colored Water with Paper	800	Pressure Jet relieved Mainline choke	Turn over to CCTV	137861
36	4/18/2012	Ednor Rd & Greystone Rd	21218	Rags & Grease	WVO	Herring Run	12:32	9:58PM - 10:30PM	Grease & Debris	2,256	By-pass Pumping	Turn over to CCTV	137888
37	4/20/2012	1517 Winford Rd	21239	Roots	DWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Paper & Clear Colored Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	137977
38	4/20/2012	1650 Union Ave	21211	Rags & Grease	DWO	Jones Falls	3:11	8:49 AM - 12:00 PM	Heavy Gray Water	955	Pressure Jet relieved Mainline choke	Turn over to CCTV	137953
39	4/20/2012	3537 Old York Rd	21218	Rags, Grease, Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	137952
40	4/22/2012	1100 Slater Rd	21225	Rags & Grease	WVO	Patapsco	0:45	5:30 PM - 6:15	Gray Water	225	Pressure Jet relieved Mainline choke	Turn over to CCTV	138019
41	4/23/2012	3220 Sun St	21226	Rags	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138069
42	4/23/2012	5082 Orville Ave	21205	Rags & Debris	WVO	Herring Run	1:35	17:30 PM - 19:05 PM	Sewer Water	190	Pressure Jet relieved Mainline choke	Turn over to CCTV	138071
43	4/24/2012	208 S Augusta Ave	21229	Rags	DWO	Gwynns Falls	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138128
44	4/24/2012	502 S Belnord Ave	21224	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138139
45	4/24/2012	5600 Purlington Way	21212	Debris	DWO	Herring Run	1:35	18:20 PM - 19:55 PM	Sewer Water	950	Pressure Jet relieved Mainline choke	Turn over to CCTV	138132
46	4/25/2012	201 E Pratt St	21230	Rags & Grease	DWO	Inner Harbor	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	138173
47	4/26/2012	3018 Overland Ave	21214	Unknown	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138191
48	4/27/2012	725 Highwood Drive	21212	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	138261
49	4/27/2012	4705 Kernwood Ave	21212	Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138267
50	4/29/2012	724 Wharton Ct	21205	Rags & Grease	WVO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	425	Pressure Jet relieved Mainline choke	Turn over to CCTV	138328
51	4/29/2012	Belair Rd & Parkside Dr	21206	Rags, Roots & Sand, Gravel, Rocks	WVO	Herring Run	4:20	10:25 AM - 2:45 PM	Gray Water	2,600	Pressure Jet relieved Mainline choke	Turn over to CCTV	138307
52	4/30/2012	1621 N Smallwood St	21216	Rags & Debris	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	138374
53	4/30/2012	1838 E 29th St	21218	Rags	DWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138357
54	4/30/2012	2254 Linden Ave	21217	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138339

SSO Notification List

April 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
55	4/30/2012	4002 Wabash Ave	21215	Rags & Debris	DWO	Jones Falls	1:00	12:50 PM - 1:50PM	Gray Water	60	Pressure Jet relieved Mainline choke	Turn over to CCTV	138354
56	4/30/2012	5082 Orville Ave	21205	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	138387
				# WWO	15				TOTAL	24,618	EVIDENCE ONLY	36	