

SSO Notification List

May 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	5/1/2012	621 S. Glover St.	21224	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138501
2	5/1/2012	2310 Cedley St	21230	Grease, Sand, Gravel, Rocks	WWO	Patapsco	2:24	8:36AM - 11:00AM	Heavy Gray Water	144	Pressure Jet relieved Mainline choke	Turn over to CCTV	138410
3	5/1/2012	3900 Groveland Ave	21214	Unknown	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138436
4	5/2/2012	611 E. 34th St	21218	Rags, Trash & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138483
5	5/3/2012	408 E. Oliver St.	21202	Trash, Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138545
6	5/3/2012	2200 Clyburn Ave	21209	Rags, Rocks	WWO	Jones Falls	2:34	11:08AM - 1:47PM	Heavy Gray Water	2,385	Pressure Jet relieved Mainline choke	Turn over to CCTV	138550
7	5/3/2012	3908 Groveland Ave	21215	Rags	WWO	Jones Falls	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138564
8	5/3/2012	4213 Ridgewood Ave	21215	Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water & Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138567
9	5/3/2012	5801 Arizona Ave	21206	Rags & Debris	WWO	Herring Run	1:15	6:50PM - 8:05PM	Sewer Water		Pressure Jet relieved Mainline choke	Turn over to CCTV	138585
10	5/6/2012	607 Turnbridge Rd	21212	Unknown	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138678
11	5/6/2012	4906 Wimslow Rd	21210	Sand, Gravel, Rocks	WWO	Jones Falls	15:55	5:35PM - 9:30AM	Heavy Gray Water	955	Electric Machine relieved House Connection choke	Turn over to CCTV	138691
12	5/6/2012	5617 Plymouth Rd	21214	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138597
13	5/7/2012	502 Evesham Ave	21212	Rocks	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Clear Colored Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138733
14	5/7/2012	1313 North Ave	21213	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris & Feaces in Yard of 1311	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138765
15	5/8/2012	824 N. Payston St	21217	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138797
16	5/9/2012	2202 E. Fairmount Ave	21231	Rags & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	None Noted	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138839
17	5/9/2012	3921 Maine Ave	21207	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	138869
18	5/11/2012	4701 East Ln	21210	Unknown	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	N/A	Turn over to CCTV	138972
19	5/11/2012	4923 St. Georges Ave	21212	Trash & Roots	DWO	Herring Run	2:15	10:00AM - 12:15PM	Brown & Gray Colored Water	675	Pressure Jet relieved Mainline choke	Turn over to CCTV	138952
20	5/13/2012	1000 N. Gilmor St.	21217	Rags & Grease	DWO	Inner Harbor	2:00	1:00PM - 3:00PM	Heavy Gray Water	240	Pressure Jet relieved Mainline choke	Turn over to CCTV	139035
21	5/13/2012	1043 W. Barre St	21230	Unknown	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139050
22	5/13/2012	2218 Hill House Rd	21207	Rags, Grease & Trash	DWO	Gwynns Falls	1:50	3:15PM - 5:05PM	Gray & Brown Colored Water	1,100	Pressure Jet relieved Mainline choke	Turn over to CCTV	139041
23	5/13/2012	5100 Wetheredsville Rd	21207	Rags, Grease & Trash	DWO	Gwynns Falls	0:45	5:15PM - 6:00PM	Rags & Brown Colored Water	450	Pressure Jet relieved Mainline choke	Turn over to CCTV	139046
24	5/14/2012	1618 McCulloh St.	21217	Rags & Roots	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139077
25	5/14/2012	1751 E Pratt St	21231	Mud	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139086
26	5/16/2012	123 S. Curly St	21224	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139204
27	5/16/2012	1220 bayard St	21230	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139177

SSO Notification List

May 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
28	5/16/2012	2003 E. 32nd St	21218	Debris & Grease	DWO	Herring Run	2:20	5:25PM - 7:45PM	Sewer Water	280	Pressure Jet relieved Mainline choke	Turn over to CCTV	139205
29	5/16/2012	2100 Louise Ave	21214	Rags, Roots & Grease	DWO	Herring Run	2:01	8:29PM - 10:30PM	Sewer Water	242	Pressure Jet relieved Mainline choke	Turn over to CCTV	139212
30	5/16/2012	2509 Shelleydale Dr	21209	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139168
31	5/16/2012	2536 Washington Blvd	21230	Rags & Roots	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139178
32	5/17/2012	4701 East Ln	21210	Rags	DWO	Jones Falls	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139255
33	5/18/2012	2257 Sidney Ave	21230	Rags	DWO	Patapsco	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139289
34	5/18/2012	2765 Chesterfield Ave	21213	Rags & Grease	DWO	Herring Run	18:30	5/18/2012 6:30PM-5/19/2012 1:PM	Gray Colored Water, Paper & Rags	5,550	Pressure Jet relieved Mainline choke	Turn over to CCTV	139299
35	5/19/2012	324 S. Augusta Ave	21229	Unknown	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139322
36	5/20/2012	325 E. Belvedere Ave	21212	Unknown	WWO	None	12:00	5/20/2012 10:00PM-5/21/2012 10:00AM	Gray Colored Water & Paper	720	Pressure Jet relieved Mainline choke	Turn over to CCTV	139348
37	5/20/2012	2562 Marbourne Ave	21230	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139334
38	5/21/2012	1653 Northwick Ct	21218	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139394
39	5/22/2012	3024 Iona Terrace	21214	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Wet Paper Around Clean Out	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139438
40	5/22/2012	4018 8th Street	21225	Pipe Break	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	N/A	Repair House Connection to stop leak	139439
41	5/23/2012	425 N. Glover St.	21224	Rags, Trash & Grease	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139475
42	5/23/2012	834 Chauncey Ave	21217	Rags, Grease & Debris	WWO	Jones Falls	0:52	9:38 PM - 10:30 PM	Sewer Water	780	Pressure Jet relieved Mainline choke	Turn over to CCTV	139525
43	5/23/2012	5510 Fernpark Ave	21207	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139576
44	5/24/2012	5612 Park Heights Ave	21215	N/A	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139542
45	5/25/2012	3327 Elmley Ave	21213	Roots	DWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139615
46	5/26/2012	416 E. Oliver St	21202	Mud	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139636
47	5/26/2012	2730 N. Longwood St	21216	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Heavy Gray Water	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139638
48	5/26/2012	Club Rd & Indian Ln	21210	Rags, Roots & Grease	DWO	Jones Falls	3:24	11:36 AM - 3:00 PM	Heavy Gray Water	204	Pressure Jet relieved Mainline choke	Turn over to CCTV	139643
49	5/26/2012	702 Bethnal Rd	21229	Rags, Pipe Break & Roots	DWO	Gwynns Falls	3:06	11:29 AM - 2:45 PM	Heavy Gray Water	186	Pressure Jet relieved Mainline choke	Turn over to CCTV	139644
50	5/26/2012	730 E. Patapsco Ave	21225	Rags & Grease	DWO	Patapsco	3:21	2:03 PM - 5:24 PM	Heavy Gray Water	201	Pressure Jet relieved Mainline choke	Turn over to CCTV	139648
51	5/26/2012	1646 Lochwood Rd	21218	N/A	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	139653
52	5/26/2012	3518 Manchester Ave	21215	Rags, Roots & Grease	DWO	Gwynns Falls	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	139663
53	5/27/2012	2705 Shirey Ave	21214	N/A	WWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Unknown	Evidence of Overflow	Electric Machine relieved House Connection choke	N/A	139682
54	5/28/2012	2705 Shirey Ave	21214	Rags & Grease	DWO	Herring Run	0:50	12:30 PM - 1:20 PM	Gray Water	100	Pressure Jet relieved Mainline choke	Turn over to CCTV	139691

SSO Notification List

May 2012

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
55	5/28/2012	2464 Lakeview Ave	21217	Rags & Debris	DWO	Jones Falls	5:20	1:25 PM - 6:45 PM	Sewer Water	1,600	Pressure Jet relieved Mainline choke	Turn over to CCTV	139696
56	5/28/2012	Guliford Ave & E. 26th St	21218	N/A	DWO	Jones Falls	3:20	2:10 PM - 5:30 PM	Paper Debris	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	139700
57	5/29/2012	2464 Lakeview Ave	21217	Rags & Grease	WWO	Jones Falls	1:20	10:20 AM - 11:40 AM	Gray Water	80	Pressure Jet relieved Mainline choke	Turn over to CCTV	139732
58	5/29/2012	1524 N. Mount St	21217	Unknown	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water & Paper Debris	Evidence of Overflow	Turned over to the Health Dept.	N/A	139758
59	5/29/2012	26th St & Guilford Ave	21218	Rags, Grease & Trash	WWO	Jones Falls	1:30	12:30 PM - 2:00 PM	Brown & Gray Colored Water	4,500	Pressure Jet relieved Mainline choke	Turn over to CCTV	139749
60	5/30/2012	5501 Fernpark Ave	21207	Rags	WWO	None	Overflow not Witnessed	Overflow not Witnessed	Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139796
61	5/30/2012	5101 Harford Rd	21214	Rags	WWO	Herring Run	Overflow not Witnessed	Overflow not Witnessed	Sewer water, Paper Debris & Feces	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139817
62	5/31/2012	3523 Oakmont Ave	21215	Rags & Grease	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Gray Colored Water	Evidence of Overflow	Pressure Jet relieved Mainline choke	Turn over to CCTV	139853
63	5/31/2012	445 Kenneth Sq	21212	Rags	DWO	None	Overflow not Witnessed	Overflow not Witnessed	Sewer Water & Paper Debris	Evidence of Overflow	Electric Machine relieved House Connection choke	Turn over to CCTV	139874
				# WWO	27				TOTAL	15,812	EVIDENCE ONLY	38	

Monthly Record of Spills of Wastewater at the Patapsco Wastewater Treatment Plant

Date	Location	Cause	Notifications	Actions
<i>There were no reportable spills at the Patapsco WWTP during May 2012</i>				

Monthly Record of Spills of Wastewater at the Back River Wastewater Treatment Plant

Date	Location	Cause	Notifications
<i>There were no reportable spills at Back River WWTP during May 2</i>			

Monthly Record of Spills of Wastewater at the Back River Wastewater Treatment Plant

Actions
'012

Monthly Record of Spills of Wastewater at Pumping Stations

Date	Location	Cause	Notifications	Actions
<i>There were no reportable spills at the pumping stations during May 2012</i>				

Monthly Record of Combined Sewer or Sanitary Sewer Overflows

Date	Location	Cause	Notifications	Actions
<i>There were no reportable combined sewer overflows during May 2012</i>				