

SSO Notification List

September 2024

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	9/3/2024	2415 W Franklin St	21223	Rags	Dry	—	—	Wastewater observed near cleanout.	2	Relieved house connection choke with 35 ft of electric cable.	CCTV confirmed house connection is clear.	1371494
2	9/5/2024	4122 Marx Ave	21206	Rags, Infiltration, Trash	Dry	Herring Run	62	Subsurface sanitary sewer overflow entering the storm drain underground.	124	Relieved mainline choke with 450 ft of pressure hose.	Confirmed abatement via Office of Research & Environmental Protection.	1372218
3	9/5/2024	120 N Fremont Ave	21201	Rags, Trash	Dry	—	—	Evidence of overflow from rear cleanout caused by mainline choke.	1	Relieved mainline choke with 250 ft of pressure hose.	Confirmed line is clear; CCTV will be performed.	1372390
4	9/6/2024	206 E Eager St	21202	Roots	Dry	—	—	Wastewater observed near the cleanout.	1	Relieved house connection choke with 30 ft electric cable.	Performed CCTV inspection.	1372672
5	9/7/2024	5702 Putney Way	21212	Roots	Dry	Stony Run	2854	Mainline sewer choke causing overflow at property cleanout.	1427	Pressure truck jetted the sewer pipe to relieve blockage.	Roots will be cut and CCTV performed.	1373032
6	9/9/2024	120 N Fremont Ave	21201	Rags, Trash	Dry	—	—	Observed evidence of overflow from rear cleanout due to mainline choke.	1	Relieved mainline choke with 250 ft pressure hose.	Performed CCTV; observed house connection and mainline clear	1372962
7	9/9/2024	313 W 30th St	21211	Trash	Dry	—	—	Wastewater overflowed from rear house connection choke.	5	Ran 30 ft of cable to relieve choke.	Performed CCTV inspection on lateral connection.	1372991
8	9/10/2024	326 Rossiter Ave	21212	Rags, Trash	Dry	Stony Run	—	Wastewater observed near the manhole in intersection.	6	Relieved mainline choke with 300 ft of pressure hose.	Confirmed the mainline is clear at this time.	—
9	9/10/2024	3607 Everett St	21226	Rags, Trash	Dry	—	—	Wastewater observed in the alley near the manhole.	5	Relieved mainline choke with 200 ft of pressure hose.	Confirmed mainline is clear; CCTV will be performed.	1373326
10	9/10/2024	1001 N Ellamont St	21216	Rags, Trash	Dry	Gwynns Falls	672	Wastewater discharging from manhole and reaching storm drain.	2016	Relieved mainline choke using 400 ft pressure electric cable.	Confirmed mainline is clear at this time.	1373347
11	9/13/2024	1903 W North Ave	21213	Rags	Dry	Northwest Harbor	—	Wastewater observed at cleanout in the rear of property.	1	Relieved house connection choke with 30 ft pressure hose.	Confirmed house connection is clear at this time.	1374773
12	9/15/2024	300 E 33rd St	21218	Rags, Trash	Dry	—	—	Wastewater evidence seen from upstream manhole	5	Pressure truck relieved choke in mainline.	Confirmed mainline is clear.	1374969
13	9/19/2024	2332 Madison Ave	21217	Rags, Trash, Structural	Wet	—	—	Wastewater observed near cleanout in rear of property	1	Relieved house connection choke with 30 ft electric machine	House connection found broken and referred for repairs	1376584
14	9/19/2024	109 Elmhurst Rd	21210	Rags, Trash	Wet	Jones Falls	468	Wastewater flowing from manhole near storm drain inlet.	2340	Relieved mainline choke with 400 ft of pressure hose.	Confirmed the line is clear; CCTV will be performed.	1377279
15	9/24/2024	4310 Lasalle Ave	21206	Rags, Trash, Sand, Gravel, Rocks	Wet	Biddison Run	76	Mainline choke causing subsurface overflow into existing storm drain	380	Relieved mainline choke with pressure hose	Abatement confirmed via Office of Research & Environmental Protection	1378807
16	9/26/2024	Charing Cross Rd & Greenwich Ave - SSO Site #156	21229	Rain	Wet	Maidens Choice	40	Wastewater discharge out of manhole structure.	3000	SSO structure; overflow due to heavy rain.	SSO structure will be closed upon completion of capital improvement projects.	—
17	9/26/2024	1901 Falls Rd - SSO Site #67	21217	Rain	Wet	Jones Falls	145	Wastewater discharge from sewer manhole structure	544040	SSO structure, overflow due to heavy rain.	SSO structure will be closed upon completion of capital improvement projects.	—
18	9/26/2024	428 E Preston St - SSO Site #72	21202	Rain	Wet	Jones Falls	200	Wastewater discharge out of manhole structure	926000	SSO structure; overflow due to heavy rain.	SSO structure will be closed upon completion of capital improvement projects.	—
19	9/26/2024	4403 Frederick Ave	21229	Rags, Rain, Grease	Wet	Maidens Choice	368	Wastewater overflowing from manhole into parking lot.	368	Relieved mainline choke with 500 ft of pressure hose.	Confirmed mainline is clear at this time. CCTV will be performed.	1379458
20	9/27/2024	827 Brinkwood Rd	21229	Rags, Other	Wet	—	—	Wastewater observed in area of rear cleanout	3	House connection choke was relieved using 30 ft of electric machine cable.	Advised citizen about the proper usage/disposal of materials in our sewage system.	1379631
21	9/28/2024	1435 Homestead St	21218	Roots	Wet	—	—	Wastewater present from cleanout in rear of property	3	Used cutters to relieve choked house connection	No action taken at this time	1379847

SSO Notification List

September 2024

WWO

9

TOTAL

1,479,729

UNDER 100 GALLONS

12