

SSO Notification List												
September 2025												
Serial No.	Date of Occurrence	Location	Zip Code	Reason	Dry or Wet-Weather Overflow?	Stream Affected	Duration (Min)	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	9/2/2025	4849 Pimlico Rd	21215	Grease	Dry	—	—	Observed wastewater coming from side house connection	2	Relieved house connection choke with 25 ft electric cable	Confirmed house connection is clear at this time. CCTV was performed	1474489
2	9/2/2025	617 N Calhoun St	21217	Roots, Structural	Dry	—	—	Wastewater observed at the rear of the property.	2	Ran 100 ft of electric cable through the lateral; determined damage exists.	Further investigation will take place after advising consumer to install closer cleanout.	1474720
3	9/5/2025	6301 Quad Ave	21205	Structural	Wet	Herring Run	16001	Wastewater leak exfiltrating above siphon.	TBD	Work has been referred to Engineering & Construction	Further evaluation and coordination are immediate next steps to stop the SSO and perform repairs.	1475511
4	9/5/2025	5015 Anntana Ave	21206	Rags, Trash	Wet	—	—	Wastewater with heavy rags and debris	1	Relieved choke in 8" sanitary sewer main with 250' of pressure hose	CCTV Inspection will be performed	1475569
5	9/5/2025	1535 Homestead St	21218	Structural	Wet	—	—	Observed wastewater coming from front house connection	2	CCTV inspection found broken pipe	Bypass pumping was installed and turned over to construction for repairs	1475611
6	9/6/2025	214 Cedarcroft Rd	21212	Rags, Trash	Wet	—	—	Wastewater with rags and debris	1	Relieved mainline choke using 450' of pressure hose	CCTV Inspection has been scheduled	1475727
7	9/7/2025	4600 Falls Rd	21210	Rags, Grease, Trash	Wet	—	245	Observed wastewater coming from manhole	245	Relieved mainline choke with 400 ft pressure hose	Confirmed mainline is clear at this time. CCTV will be performed	1475824
8	9/8/2025	3306 Spaulding Ave	21215	Structural	Dry	—	—	Observed wastewater at side house connection	1	Attempt to relieve house connection choke with 120 ft electric cable found broken pipe.	Bypass Pumping was installed to stop the SSO and referred for repair	1475898
9	9/8/2025	436 Kane St	21224	Rags, Grease	Dry	—	257	Observed wastewater coming from manhole	257	Relieved mainline choke with 300 ft pressure hose	Confirmed mainline is clear and flowing freely at this time. CCTV will be performed	1476212
10	9/10/2025	2717 Hollins Ferry Rd	21230	Structural	Dry	—	—	Wastewater	1	Attempted to relieve choke with spearhead cables and set up bypass pumping	Left note with homeowner to repair broken house connection	1476643
11	9/10/2025	617 N Calhoun St	21217	Rags	Dry	—	—	Wastewater with rags	1	Relieved choke with 95ft of electric machine cables with spear head cutters	CCTV Inspection will be performed	1476650
12	9/10/2025	504 E 36th St	21218	Rags, Roots	Dry	—	—	Observed wastewater at front house connection	1	Relieved house connection choke with 60 ft electric cable	Confirmed house connection is clear at this time. CCTV will be performed	1476756
13	9/12/2025	1533 W Lombard St	21223	Roots	Wet	—	—	Observed wastewater at rear house connection	1	Relieved house connection choke with 30 ft electric cable	Confirmed house connection is clear at this time. CCTV was performed	1477410
14	9/13/2025	5707 Cross Country Blvd	21209	Rags, Grease	Wet	—	295	Wastewater with rags and grease	590	Relieved main line choke using 400ft of pressure hose	CCTV Inspection will be performed	1477657
15	9/18/2025	4712 Club Rd	21210	Rags, Grease, Trash	Wet	Jones Falls	274	Observed wastewater coming from manhole flowing into nearby stream	2192	Relieved mainline choke with 500 ft pressure hose	Confirmed mainline is clear at this time and has been referred for CCTV	1479148
16	9/18/2025	5656 The Alameda	21239	Rags, Roots	Wet	Chinquapin Run	—	Wastewater roots and rags	1	Relieved choke using electric machine with expander cutters.	CCTV Inspection was performed	1479175
17	9/20/2025	201 W Lanvale St	21217	Roots	Dry	—	—	Wastewater with roots	2	Relieved choke with 30ft electric machine cable with expander cutter	CCTV Inspection was performed	1479669
18	9/22/2025	206 E Eager St	21202	Rags, Roots	Dry	—	—	Observed wastewater coming from front house connection	1	Relieved house connection choke with 30 ft electric cable	Confirmed house connection is clear at this time. CCTV was performed	1479781
19	9/22/2025	2212 Russell St	21230	Rags, Grease, Trash	Dry	Gwynns Falls	485	Observed wastewater coming from manhole	485	Relieved flushed and cleaned mainline with 400 ft pressure hose	Confirmed mainline is clear at this time. Referred for CCTV	1479793
20	9/23/2025	336 S Calhoun St	21223	Rags, Grease, Trash	Dry	—	80	Observed wastewater coming from manhole	160	Relieved mainline choke with 200 ft pressure hose	Confirmed mainline is clear at this time. Referred for CCTV	1480023

SSO Notification List												
September 2025												
21	9/23/2025	948 Montpelier St	21218	Roots	Dry	—	168	Observed wastewater coming from rear house connection	168	Relieved house connection choke with 30 ft electric cable	Confirmed house connection is clear at this time. CCTV was performed	1480048
22	9/23/2025	502 E Cold Spring Ln	21212	Grease, Trash	Dry	Tiffany Run	1198	Observed wastewater overflow into nearby storm drain	1198	Relieved mainline choke with 250 ft pressure hose	Confirmed mainline is clear at this time. CCTV will be performed	1480225
23	9/23/2025	2518 Keyworth Ave	21215	Rags, Roots, Trash	Dry	—	—	Observed wastewater at rear house connection	1	Relieved house connection with 60 ft electric cable	Confirmed house connection is clear at this time. CCTV was performed	1480285
24	9/25/2025	104 S Clinton St	21224	Rags, Grease	Wet	—	—	Observed wastewater coming from rear house connection	1	Relieved house connection choke with 30 ft electric cable	Confirmed house connection is clear at this time. CCTV will be performed	1481238
25	9/29/2025	Steelton Ave & Gray Ave	21224	Rags, Grease	Dry	Inner Harbor	837	Wastewater with grease and rags	6696	Relieved choke with pressure hose	CCTV Inspection will be performed	1482307
				# WWO	10			TOTAL	12,010*	UNDER 100 GALLONS	15	